

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Battle Creek Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
02-01A Kitchen Food Prep Sink Faucet	8/13/16 10:20	8/22/16 11:00	608151601	COPPER	0.3 PPM	1.3 PPM
02-02A Cafeteria Drinking Fountain #1	8/13/16 10:24	8/22/16 11:00	608151602	COPPER	1.0 PPM	1.3 PPM
02-03A Cafeteria Drinking Fountain #2	8/13/16 10:24	8/22/16 11:00	608151603	COPPER	0.9 PPM	1.3 PPM
02-04A Gymnasium Drinking Fountain #1	8/13/16 10:30	8/22/16 11:00	608151604	COPPER	0.9 PPM	1.3 PPM
02-05A Gymnasium Drinking Fountain #2	8/13/16 10:30	8/22/16 11:00	608151605	COPPER	0.9 PPM	1.3 PPM
02-06A Classroom 186 Sink Faucet	8/13/16 10:33	8/22/16 11:00	608151606	COPPER	0.4 PPM	1.3 PPM
02-07A Classroom 186 Drinking Fountain #1	8/13/16 10:33	8/22/16 11:01	608151607	COPPER	0.6 PPM	1.3 PPM
02-08A Classroom 186 Drinking Fountain #2	8/13/16 10:35	8/23/16 9:11	608151608	COPPER	1.9 PPM	1.3 PPM
02-09A Classroom 186 Drinking Fountain #3	8/13/16 10:35	8/23/16 9:11	608151609	COPPER	1.9 PPM	1.3 PPM
02-10A Bathroom 191/192 Drinking Fountain #1	8/13/16 10:40	8/22/16 11:02	608151610	COPPER	0.6 PPM	1.3 PPM
02-11A Bathroom 191/192 Drinking Fountain #2	8/13/16 10:40	8/22/16 11:02	608151611	COPPER	0.7 PPM	1.3 PPM
02-12A Staff Lounge Sink Faucet	8/13/16 10:51	8/22/16 11:02	608151612	COPPER	0.5 PPM	1.3 PPM
02-13A Room (PLC) 113 Sink Faucet	8/13/16 10:49	8/22/16 11:02	608151613	COPPER	0.5 PPM	1.3 PPM
02-14A Classroom 101 Sink Faucet	8/13/16 10:55	8/22/16 11:02	608151614	COPPER	0.4 PPM	1.3 PPM
02-15A Classroom 101 Drinking Fountain	8/13/16 10:55	8/22/16 11:02	608151615	COPPER	0.5 PPM	1.3 PPM
02-16A Classroom 102 Sink Faucet	8/13/16 10:57	8/22/16 11:02	608151616	COPPER	0.3 PPM	1.3 PPM
02-17A Classroom 102 Drinking Fountain	8/13/16 10:57	8/22/16 11:03	608151617	COPPER	0.5 PPM	1.3 PPM
02-18A Classroom 103 Sink Faucet	8/13/16 11:00	8/22/16 11:03	608151618	COPPER	0.3 PPM	1.3 PPM
02-19A Classroom 103 Drinking Fountain	8/13/16 11:00	8/22/16 11:03	608151619	COPPER	0.3 PPM	1.3 PPM
02-20A Classroom 104 Sink Faucet	8/13/16 11:02	8/22/16 11:03	608151620	COPPER	0.5 PPM	1.3 PPM
02-21A Classroom 104 Drinking Fountain	8/13/16 11:02	8/22/16 11:03	608151621	COPPER	0.6 PPM	1.3 PPM
02-22A Classroom 105 Sink Faucet	8/13/16 11:05	8/22/16 11:03	608151622	COPPER	0.4 PPM	1.3 PPM
02-23A Classroom 105 Drinking Fountain	8/13/16 11:05	8/22/16 11:03	608151623	COPPER	0.4 PPM	1.3 PPM
02-24A Classroom 106 Sink Faucet	8/13/16 11:07	8/22/16 11:03	608151624	COPPER	0.7 PPM	1.3 PPM
02-25A Classroom 106 Drinking Fountain	8/13/16 11:07	8/22/16 11:04	608151625	COPPER	0.5 PPM	1.3 PPM
02-26A Classroom 107 Sink Faucet	8/13/16 11:19	8/22/16 11:04	608151626	COPPER	0.4 PPM	1.3 PPM
02-27A Classroom 107 Drinking Fountain	8/13/16 11:19	8/22/16 11:05	608151627	COPPER	0.6 PPM	1.3 PPM
02-28A Classroom 108 Sink Faucet	8/13/16 11:22	8/22/16 11:05	608151628	COPPER	0.4 PPM	1.3 PPM
02-29A Classroom 108 Drinking Fountain	8/13/16 11:22	8/22/16 11:05	608151629	COPPER	0.5 PPM	1.3 PPM
02-30A Classroom 109 Sink Faucet	8/13/16 11:24	8/22/16 11:05	608151630	COPPER	0.4 PPM	1.3 PPM
02-31A Classroom 109 Drinking Fountain	8/13/16 11:24	8/22/16 11:05	608151631	COPPER	0.5 PPM	1.3 PPM
02-32A Hallway Drinking Fountain #1	8/13/16 11:27	8/22/16 11:05	608151632	COPPER	0.6 PPM	1.3 PPM
02-33A Hallway Drinking Fountain #2	8/13/16 11:22	8/22/16 11:05	608151633	COPPER	0.6 PPM	1.3 PPM
02-34A Classroom 110 Sink Faucet	8/13/16 11:29	8/22/16 11:05	608151634	COPPER	0.4 PPM	1.3 PPM
02-35A Classroom 110 Drinking Fountain	8/13/16 11:29	8/22/16 11:05	608151635	COPPER	0.6 PPM	1.3 PPM
02-36A Classroom 111 Sink Faucet	8/13/16 11:32	8/22/16 11:05	608151636	COPPER	0.4 PPM	1.3 PPM
02-37A Classroom 111 Drinking Fountain	8/13/16 11:32	8/22/16 11:06	608151637	COPPER	0.5 PPM	1.3 PPM
02-38A Wet Lab Sink Faucet #1	8/13/16 11:45	8/22/16 11:06	608151638	COPPER	0.4 PPM	1.3 PPM
02-39A Wet Lab Sink Faucet #2	8/13/16 11:46	8/22/16 11:06	608151639	COPPER	0.4 PPM	1.3 PPM
02-40A Wet Lab Sink Faucet #3	8/13/16 11:46	8/22/16 11:06	608151640	COPPER	0.3 PPM	1.3 PPM
02-41A Wet Lab Sink Faucet #4	8/13/16 11:47	8/22/16 11:06	608151641	COPPER	0.5 PPM	1.3 PPM
02-42A Wet Lab Sink Faucet #5	8/13/16 11:47	8/22/16 11:06	608151642	COPPER	0.4 PPM	1.3 PPM
02-43A Wet Lab Sink Faucet #6	8/13/16 11:48	8/22/16 11:06	608151643	COPPER	0.1 PPM	1.3 PPM
02-44A Wet Lab Sink Faucet #7	8/13/16 11:48	8/22/16 11:06	608151644	COPPER	0.4 PPM	1.3 PPM
02-45A Bathroom Drinking Fountain 239/240	8/13/16 11:38	8/22/16 11:06	608151645	COPPER	0.6 PPM	1.3 PPM
02-46A Classroom (LRC) 200 Sink Faucet	8/13/16 11:53	8/22/16 11:06	608151646	COPPER	0.4 PPM	1.3 PPM
02-47A Classroom (LRC) 200 Drinking Fountain	8/13/16 11:53	8/22/16 11:10	608151647	COPPER	0.4 PPM	1.3 PPM
02-48A Classroom 212 Sink Faucet	8/13/16 11:56	8/22/16 11:10	608151648	COPPER	0.4 PPM	1.3 PPM
02-49A Classroom 212 Drinking Fountain	8/13/16 11:56	8/22/16 11:10	608151649	COPPER	0.4 PPM	1.3 PPM
02-50A Room (PLC) 213 Sink Faucet	8/13/16 12:01	8/22/16 11:10	608151650	COPPER	0.5 PPM	1.3 PPM
02-51A Classroom 201 Sink Faucet	8/13/16 12:03	8/22/16 11:10	608151651	COPPER	0.4 PPM	1.3 PPM
02-52A Classroom 201 Drinking Fountain	8/13/16 12:03	8/22/16 11:10	608151652	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Battle Creek Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
02-53A Classroom 202 Sink Faucet	8/13/16 12:07	8/22/16 11:10	608151653	COPPER	0.4 PPM	1.3 PPM
02-54A Classroom 202 Drinking Fountain	8/13/16 12:07	8/22/16 11:11	608151654	COPPER	0.4 PPM	1.3 PPM
02-55A Classroom 203 Sink Faucet	8/13/16 12:12	8/22/16 11:11	608151655	COPPER	0.3 PPM	1.3 PPM
02-56A Classroom 203 Drinking Fountain	8/13/16 12:12	8/22/16 11:11	608151656	COPPER	0.4 PPM	1.3 PPM
02-57A Classroom 204 Sink Faucet	8/13/16 12:15	8/22/16 11:12	608151657	COPPER	0.4 PPM	1.3 PPM
02-58A Classroom 204 Drinking Fountain	8/13/16 12:15	8/22/16 11:12	608151658	COPPER	0.4 PPM	1.3 PPM
02-59A Classroom 205 Sink Faucet	8/13/16 12:17	8/22/16 11:12	608151659	COPPER	0.3 PPM	1.3 PPM
02-60A Classroom 205 Drinking Fountain	8/13/16 12:17	8/22/16 11:12	608151660	COPPER	0.4 PPM	1.3 PPM
02-61A Classroom 206 Sink Faucet	8/13/16 12:19	8/22/16 11:12	608151661	COPPER	0.5 PPM	1.3 PPM
02-62A Classroom 206 Drinking Fountain	8/13/16 12:19	8/22/16 11:12	608151662	COPPER	0.5 PPM	1.3 PPM
02-63A Room (PHC) 215 Sink Faucet	8/13/16 12:24	8/22/16 11:12	608151663	COPPER	0.5 PPM	1.3 PPM
02-64A Classroom 207 Sink Faucet	8/13/16 12:27	8/22/16 11:12	608151664	COPPER	0.4 PPM	1.3 PPM
02-65A Classroom 207 Drinking Fountain	8/13/16 12:27	8/22/16 11:12	608151665	COPPER	0.5 PPM	1.3 PPM
02-66A Classroom 208 Sink Faucet	8/13/16 12:28	8/22/16 11:12	608151666	COPPER	0.4 PPM	1.3 PPM
02-67A Classroom 208 Drinking Fountain	8/13/16 12:28	8/22/16 11:13	608151667	COPPER	0.5 PPM	1.3 PPM
02-68A Classroom 209 Sink Faucet	8/13/16 12:30	8/22/16 11:13	608151668	COPPER	0.4 PPM	1.3 PPM
02-69A Classroom 209 Drinking Fountain	8/13/16 12:30	8/22/16 11:13	608151669	COPPER	0.5 PPM	1.3 PPM
02-70A Hallway Drinking Fountain #3	8/13/16 12:33	8/22/16 11:13	608151670	COPPER	0.7 PPM	1.3 PPM
02-71A Hallway Drinking Fountain #4	8/13/16 12:33	8/22/16 11:13	608151671	COPPER	0.6 PPM	1.3 PPM
02-72A Classroom 210 Sink Faucet	8/13/16 12:35	8/22/16 11:13	608151672	COPPER	0.4 PPM	1.3 PPM
02-73A Classroom 210 Drinking Fountain	8/13/16 12:35	8/22/16 11:13	608151673	COPPER	0.4 PPM	1.3 PPM
02-74A Classroom 211 Sink Faucet	8/13/16 12:38	8/22/16 11:13	608151674	COPPER	0.3 PPM	1.3 PPM
02-75A Classroom 211 Drinking Fountain	8/13/16 12:38	8/22/16 11:13	608151675	COPPER	0.4 PPM	1.3 PPM
02-76A Health Room Office Sink Faucet	8/13/16 11:38	8/22/16 11:13	608151676	COPPER	0.7 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
Flushed (B) Sample Data  
Battle Creek Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
02-08B Classroom 186 Drinking Fountain #2	8/13/16 10:36	9/30/16 17:02	609280801	COPPER	1.7 PPM	1.3 PPM
02-09B Classroom 186 Drinking Fountain #3	8/13/16 10:36	9/30/16 17:03	609280802	COPPER	1.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level