

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Bethel Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
66-01A Classroom 2 Sink Faucet	7/20/2016 12:35	7/27/2016	42850	LEAD	10 PPB	15 PPB
66-02A Activity Room Drinking Fountain	7/20/2016 12:37	7/27/2016	42851	LEAD	23 PPB	15 PPB
66-03A Activity Room Sink Faucet	7/20/2016 12:39	7/27/2016	42852	LEAD	15 PPB	15 PPB
66-04A Classroom 1 Sink Faucet	7/20/2016 12:42	7/27/2016	42853	LEAD	4 PPB	15 PPB
66-05A Classroom 1 Drinking Fountain	7/20/2016 12:44	7/27/2016	42854	LEAD	1 PPB	15 PPB
66-06A Front Entry Drinking Fountain	7/20/2016 12:46	7/27/2016	42855	LEAD	10 PPB	15 PPB
66-07A Media Room Sink Faucet	7/20/2016 12:54	7/27/2016	42856	LEAD	5 PPB	15 PPB
66-08A Modular Classroom 3 Sink Faucet	7/20/2016 12:57	7/27/2016	42857	LEAD	<1 PPB	15 PPB
66-09A Modular Classroom 3 Drinking Fountain	7/20/2016 12:59	7/27/2016	42858	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Bethel Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
66-02B Activity Room Drinking Fountain	7/20/2016 12:38	9/6/2016	53423	LEAD	3 PPB	15 PPB
66-03B Activity Room Sink Faucet	7/20/2016 12:40	9/6/2016	53424	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Bethel Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
66-02C Activity Room Drinking Fountain	1/20/2017 6:51	1/23/2017	3137	LEAD	9 PPB	15 PPB
66-03C Activity Room Sink Faucet	1/20/2017 6:53	1/23/2017	3138	LEAD	21 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level