

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Centennial-Wheatland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
070-01A Classroom 2 Sink Faucet	8/3/16 4:55	8/11/16 11:29	608034001	LEAD	2 PPB	15 PPB
070-02A Classroom 1 Sink Faucet	8/3/16 4:56	8/11/16 11:29	608034002	LEAD	1 PPB	15 PPB
070-03A Classroom 4 Sink Faucet	8/3/16 4:59	8/11/16 11:30	608034003	LEAD	4 PPB	15 PPB
070-04A Classroom 4 Sink Faucet	8/3/16 4:59	8/11/16 11:30	608034004	LEAD	10 PPB	15 PPB
070-05A Hallway Drinking Fountain 1	8/3/16 5:02	8/11/16 11:30	608034005	LEAD	4 PPB	15 PPB
070-06A Kitchen Food Prep Sink Faucet	8/3/16 5:03	8/11/16 11:30	608034006	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level