

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Central Kitchen

Sampled Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
71-01A Sink Faucet by Sprinkler Control Room	8/6/16 10:57	8/14/2016	1608471-01A	LEAD	3 PPB	15 PPB
71-02A Test Kitchen Triple Basin Sink Faucet (Left)	8/6/16 11:01	8/14/2016	1608471-02A	LEAD	2 PPB	15 PPB
71-03A Test Kitchen Triple Basin Sink Faucet (Right)	8/6/16 11:01	8/14/2016	1608471-03A	LEAD	2 PPB	15 PPB
71-04A Mixing Basin Faucet	8/6/16 11:02	8/14/2016	1608471-04A	LEAD	10 PPB	15 PPB
71-05A Catering Sink Faucet	8/6/16 11:03	8/14/2016	1608471-05A	LEAD	1 PPB	15 PPB
71-06A Break Room Sink Faucet	8/6/16 11:04	8/14/2016	1608471-06A	LEAD	8 PPB	15 PPB
71-07A Hall by Fire Alarm Room Drinking Fountain	8/6/16 11:08	8/14/2016	1608471-07A	LEAD	<1.0 PPB	15 PPB
71-08A Loading Dock Ice Maker	8/6/16 11:10	8/14/2016	1608471-08A	LEAD	<1.0 PPB	15 PPB
71-09A Prep Area Sink Faucet	8/6/16 11:14	8/10/2016	1608471-09A	LEAD	1 PPB	15 PPB
71-10A Prep Area Sink Faucet	8/6/16 11:14	8/10/2016	1608471-10A	LEAD	5 PPB	15 PPB
71-11A Prep Area Hand Wash Sink Faucet	8/6/16 11:17	8/10/2016	1608471-11A	LEAD	4 PPB	15 PPB
71-12A Food Prep Double Sink Faucet	8/6/16 11:17	8/10/2016	1608471-12A	LEAD	3 PPB	15 PPB
<b>71-13A Food Prep Area Left Triple Sink Faucet</b>	<b>8/6/16 11:21</b>	<b>8/10/2016</b>	<b>1608471-13A</b>	<b>LEAD</b>	<b>18 PPB</b>	<b>15 PPB</b>
71-14A Food Prep Area Right Triple Sink Faucet	8/6/16 11:21	8/10/2016	1608471-14A	LEAD	4 PPB	15 PPB
71-15A Mixer Faucet	8/6/16 11:24	8/14/2016	1608471-15A	LEAD	7 PPB	15 PPB
71-16A Middle of Food Prep Sink Faucet	8/6/16 11:26	8/14/2016	1608471-16A	LEAD	2 PPB	15 PPB
71-17A Food Prep Hand Wash Sink Faucet	8/6/16 11:26	8/10/2016	1608471-17A	LEAD	2 PPB	15 PPB
71-18A Food Prep Vat Faucet	8/6/16 11:28	8/11/2016	1608471-18A	LEAD	14 PPB	15 PPB
71-19A Island Catering Kitchen Sink Faucet	8/6/16 11:29	8/14/2016	1608471-19A	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Central Kitchen

Sampled Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
71-18C Food Prep Vat Faucet	9/22/2016 4:30	9/26/2016	57959	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Central Kitchen

Sampled Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
71-13B Food Prep Area Left Triple Sink Faucet	8/6/16 11:22	8/26/2016	1608472-12A	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Central Kitchen

Sampled Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
71-13C Food Prep Area Left Triple Sink Faucet	9/14/2016 4:49	9/15/2016	55817	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**