

Salem-Keizer Public Schools
 Copper Water Sampling Results
 First Draw (A) Sample Data
 Central Services Center

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
72-01A Staff Lounge Sink Faucet	8/12/16 7:17	8/22/16 10:58	608151901	COPPER	0.4 PPM	1.3 PPM
72-02A Restroom Hall Drinking Fountain	8/12/16 7:18	8/22/16 10:58	608151902	COPPER	0.5 PPM	1.3 PPM
72-03A Restroom Hall (Construction Services) Drinking Fountain	8/12/16 3:42	8/22/16 10:58	608151903	COPPER	0.4 PPM	1.3 PPM
72-04A Restroom Hall (Construction Services) Bottle Refill	8/12/16 3:43	8/22/16 10:58	608151904	COPPER	0.4 PPM	1.3 PPM
72-05A Staff Lounge Sink Faucet	8/12/16 3:40	8/22/16 10:59	608151905	COPPER	0.2 PPM	1.3 PPM
72-06A Shop Area Sink Faucet	8/12/16 3:48	8/22/16 11:00	608151906	COPPER	0.3 PPM	1.3 PPM
72-07A Paint Shop Area Sink Faucet	8/12/16 3:50	8/22/16 11:00	608151907	COPPER	0.3 PPM	1.3 PPM
72-08A Shop Area (outside Restroom) Drinking Fountain	8/12/16 3:52	8/22/16 11:00	608151908	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level