

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Central Services Center

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
72-01A Staff Lounge Sink Faucet	8/12/16 7:17	8/22/16 10:58	608151901	LEAD	2 PPB	15 PPB
72-02A Restroom Hall Drinking Fountain	8/12/16 7:18	8/22/16 10:58	608151902	LEAD	< 1 PPB	15 PPB
72-03A Restroom Hall (Construction Services) Drinking Fountain	8/12/16 3:42	8/22/16 10:58	608151903	LEAD	6 PPB	15 PPB
72-04A Restroom Hall (Construction Services) Bottle Refill	8/12/16 3:43	8/22/16 10:58	608151904	LEAD	6 PPB	15 PPB
72-05A Staff Lounge Sink Faucet	8/12/16 3:40	8/22/16 10:59	608151905	LEAD	3 PPB	15 PPB
72-06A Shop Area Sink Faucet	8/12/16 3:48	8/22/16 11:00	608151906	LEAD	5 PPB	15 PPB
72-07A Paint Shop Area Sink Faucet	8/12/16 3:50	8/22/16 11:00	608151907	LEAD	< 1 PPB	15 PPB
72-08A Shop Area (outside Restroom) Drinking Fountain	8/12/16 3:52	8/22/16 11:00	608151908	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level