

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
06-01A Staff Lounge Sink Faucet	7/22/2016 11:02	7/28/2016	43584	COPPER	0.0 PPM	1.3 PPM
06-02A Nurse/Health Sink Faucet	7/22/2016 11:05	7/28/2016	43585	COPPER	0.1 PPM	1.3 PPM
06-03A Nurse/Health Drinking Fountain	7/22/2016 11:07	7/28/2016	43586	COPPER	0.1 PPM	1.3 PPM
06-04A Music Room Sink Faucet	7/22/2016 11:10	7/28/2016	43587	COPPER	0.1 PPM	1.3 PPM
06-05A Music Room Drinking Fountain	7/22/2016 11:12	7/28/2016	43588	COPPER	0.2 PPM	1.3 PPM
06-06A Hallway Drinking Fountain 1	7/22/2016 11:15	7/28/2016	43589	COPPER	0.1 PPM	1.3 PPM
06-07A Art Room Drinking Fountain	7/22/2016 11:18	7/28/2016	43590	COPPER	0.1 PPM	1.3 PPM
06-08A Art Room Sink Faucet	7/22/2016 11:20	8/2/2016	43591	COPPER	0.1 PPM	1.3 PPM
06-09A Hallway Drinking Fountain 2	7/22/2016 11:23	8/2/2016	43592	COPPER	0.1 PPM	1.3 PPM
06-10A Classroom 27 Sink Faucet	7/22/2016 11:28	8/2/2016	43593	COPPER	0.1 PPM	1.3 PPM
06-11A Classroom 27 Drinking Fountain	7/22/2016 11:30	8/2/2016	43594	COPPER	0.1 PPM	1.3 PPM
06-12A Classroom 1 Sink Faucet	7/22/2016 11:34	8/2/2016	43595	COPPER	0.1 PPM	1.3 PPM
06-13A Classroom 1 Drinking Fountain	7/22/2016 11:36	8/2/2016	43596	COPPER	0.1 PPM	1.3 PPM
06-14A Classroom 2 Sink Faucet	7/22/2016 11:39	8/2/2016	43597	COPPER	0.1 PPM	1.3 PPM
06-15A Classroom 2 Drinking Fountain	7/22/2016 11:41	8/2/2016	43598	COPPER	0.1 PPM	1.3 PPM
06-16A Classroom 3 Sink Faucet	7/22/2016 11:45	8/2/2016	43599	COPPER	0.1 PPM	1.3 PPM
06-17A Classroom 3 Drinking Fountain	7/22/2016 11:47	8/2/2016	43600	COPPER	0.1 PPM	1.3 PPM
06-18A Classroom 4 Sink Faucet	7/22/2016 11:50	8/2/2016	43601	COPPER	0.1 PPM	1.3 PPM
06-19A Classroom 4 Drinking Fountain	7/22/2016 11:52	8/2/2016	43602	COPPER	0.1 PPM	1.3 PPM
06-20A Classroom 5 Sink Faucet	7/22/2016 11:56	8/2/2016	43603	COPPER	0.1 PPM	1.3 PPM
06-21A Classroom 5 Drinking Fountain	7/22/2016 11:58	8/2/2016	43604	COPPER	0.1 PPM	1.3 PPM
06-22A Classroom 6 Sink Fountain	7/22/2016 12:00	8/2/2016	43605	COPPER	0.1 PPM	1.3 PPM
06-23A Classroom 6 Drinking Fountain	7/22/2016 12:02	8/2/2016	43606	COPPER	0.1 PPM	1.3 PPM
06-24A Classroom 7 Drinking Fountain	7/22/2016 12:05	8/2/2016	43607	COPPER	0.1 PPM	1.3 PPM
06-25A Classroom 7 Sink Faucet	7/22/2016 12:07	8/2/2016	43608	COPPER	0.1 PPM	1.3 PPM
06-26A Classroom 8 Sink Faucet	7/22/2016 12:10	8/2/2016	43609	COPPER	0.1 PPM	1.3 PPM
06-27A Classroom 8 Drinking Fountain	7/22/2016 12:12	8/2/2016	43610	COPPER	0.1 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
06-28A Computer Lab 25 Sink Faucet	7/22/2016 12:15	8/2/2016	43611	COPPER	0.1 PPM	1.3 PPM
06-29A Computer Lab 25 Drinking Fountain	7/22/2016 12:17	8/2/2016	43612	COPPER	0.1 PPM	1.3 PPM
06-30A Kitchen Food Prep Sink Faucet	7/22/2016 12:20	8/2/2016	43613	COPPER	0.1 PPM	1.3 PPM
06-31A Classroom 9 Sink Faucet	7/22/2016 12:23	8/2/2016	43614	COPPER	0.1 PPM	1.3 PPM
06-32A Classroom 9 Drinking Fountain	7/22/2016 12:25	8/2/2016	43615	COPPER	0.0 PPM	1.3 PPM
06-33A Classroom 10 Sink Fountain	7/22/2016 12:28	8/2/2016	43616	COPPER	0.1 PPM	1.3 PPM
06-34A Classroom 10 Drinking Fountain	7/22/2016 12:30	8/2/2016	43617	COPPER	0.1 PPM	1.3 PPM
06-35A Classroom 20 Sink Faucet	7/22/2016 12:34	8/2/2016	43618	COPPER	0.1 PPM	1.3 PPM
06-36A Classroom 20 Drinking Fountain	7/22/2016 12:36	8/2/2016	43619	COPPER	0.1 PPM	1.3 PPM
06-37A Classroom 19 Sink Faucet	7/22/2016 12:39	8/2/2016	43620	COPPER	0.1 PPM	1.3 PPM
06-38A Classroom 19 Drinking Faucet	7/22/2016 12:41	8/2/2016	43621	COPPER	0.1 PPM	1.3 PPM
06-39A Classroom 11 Sink Faucet	7/22/2016 12:45	8/2/2016	43622	COPPER	0.1 PPM	1.3 PPM
06-40A Classroom 11 Drinking Fountain	7/22/2016 12:47	8/2/2016	43623	COPPER	0.2 PPM	1.3 PPM
06-41A Classroom 12 Sink Faucet	7/22/2016 12:49	8/2/2016	43624	COPPER	0.2 PPM	1.3 PPM
06-42A Classroom 12 Drinking Fountain	7/22/2016 12:51	8/2/2016	43625	COPPER	0.1 PPM	1.3 PPM
06-43A Classroom 13 Sink Faucet	7/22/2016 12:54	8/2/2016	43626	COPPER	0.2 PPM	1.3 PPM
06-44A Classroom 13 Drinking Fountain	7/22/2016 12:56	8/5/2016	43627	COPPER	0.1 PPM	1.3 PPM
06-45A Classroom 14 Sink Faucet	7/22/2016 12:59	8/2/2016	43628	COPPER	0.1 PPM	1.3 PPM
06-46A Classroom 14 Drinking Fountain	7/22/2016 13:01	8/2/2016	43629	COPPER	0.1 PPM	1.3 PPM
06-47A Classroom 15 Sink Faucet	7/22/2016 13:04	8/2/2016	43630	COPPER	0.1 PPM	1.3 PPM
06-48A Classroom 15 Drinking Fountain	7/22/2016 13:06	8/2/2016	43631	COPPER	0.1 PPM	1.3 PPM
06-49A Classroom 16 Sink Faucet	7/22/2016 13:09	8/2/2016	43632	COPPER	0.2 PPM	1.3 PPM
06-50A Classroom 16 Drinking Fountain	7/22/2016 13:11	8/2/2016	43633	COPPER	0.1 PPM	1.3 PPM
06-51A Classroom 17 Sink Faucet	7/22/2016 13:14	8/2/2016	43634	COPPER	0.1 PPM	1.3 PPM
06-52A Classroom 17 Drinking Faucet	7/22/2016 13:16	8/2/2016	43635	COPPER	0.1 PPM	1.3 PPM
06-53A Classroom 18 Sink Faucet	7/22/2016 13:19	8/2/2016	43636	COPPER	0.0 PPM	1.3 PPM
06-54A Classroom 18 Drinking Fountain	7/22/2016 13:21	8/2/2016	43637	COPPER	0.0 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
06-55A Staff Lounge Drinking Fountain	7/22/2016 11:25	8/2/2016	43638	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
006-56A Book/Staff/Community Rm Sink Faucet	4/28/2017 6:17	5/2/2017	22386	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level