

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
06-01A Staff Lounge Sink Faucet	7/22/2016 11:02	7/28/2016	43584	LEAD	3 PPB	15 PPB
06-02A Nurse/Health Sink Faucet	7/22/2016 11:05	7/28/2016	43585	LEAD	6 PPB	15 PPB
06-03A Nurse/Health Drinking Fountain	7/22/2016 11:07	7/28/2016	43586	LEAD	10 PPB	15 PPB
06-04A Music Room Sink Faucet	7/22/2016 11:10	7/28/2016	43587	LEAD	7 PPB	15 PPB
06-05A Music Room Drinking Fountain	7/22/2016 11:12	7/28/2016	43588	LEAD	<1 PPB	15 PPB
06-06A Hallway Drinking Fountain 1	7/22/2016 11:15	7/28/2016	43589	LEAD	<1 PPB	15 PPB
06-07A Art Room Drinking Fountain	7/22/2016 11:18	7/28/2016	43590	LEAD	8 PPB	15 PPB
06-08A Art Room Sink Faucet	7/22/2016 11:20	8/2/2016	43591	LEAD	17 PPB	15 PPB
06-09A Hallway Drinking Fountain 2	7/22/2016 11:23	8/2/2016	43592	LEAD	<1 PPB	15 PPB
06-10A Classroom 27 Sink Faucet	7/22/2016 11:28	8/2/2016	43593	LEAD	<1 PPB	15 PPB
06-11A Classroom 27 Drinking Fountain	7/22/2016 11:30	8/2/2016	43594	LEAD	15 PPB	15 PPB
06-12A Classroom 1 Sink Faucet	7/22/2016 11:34	8/2/2016	43595	LEAD	2 PPB	15 PPB
06-13A Classroom 1 Drinking Fountain	7/22/2016 11:36	8/2/2016	43596	LEAD	9 PPB	15 PPB
06-14A Classroom 2 Sink Faucet	7/22/2016 11:39	8/2/2016	43597	LEAD	2 PPB	15 PPB
06-15A Classroom 2 Drinking Fountain	7/22/2016 11:41	8/2/2016	43598	LEAD	2 PPB	15 PPB
06-16A Classroom 3 Sink Faucet	7/22/2016 11:45	8/2/2016	43599	LEAD	2 PPB	15 PPB
06-17A Classroom 3 Drinking Fountain	7/22/2016 11:47	8/2/2016	43600	LEAD	8 PPB	15 PPB
06-18A Classroom 4 Sink Faucet	7/22/2016 11:50	8/2/2016	43601	LEAD	2 PPB	15 PPB
06-19A Classroom 4 Drinking Fountain	7/22/2016 11:52	8/2/2016	43602	LEAD	9 PPB	15 PPB
06-20A Classroom 5 Sink Faucet	7/22/2016 11:56	8/2/2016	43603	LEAD	2 PPB	15 PPB
06-21A Classroom 5 Drinking Fountain	7/22/2016 11:58	8/2/2016	43604	LEAD	11 PPB	15 PPB
06-22A Classroom 6 Sink Fountain	7/22/2016 12:00	8/2/2016	43605	LEAD	5 PPB	15 PPB
06-23A Classroom 6 Drinking Fountain	7/22/2016 12:02	8/2/2016	43606	LEAD	8 PPB	15 PPB
06-24A Classroom 7 Drinking Fountain	7/22/2016 12:05	8/2/2016	43607	LEAD	<1 PPB	15 PPB
06-25A Classroom 7 Sink Faucet	7/22/2016 12:07	8/2/2016	43608	LEAD	6 PPB	15 PPB
06-26A Classroom 8 Sink Faucet	7/22/2016 12:10	8/2/2016	43609	LEAD	4 PPB	15 PPB
06-27A Classroom 8 Drinking Fountain	7/22/2016 12:12	8/2/2016	43610	LEAD	3 PPB	15 PPB
06-28A Computer Lab 25 Sink Faucet	7/22/2016 12:15	8/2/2016	43611	LEAD	7 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
06-29A Computer Lab 25 Drinking Fountain	7/22/2016 12:17	8/2/2016	43612	LEAD	14 PPB	15 PPB
06-30A Kitchen Food Prep Sink Faucet	7/22/2016 12:20	8/2/2016	43613	LEAD	5 PPB	15 PPB
06-31A Classroom 9 Sink Faucet	7/22/2016 12:23	8/2/2016	43614	LEAD	4 PPB	15 PPB
06-32A Classroom 9 Drinking Fountain	7/22/2016 12:25	8/2/2016	43615	LEAD	<1 PPB	15 PPB
06-33A Classroom 10 Sink Fountain	7/22/2016 12:28	8/2/2016	43616	LEAD	3 PPB	15 PPB
06-34A Classroom 10 Drinking Fountain	7/22/2016 12:30	8/2/2016	43617	LEAD	<1 PPB	15 PPB
06-35A Classroom 20 Sink Faucet	7/22/2016 12:34	8/2/2016	43618	LEAD	8 PPB	15 PPB
06-36A Classroom 20 Drinking Fountain	7/22/2016 12:36	8/2/2016	43619	LEAD	9 PPB	15 PPB
06-37A Classroom 19 Sink Faucet	7/22/2016 12:39	8/2/2016	43620	LEAD	3 PPB	15 PPB
06-38A Classroom 19 Drinking Faucet	7/22/2016 12:41	8/2/2016	43621	LEAD	3 PPB	15 PPB
06-39A Classroom 11 Sink Faucet	7/22/2016 12:45	8/2/2016	43622	LEAD	3 PPB	15 PPB
06-40A Classroom 11 Drinking Fountain	7/22/2016 12:47	8/2/2016	43623	LEAD	3 PPB	15 PPB
06-41A Classroom 12 Sink Faucet	7/22/2016 12:49	8/2/2016	43624	LEAD	2 PPB	15 PPB
06-42A Classroom 12 Drinking Fountain	7/22/2016 12:51	8/2/2016	43625	LEAD	6 PPB	15 PPB
06-43A Classroom 13 Sink Faucet	7/22/2016 12:54	8/2/2016	43626	LEAD	4 PPB	15 PPB
06-44A Classroom 13 Drinking Fountain	7/22/2016 12:56	8/5/2016	43627	LEAD	4 PPB	15 PPB
06-45A Classroom 14 Sink Faucet	7/22/2016 12:59	8/2/2016	43628	LEAD	<1 PPB	15 PPB
06-46A Classroom 14 Drinking Fountain	7/22/2016 13:01	8/2/2016	43629	LEAD	6 PPB	15 PPB
06-47A Classroom 15 Sink Faucet	7/22/2016 13:04	8/2/2016	43630	LEAD	4 PPB	15 PPB
06-48A Classroom 15 Drinking Fountain	7/22/2016 13:06	8/2/2016	43631	LEAD	5 PPB	15 PPB
06-49A Classroom 16 Sink Faucet	7/22/2016 13:09	8/2/2016	43632	LEAD	8 PPB	15 PPB
06-50A Classroom 16 Drinking Fountain	7/22/2016 13:11	8/2/2016	43633	LEAD	<1 PPB	15 PPB
06-51A Classroom 17 Sink Faucet	7/22/2016 13:14	8/2/2016	43634	LEAD	4 PPB	15 PPB
06-52A Classroom 17 Drinking Faucet	7/22/2016 13:16	8/2/2016	43635	LEAD	2 PPB	15 PPB
06-53A Classroom 18 Sink Faucet	7/22/2016 13:19	8/2/2016	43636	LEAD	1 PPB	15 PPB
06-54A Classroom 18 Drinking Fountain	7/22/2016 13:21	8/2/2016	43637	LEAD	<1 PPB	15 PPB
06-55A Staff Lounge Drinking Fountain	7/22/2016 11:25	8/2/2016	43638	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
--------------------------------------	-------------------	---------------	--------------	------------	---------	--------------

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
06-08B Art Room Sink Faucet	7/22/2016 11:20	9/1/2016	52927	LEAD	2 PPB	15 PPB
06-11B Classroom 27 Drinking Fountain	7/22/2016 11:30	9/1/2016	52928	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Chapman Hill Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
06-56A Book/Staff/Community Rm Sink Faucet	4/28/2017 6:17	5/2/2017	22386	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level