

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Cesar Chavez Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
007-01A Kitchen Food Prep Sink Faucet	7/26/16 8:11	8/1/2016	1607C83-01A	COPPER	0.5 PPM	1.3 PPM
007-02A Cafeteria Drinking Fountain (1)	7/27/16 8:00	8/2/2016	1607C83-02A	COPPER	1.1 PPM	1.3 PPM
007-03A Cafeteria Drinking Fountain (1)	7/27/16 8:03	8/2/2016	1607C83-03A	COPPER	1.2 PPM	1.3 PPM
007-04A Music Room Sink Faucet	7/27/16 8:23	8/1/2016	1607C83-04A	COPPER	0.4 PPM	1.3 PPM
007-05A Music Room Drinking Fountain (1)	7/27/16 8:25	8/1/2016	1607C83-05A	COPPER	0.4 PPM	1.3 PPM
007-06A Music Room Drinking Fountain (2)	7/27/16 8:17	8/2/2016	1607C83-06A	COPPER	2.8 PPM	1.3 PPM
007-07A Music Room Drinking Fountain (3)	7/27/16 8:19	8/2/2016	1607C83-07A	COPPER	1.9 PPM	1.3 PPM
007-08A Hall Drinking Fountain 1	7/27/16 7:27	8/1/2016	1607C83-08A	COPPER	0.7 PPM	1.3 PPM
007-09A Hall Drinking Fountain 2	7/27/16 7:32	8/1/2016	1607C83-09A	COPPER	0.7 PPM	1.3 PPM
007-10A Staff Lounge Refrigerator Ice Maker 1	7/27/16 9:05	8/1/2016	1607C83-10A	COPPER	0.8 PPM	1.3 PPM
007-11A Staff Lounge Refrigerator Ice Maker 2	7/27/16 9:00	8/1/2016	1607C83-11A	COPPER	0.7 PPM	1.3 PPM
007-12A Staff Lounge Sink Faucet	7/27/16 7:36	8/1/2016	1607C83-12A	COPPER	0.6 PPM	1.3 PPM
007-13A Health Room Sink Faucet	7/27/16 7:37	8/1/2016	1607C83-13A	COPPER	0.5 PPM	1.3 PPM
007-15A Gymnasium Drinking Fountain	7/27/16 8:53	8/1/2016	1607C83-14A	COPPER	0.8 PPM	1.3 PPM
007-16A Gymnasium Drinking Fountain	7/27/16 8:54	8/1/2016	1607C83-15A	COPPER	0.8 PPM	1.3 PPM
007-17A Room 101 Sink Faucet	7/27/16 7:29	8/1/2016	1607C83-16A	COPPER	0.3 PPM	1.3 PPM
007-18A Room 101 Drinking Fountain	7/27/16 7:29	8/1/2016	1607C83-17A	COPPER	0.6 PPM	1.3 PPM
007-19A Room 102 Sink Faucet	7/27/16 7:31	8/1/2016	1607C83-18A	COPPER	0.5 PPM	1.3 PPM
007-20A Room 102 Drinking Fountain	7/27/16 7:31	8/1/2016	1607C83-19A	COPPER	0.5 PPM	1.3 PPM
007-21A Room 112 Sink Faucet	7/27/16 7:33	8/1/2016	1607C83-20A	COPPER	0.3 PPM	1.3 PPM
007-22A Room 112 Drinking Fountain	7/27/16 7:33	8/1/2016	1607C83-21A	COPPER	0.4 PPM	1.3 PPM
007-24A PLC 118 Sink Faucet	7/27/16 7:35	8/1/2016	1607C83-22A	COPPER	0.4 PPM	1.3 PPM
007-25A Hall Drinking Fountain 3	7/27/16 7:38	8/1/2016	1607C83-23A	COPPER	0.6 PPM	1.3 PPM
007-26A Hall Drinking Fountain 4	7/27/16 7:39	8/1/2016	1607C83-24A	COPPER	0.5 PPM	1.3 PPM
007-27A Room 103 Sink Faucet	7/27/16 7:41	8/1/2016	1607C83-25A	COPPER	0.4 PPM	1.3 PPM
007-28A Room 103 Drinking Fountain	7/27/16 7:41	8/1/2016	1607C83-26A	COPPER	0.6 PPM	1.3 PPM
007-29A Room 104 Sink Faucet	7/27/16 7:47	8/1/2016	1607C83-27A	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 First Draw (A) Sample Data  
 Cesar Chavez Elementary School

007-30A	Room 104 Drinking Fountain	7/27/16 7:47	8/2/2016	1607C83-28A	COPPER	0.5 PPM	1.3 PPM
007-31A	Room 110 Sink Faucet	7/27/16 7:44	8/1/2016	1607C83-29A	COPPER	0.4 PPM	1.3 PPM
007-32A	Room 110 Drinking Fountain	7/27/16 7:44	8/2/2016	1607C83-30A	COPPER	0.4 PPM	1.3 PPM
007-33A	Room 109 Sink Faucet	7/27/16 7:49	8/1/2016	1607C83-31A	COPPER	0.3 PPM	1.3 PPM
007-34A	Room 109 Drinking Fountain	7/27/16 7:49	8/2/2016	1607C83-32A	COPPER	0.2 PPM	1.3 PPM
007-35A	Room 105 Sink Faucet	7/27/16 7:52	8/1/2016	1607C83-33A	COPPER	0.3 PPM	1.3 PPM
007-36A	Room 105 Drinking Fountain	7/27/16 7:52	8/2/2016	1607C83-34A	COPPER	0.2 PPM	1.3 PPM
007-37A	Room 108 Sink Faucet	7/27/16 7:54	8/1/2016	1607C83-35A	COPPER	0.6 PPM	1.3 PPM
007-38A	Room 108 Drinking Fountain	7/27/16 7:54	8/2/2016	1607C83-36A	COPPER	0.5 PPM	1.3 PPM
007-39A	Room 106 Sink Faucet	7/27/16 8:00	8/1/2016	1607C83-37A	COPPER	0.3 PPM	1.3 PPM
007-40A	Room 106 Drinking Fountain	7/27/16 8:00	8/2/2016	1607C83-38A	COPPER	0.4 PPM	1.3 PPM
007-41A	Room 107 Sink Faucet	7/27/16 7:57	8/1/2016	1607C83-39A	COPPER	0.5 PPM	1.3 PPM
007-42A	Room 108 Drinking Fountain	7/27/16 7:57	8/2/2016	1607C83-40A	COPPER	0.5 PPM	1.3 PPM
007-43A	Room 210 Sink Faucet	7/27/16 8:40	8/1/2016	1607C83-41A	COPPER	0.4 PPM	1.3 PPM
007-44A	Room 210 Drinking Fountain	7/27/16 8:40	8/2/2016	1607C83-42A	COPPER	0.3 PPM	1.3 PPM
007-45A	Room 209 Sink Faucet	7/27/16 8:42	8/1/2016	1607C83-43A	COPPER	0.4 PPM	1.3 PPM
007-46A	Room 209 Drinking Fountain	7/27/16 8:42	8/2/2016	1607C83-44A	COPPER	0.3 PPM	1.3 PPM
007-47A	Room 211 Sink Faucet	7/27/16 8:45	8/1/2016	1607C83-45A	COPPER	0.3 PPM	1.3 PPM
007-48A	Room 211 Drinking Fountain	7/27/16 8:45	8/2/2016	1607C83-46A	COPPER	0.3 PPM	1.3 PPM
007-49A	Room 208 Drinking Fountain	7/27/16 8:48	8/1/2016	1607C83-47A	COPPER	0.3 PPM	1.3 PPM
007-50A	Room 208 Sink Faucet	7/27/16 8:48	8/2/2016	1607C83-48A	COPPER	0.3 PPM	1.3 PPM
007-51A	PLC 211 Refrigerator Ice Maker	7/27/16 8:50	8/2/2016	1607C83-49A	COPPER	0.6 PPM	1.3 PPM
007-52A	PLC 211 Sink Faucet	7/27/16 8:50	8/1/2016	1607C83-50A	COPPER	0.4 PPM	1.3 PPM
007-53A	Room 212 Sink Faucet	7/27/16 8:54	8/1/2016	1607C83-51A	COPPER	0.4 PPM	1.3 PPM
007-54A	Room 212 Drinking Fountain	7/27/16 8:54	8/2/2016	1607C83-52A	COPPER	0.2 PPM	1.3 PPM
007-55A	Room 213 Sink Faucet	7/27/16 8:56	8/1/2016	1607C83-53A	COPPER	0.2 PPM	1.3 PPM
007-56A	Room 213 Drinking Fountain	7/27/16 8:56	8/2/2016	1607C83-54A	COPPER	0.2 PPM	1.3 PPM
007-57A	Room 207 Sink Faucet	7/27/16 8:58	8/1/2016	1607C83-55A	COPPER	0.3 PPM	1.3 PPM
007-58A	Room 207 Drinking Fountain	7/27/16 8:58	8/2/2016	1607C83-56A	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Cesar Chavez Elementary School

007-59A	Room 206 Sink Faucet	7/27/16 9:02	8/1/2016	1607C83-57A	COPPER	0.8 PPM	1.3 PPM
007-60A	Room 206 Drinking Fountain	7/27/16 9:02	8/2/2016	1607C83-58A	COPPER	0.3 PPM	1.3 PPM
007-61A	PLC 206 Refrigerator Ice Maker	7/27/16 9:07	8/2/2016	1607C83-59A	COPPER	1.2 PPM	1.3 PPM
007-62A	PLC 206 Sink Faucet	7/27/16 9:07	8/1/2016	1607C83-60A	COPPER	0.4 PPM	1.3 PPM
007-63A	Hall Drinking Fountain 5	7/27/16 9:04	8/1/2016	1607C83-61A	COPPER	0.5 PPM	1.3 PPM
007-64A	Hall Drinking Fountain 6	7/27/16 9:05	8/2/2016	1607C83-62A	COPPER	0.4 PPM	1.3 PPM
007-65A	Room 214 Sink Faucet	7/27/16 9:12	8/1/2016	1607C83-63A	COPPER	0.3 PPM	1.3 PPM
007-66A	Room 244 Drinking Fountain	7/27/16 9:12	8/2/2016	1607C83-64A	COPPER	0.3 PPM	1.3 PPM
007-67A	Room 215 Sink Faucet	7/27/16 9:15	8/1/2016	1607C83-65A	COPPER	0.3 PPM	1.3 PPM
007-68A	Room 215 Drinking Fountain	7/27/16 9:15	8/1/2016	1607C83-66A	COPPER	0.3 PPM	1.3 PPM
007-69A	Room 205 Sink Faucet	7/27/16 9:14	8/1/2016	1607C83-67A	COPPER	0.4 PPM	1.3 PPM
007-70A	Room 205 Drinking Fountain	7/27/16 9:14	8/1/2016	1607C83-68A	COPPER	0.3 PPM	1.3 PPM
007-71A	Room 204 Sink Faucet	7/27/16 9:17	8/2/2016	1607C83-69A	COPPER	0.4 PPM	1.3 PPM
007-72A	Room 204 Drinking Fountain	7/27/16 9:17	8/2/2016	1607C83-70A	COPPER	0.4 PPM	1.3 PPM
007-73A	LRC 203 Sink Faucet	7/27/16 9:20	8/1/2016	1607C83-71A	COPPER	0.4 PPM	1.3 PPM
007-74A	LRC 203 Drinking Fountain	7/27/16 9:20	8/1/2016	1607C83-72A	COPPER	0.3 PPM	1.3 PPM
007-75A	Hall Drinking Fountain 7	7/27/16 9:23	8/1/2016	1607C83-73A	COPPER	0.8 PPM	1.3 PPM
007-76A	Hall Drinking Fountain 8	7/27/16 9:24	8/1/2016	1607C83-74A	COPPER	0.9 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Cesar Chavez Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
007-23A PLC 118 Refrigerator Ice Maker	9/30/2016 6:20	10/3/2016	59711	COPPER	0.5 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Copper Water Sampling Results  
Flushed (B) Sample Data  
Cesar Chavez Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
007-06B Music Room Drinking Fountain (2)	7/27/16 8:18	8/23/2016	1607C84-06A	COPPER	0.9 PPM	1.3 PPM
007-07B Music Room Drinking Fountain (3)	7/27/16 8:20	8/23/2016	1607C84-07A	COPPER	0.5 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level