

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
08-01A Kitchen Food Prep Sink Faucet 1	7/27/16 14:32	8/3/16 15:53	607284601	COPPER	0.4 PPM	1.3 PPM
08-02A Kitchen Food Prep Sink Faucet 2	7/27/16 14:39	8/3/16 15:53	607284602	COPPER	0.2 PPM	1.3 PPM
08-03A Kitchen Food Counter Sink Faucet 1	7/27/16 14:41	8/3/16 15:54	607284603	COPPER	0.5 PPM	1.3 PPM
08-04A Kitchen Food Counter Sink Faucet 2	7/27/16 14:41	8/3/16 15:54	607284604	COPPER	0.5 PPM	1.3 PPM
08-05A Kitchen Food Counter Sink Faucet 3	7/27/16 14:47	8/3/16 15:54	607284605	COPPER	0.5 PPM	1.3 PPM
08-06A Hallway Drinking Fountain 1	7/27/16 14:52	8/3/16 15:54	607284606	COPPER	0.6 PPM	1.3 PPM
08-07A Hallway Drinking Fountain 2	7/27/16 14:52	8/4/16 7:56	607284607	COPPER	0.6 PPM	1.3 PPM
08-08A Room 114 Drinking Fountain 1	7/27/16 15:00	8/4/16 7:57	607284608	COPPER	0.3 PPM	1.3 PPM
08-09A Room 114 Drinking Fountain 2	7/27/16 15:00	8/4/16 7:57	607284609	COPPER	0.3 PPM	1.3 PPM
08-10A Classroom 115 Drinking Fountain	7/27/16 15:05	8/4/16 7:57	607284610	COPPER	0.1 PPM	1.3 PPM
08-11A Classroom 115 Sink Faucet	7/27/16 15:05	8/4/16 7:58	607284611	COPPER	0.2 PPM	1.3 PPM
08-12A Gymnasium Drinking Fountain 1	7/27/16 15:12	8/4/16 7:58	607284612	COPPER	0.3 PPM	1.3 PPM
08-13A Gymnasium Drinking Fountain 2	7/27/16 15:13	8/4/16 7:58	607284613	COPPER	0.4 PPM	1.3 PPM
08-14A Hallway Drinking Fountain 3	7/27/16 17:04	8/4/16 7:58	607284614	COPPER	0.3 PPM	1.3 PPM
08-15A Hallway Drinking Fountain 4	7/27/16 17:05	8/4/16 7:59	607284615	COPPER	0.5 PPM	1.3 PPM
08-16A Choir Drinking Fountain 1	7/27/16 17:08	8/4/16 7:59	607284616	COPPER	0.4 PPM	1.3 PPM
08-17A Choir Drinking Fountain 2	7/27/16 17:09	8/4/16 8:04	607284617	COPPER	0.3 PPM	1.3 PPM
08-18A Band 215 Drinking Fountain 1	7/27/16 17:13	8/4/16 8:04	607284618	COPPER	0.5 PPM	1.3 PPM
08-19A Band 215 Drinking Fountain 2	7/27/16 17:14	8/4/16 8:04	607284619	COPPER	0.3 PPM	1.3 PPM
08-20A Hallway Drinking Fountain 5	7/27/16 15:16	8/4/16 8:04	607284620	COPPER	0.4 PPM	1.3 PPM
08-21A Hallway Drinking Fountain 6	7/27/16 15:18	8/4/16 8:05	607284621	COPPER	0.5 PPM	1.3 PPM
08-22A Boys Locker Room Drinking Fountain 1	7/27/16 15:34	8/4/16 8:05	607284622	COPPER	0.3 PPM	1.3 PPM
08-23A Boys Locker Room Drinking Fountain 2	7/27/16 15:34	8/4/16 8:05	607284623	COPPER	0.3 PPM	1.3 PPM
08-24A Girls Locker Room Drinking Fountain 1	7/27/16 15:28	8/4/16 8:05	607284624	COPPER	0.4 PPM	1.3 PPM
08-25A Girls Locker Room Drinking Fountain 2	7/27/16 15:29	8/4/16 8:05	607284625	COPPER	0.5 PPM	1.3 PPM
08-26A Classroom 112 Sink Faucet	7/27/16 15:45	8/4/16 8:06	607284626	COPPER	0.3 PPM	1.3 PPM
08-27A Classroom 112 Drinking Fountain	7/27/16 15:45	8/4/16 8:09	607284627	COPPER	0.2 PPM	1.3 PPM
08-28A Home Economics Sink Faucet 1	7/27/16 16:15	8/4/16 8:09	607284628	COPPER	0.4 PPM	1.3 PPM
08-29A Home Economics Sink Faucet 2	7/27/16 16:17	8/4/16 8:10	607284629	COPPER	0.2 PPM	1.3 PPM
08-30A Home Economics Sink Faucet 3	7/27/16 16:20	8/4/16 8:10	607284630	COPPER	0.4 PPM	1.3 PPM
08-31A Home Economics Sink Faucet 4	7/27/16 16:20	8/4/16 8:10	607284631	COPPER	0.2 PPM	1.3 PPM
08-32A Home Economics Sink Faucet 5	7/27/16 16:22	8/4/16 8:10	607284632	COPPER	0.2 PPM	1.3 PPM
08-33A Home Economics Sink Faucet 6	7/27/16 16:25	8/4/16 8:10	607284633	COPPER	0.4 PPM	1.3 PPM
08-34A Home Economics Sink Faucet 7	7/27/16 16:30	8/4/16 8:10	607284634	COPPER	0.5 PPM	1.3 PPM
08-35A Home Economics Refrigerator Ice Maker 1	7/27/16 16:33	8/4/16 8:11	607284635	COPPER	0.4 PPM	1.3 PPM
08-36A Home Economics Refrigerator Ice Maker 2	7/27/16 16:38	8/4/16 8:11	607284636	COPPER	0.4 PPM	1.3 PPM
08-37A Home Economics Refrigerator Ice Maker 3	7/27/16 16:40	8/4/16 8:12	607284637	COPPER	0.1 PPM	1.3 PPM
08-38A Home Economics Refrigerator Ice Maker 4	7/27/16 16:43	8/4/16 8:12	607284638	COPPER	0.4 PPM	1.3 PPM
08-39A Classroom 110 Sink Faucet	7/27/16 16:50	8/4/16 8:13	607284639	COPPER	0.3 PPM	1.3 PPM
08-40A Classroom 110 Drinking Fountain	7/27/16 16:50	8/4/16 8:13	607284640	COPPER	0.2 PPM	1.3 PPM
08-41A Nurse Sink Faucet	7/27/16 15:50	8/4/16 8:13	607284641	COPPER	0.2 PPM	1.3 PPM
08-42A Nurse Refrigerator Ice Maker	7/27/16 15:52	8/4/16 8:13	607284642	COPPER	0.2 PPM	1.3 PPM
08-43A Office Sink Faucet 1	7/27/16 15:52	8/4/16 8:13	607284643	COPPER	0.2 PPM	1.3 PPM
08-44A Office Sink Faucet 2	7/27/16 15:57	8/4/16 8:13	607284644	COPPER	0.3 PPM	1.3 PPM
08-45A Classroom 100 Sink Faucet	7/27/16 17:00	8/4/16 8:14	607284645	COPPER	0.4 PPM	1.3 PPM
08-46A Classroom 100 Drinking Fountain	7/27/16 17:06	8/4/16 8:14	607284646	COPPER	0.3 PPM	1.3 PPM
08-47A Classroom 102 Sink Faucet	7/27/16 17:08	8/4/16 8:16	607284647	COPPER	0.3 PPM	1.3 PPM
08-48A Classroom 102 Drinking Fountain	7/27/16 17:08	8/4/16 8:16	607284648	COPPER	0.3 PPM	1.3 PPM
08-49A Classroom 103 Sink Faucet	7/27/16 17:14	8/4/16 8:16	607284649	COPPER	0.3 PPM	1.3 PPM
08-50A Classroom 103 Drinking Fountain	7/27/16 17:14	8/4/16 8:16	607284650	COPPER	0.2 PPM	1.3 PPM
08-51A Room 104 Sink Faucet	7/27/16 17:20	8/4/16 8:17	607284651	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
08-52A Classroom 106 Drinking Fountain	7/27/16 15:30	8/4/16 8:17	607284652	COPPER	0.2 PPM	1.3 PPM
08-54A Classroom 107 Sink Faucet	7/27/16 17:35	8/4/16 8:17	607284653	COPPER	0.8 PPM	1.3 PPM
08-55A Classroom 107 Drinking Fountain	7/27/16 17:35	8/4/16 8:17	607284654	COPPER	0.3 PPM	1.3 PPM
08-56A Classroom 108 Sink Faucet	7/27/16 17:42	8/4/16 8:17	607284655	COPPER	0.5 PPM	1.3 PPM
08-57A Classroom 108 Drinking Fountain	7/27/16 17:42	8/4/16 8:18	607284656	COPPER	0.2 PPM	1.3 PPM
08-58A Classroom 208 Sink Faucet	7/27/16 14:32	8/4/16 8:19	607284657	COPPER	0.3 PPM	1.3 PPM
08-59A Classroom 208 Drinking Fountain	7/27/16 14:32	8/4/16 8:19	607284658	COPPER	0.2 PPM	1.3 PPM
08-60A Classroom 207 Sink Faucet	7/27/16 14:34	8/4/16 8:19	607284659	COPPER	0.4 PPM	1.3 PPM
08-61A Classroom 207 Drinking Fountain	7/27/16 14:34	8/4/16 8:19	607284660	COPPER	0.2 PPM	1.3 PPM
08-62A Classroom 206 Sink Faucet	7/27/16 14:36	8/4/16 8:20	607284661	COPPER	0.4 PPM	1.3 PPM
08-63A Classroom 206 Drinking Fountain	7/27/16 14:36	8/4/16 8:20	607284662	COPPER	0.2 PPM	1.3 PPM
08-64A Classroom 209 Sink Faucet	7/27/16 14:38	8/4/16 8:20	607284663	COPPER	0.4 PPM	1.3 PPM
08-65A Classroom 203 Sink Faucet	7/27/16 14:40	8/4/16 8:20	607284664	COPPER	0.3 PPM	1.3 PPM
08-66A Classroom 203 Drinking Fountain	7/27/16 14:40	8/4/16 8:20	607284665	COPPER	0.2 PPM	1.3 PPM
08-67A Classroom 202 Sink Faucet	7/27/16 14:42	8/4/16 8:21	607284666	COPPER	0.2 PPM	1.3 PPM
08-68A Classroom 202 Drinking Fountain	7/27/16 14:42	8/3/16 10:23	607284667	COPPER	0.1 PPM	1.3 PPM
08-69A Classroom 201 Sink Faucet	7/27/16 14:44	8/3/16 10:23	607284668	COPPER	0.2 PPM	1.3 PPM
08-70A Classroom 201 Drinking Fountain	7/27/16 14:44	8/3/16 10:23	607284669	COPPER	0.2 PPM	1.3 PPM
08-71A Classroom 200 Sink Faucet	7/27/16 14:46	8/3/16 10:22	607284670	COPPER	0.2 PPM	1.3 PPM
08-72A Classroom 200 Drinking Fountain	7/27/16 14:46	8/3/16 10:22	607284671	COPPER	0.2 PPM	1.3 PPM
08-73A Computer 213 Sink Faucet	7/27/16 18:57	8/3/16 10:22	607284672	COPPER	0.2 PPM	1.3 PPM
08-74A Computer 213 Drinking Fountain	7/27/16 18:57	8/3/16 10:22	607284673	COPPER	0.1 PPM	1.3 PPM
08-75A Computer 212 Sink Faucet	7/27/16 18:47	8/3/16 10:22	607284674	COPPER	0.3 PPM	1.3 PPM
08-76A Computer 212 Drinking Fountain	7/27/16 18:47	8/3/16 10:21	607284675	COPPER	0.3 PPM	1.3 PPM
08-77A Classroom 211 Sink Faucet	7/27/16 18:42	8/3/16 10:21	607284676	COPPER	0.2 PPM	1.3 PPM
08-78A Classroom 211 Drinking Fountain	7/27/16 18:42	8/3/16 10:28	607284677	COPPER	0.1 PPM	1.3 PPM
08-79A Classroom 210 Sink Faucet	7/27/16 18:33	8/3/16 10:28	607284678	COPPER	0.3 PPM	1.3 PPM
08-80A Classroom 210 Drinking Fountain	7/27/16 18:34	8/3/16 10:28	607284679	COPPER	0.2 PPM	1.3 PPM
08-81A Classroom 314 Sink Faucet	7/27/16 14:48	8/3/16 10:28	607284680	COPPER	0.2 PPM	1.3 PPM
08-82A Classroom 314 Drinking Fountain	7/27/16 14:48	8/3/16 10:28	607284681	COPPER	0.2 PPM	1.3 PPM
08-83A Classroom 316 Sink Faucet	7/27/16 14:50	8/3/16 10:29	607284682	COPPER	0.1 PPM	1.3 PPM
08-84A Classroom 316 Drinking Fountain	7/27/16 14:50	8/3/16 10:29	607284683	COPPER	0.2 PPM	1.3 PPM
08-85A Hallway Drinking Fountain 7	7/27/16 17:53	8/3/16 10:29	607284684	COPPER	0.2 PPM	1.3 PPM
08-86A Hallway Drinking Fountain 8	7/27/16 17:54	8/3/16 10:29	607284685	COPPER	0.3 PPM	1.3 PPM
08-89A Classroom 317 Sink Faucet	7/27/16 14:52	8/3/16 11:12	6072846107	COPPER	0.6 PPM	1.3 PPM
08-90A Classroom 317 Drinking Fountain	7/27/16 14:52	8/3/16 10:30	607284686	COPPER	0.2 PPM	1.3 PPM
08-91A Classroom 312 Sink Faucet	7/27/16 14:54	8/3/16 10:32	607284687	COPPER	0.3 PPM	1.3 PPM
08-92A Classroom 312 Drinking Fountain	7/27/16 14:54	8/3/16 10:41	607284688	COPPER	0.1 PPM	1.3 PPM
08-93A Classroom 311 Sink Faucet	7/27/16 17:51	8/3/16 10:41	607284689	COPPER	0.2 PPM	1.3 PPM
08-94A Classroom 311 Drinking Fountain	7/27/16 17:51	8/3/16 10:42	607284690	COPPER	0.2 PPM	1.3 PPM
08-95A Room 310 Sink Faucet	7/27/16 17:50	8/3/16 10:42	607284691	COPPER	0.2 PPM	1.3 PPM
08-96A Room 300 Sink Faucet	7/27/16 17:25	8/3/16 10:42	607284692	COPPER	0.3 PPM	1.3 PPM
08-97A Room 300 Drinking Fountain	7/27/16 17:25	8/3/16 10:42	607284693	COPPER	0.2 PPM	1.3 PPM
08-98A Room 301 Sink Faucet	7/27/16 17:28	8/3/16 10:42	607284694	COPPER	0.3 PPM	1.3 PPM
08-99A Room 301 Drinking Fountain	7/27/16 17:28	8/3/16 10:43	607284695	COPPER	0.2 PPM	1.3 PPM
08-100A Room 302 Sink Faucet	7/27/16 17:31	8/3/16 10:44	607284696	COPPER	0.2 PPM	1.3 PPM
08-101A Room 302 Drinking Fountain	7/27/16 17:31	8/3/16 10:56	607284697	COPPER	0.1 PPM	1.3 PPM
08-102A Room 303 Sink Faucet	7/27/16 17:35	8/3/16 10:56	607284698	COPPER	0.2 PPM	1.3 PPM
08-103A Room 303 Drinking Fountain	7/27/16 17:35	8/3/16 10:56	607284699	COPPER	0.2 PPM	1.3 PPM
08-104A Room 304 Sink Faucet	7/27/16 17:40	8/3/16 10:57	6072846100	COPPER	0.2 PPM	1.3 PPM
08-105A Room 306 Sink Faucet	7/27/16 17:43	8/3/16 10:57	6072846101	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
08-106A Room 306 Drinking Fountain	7/27/16 17:43	8/3/16 10:57	6072846102	COPPER	0.2 PPM	1.3 PPM
08-107A Room 307 Sink Faucet	7/27/16 17:45	8/3/16 10:59	6072846103	COPPER	0.4 PPM	1.3 PPM
08-108A Room 307 Drinking Fountain	7/27/16 17:45	8/3/16 10:59	6072846104	COPPER	0.2 PPM	1.3 PPM
08-109A Room 308 Sink Faucet	7/27/16 17:48	8/3/16 11:00	6072846105	COPPER	0.2 PPM	1.3 PPM
08-110A Room 308 Drinking Fountain	7/27/16 17:48	8/3/16 11:01	6072846106	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
08-53A Classroom 106 Sink Faucet	9/23/2016 4:27	9/26/2016	58297	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
08-45B Classroom 100 Sink Faucet	7/27/16 17:07	8/23/16 11:31	608170201	COPPER	< 0.005 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level