

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
08-01A Kitchen Food Prep Sink Faucet 1	7/27/16 14:32	8/3/16 15:53	607284601	LEAD	2 PPB	15 PPB
08-02A Kitchen Food Prep Sink Faucet 2	7/27/16 14:39	8/3/16 15:53	607284602	LEAD	3 PPB	15 PPB
08-03A Kitchen Food Counter Sink Faucet 1	7/27/16 14:41	8/3/16 15:54	607284603	LEAD	9 PPB	15 PPB
08-04A Kitchen Food Counter Sink Faucet 2	7/27/16 14:41	8/3/16 15:54	607284604	LEAD	5 PPB	15 PPB
08-05A Kitchen Food Counter Sink Faucet 3	7/27/16 14:47	8/3/16 15:54	607284605	LEAD	4 PPB	15 PPB
08-06A Hallway Drinking Fountain 1	7/27/16 14:52	8/3/16 15:54	607284606	LEAD	< 1 PPB	15 PPB
08-07A Hallway Drinking Fountain 2	7/27/16 14:52	8/4/16 7:56	607284607	LEAD	< 1 PPB	15 PPB
08-08A Room 114 Drinking Fountain 1	7/27/16 15:00	8/4/16 7:57	607284608	LEAD	< 1 PPB	15 PPB
08-09A Room 114 Drinking Fountain 2	7/27/16 15:00	8/4/16 7:57	607284609	LEAD	< 1 PPB	15 PPB
08-10A Classroom 115 Drinking Fountain	7/27/16 15:05	8/4/16 7:57	607284610	LEAD	2 PPB	15 PPB
08-11A Classroom 115 Sink Faucet	7/27/16 15:05	8/4/16 7:58	607284611	LEAD	7 PPB	15 PPB
08-12A Gymnasium Drinking Fountain 1	7/27/16 15:12	8/4/16 7:58	607284612	LEAD	< 1 PPB	15 PPB
08-13A Gymnasium Drinking Fountain 2	7/27/16 15:13	8/4/16 7:58	607284613	LEAD	< 1 PPB	15 PPB
08-14A Hallway Drinking Fountain 3	7/27/16 17:04	8/4/16 7:58	607284614	LEAD	< 1 PPB	15 PPB
08-15A Hallway Drinking Fountain 4	7/27/16 17:05	8/4/16 7:59	607284615	LEAD	< 1 PPB	15 PPB
08-16A Choir Drinking Fountain 1	7/27/16 17:08	8/4/16 7:59	607284616	LEAD	< 1 PPB	15 PPB
08-17A Choir Drinking Fountain 2	7/27/16 17:09	8/4/16 8:04	607284617	LEAD	< 1 PPB	15 PPB
08-18A Band 215 Drinking Fountain	7/27/16 17:13	8/4/16 8:04	607284618	LEAD	< 1 PPB	15 PPB
08-19A Band 215 Drinking Fountain	7/27/16 17:14	8/4/16 8:04	607284619	LEAD	< 1 PPB	15 PPB
08-20A Hallway Drinking Fountain 5	7/27/16 15:16	8/4/16 8:04	607284620	LEAD	< 1 PPB	15 PPB
08-21A Hallway Drinking Fountain 6	7/27/16 15:18	8/4/16 8:05	607284621	LEAD	< 1 PPB	15 PPB
08-22A Boys Locker Room Drinking Fountain 1	7/27/16 15:34	8/4/16 8:05	607284622	LEAD	< 1 PPB	15 PPB
08-23A Boys Locker Room Drinking Fountain 2	7/27/16 15:34	8/4/16 8:05	607284623	LEAD	< 1 PPB	15 PPB
08-24A Girls Locker Room Drinking Fountain 1	7/27/16 15:28	8/4/16 8:05	607284624	LEAD	< 1 PPB	15 PPB
08-25A Girls Locker Room Drinking Fountain 2	7/27/16 15:29	8/4/16 8:05	607284625	LEAD	< 1 PPB	15 PPB
08-26A Classroom 112 Sink Faucet	7/27/16 15:45	8/4/16 8:06	607284626	LEAD	10 PPB	15 PPB
08-27A Classroom 112 Drinking Fountain	7/27/16 15:45	8/4/16 8:09	607284627	LEAD	< 1 PPB	15 PPB
08-28A Home Economics Sink Faucet 1	7/27/16 16:15	8/4/16 8:09	607284628	LEAD	2 PPB	15 PPB
08-29A Home Economics Sink Faucet 2	7/27/16 16:17	8/4/16 8:10	607284629	LEAD	1 PPB	15 PPB
08-30A Home Economics Sink Faucet 3	7/27/16 16:20	8/4/16 8:10	607284630	LEAD	2 PPB	15 PPB
08-31A Home Economics Sink Faucet 4	7/27/16 16:20	8/4/16 8:10	607284631	LEAD	1 PPB	15 PPB
08-32A Home Economics Sink Faucet 5	7/27/16 16:22	8/4/16 8:10	607284632	LEAD	2 PPB	15 PPB
08-33A Home Economics Sink Faucet 6	7/27/16 16:25	8/4/16 8:10	607284633	LEAD	2 PPB	15 PPB
08-34A Home Economics Sink Faucet 7	7/27/16 16:30	8/4/16 8:10	607284634	LEAD	2 PPB	15 PPB
08-35A Home Economics Refrigerator Ice Maker 1	7/27/16 16:33	8/4/16 8:11	607284635	LEAD	4 PPB	15 PPB
08-36A Home Economics Refrigerator Ice Maker 2	7/27/16 16:38	8/4/16 8:11	607284636	LEAD	1 PPB	15 PPB
08-37A Home Economics Refrigerator Ice Maker 3	7/27/16 16:40	8/4/16 8:12	607284637	LEAD	< 1 PPB	15 PPB
08-38A Home Economics Refrigerator Ice Maker 4	7/27/16 16:43	8/4/16 8:12	607284638	LEAD	4 PPB	15 PPB
08-39A Classroom 110 Sink Faucet	7/27/16 16:50	8/4/16 8:13	607284639	LEAD	2 PPB	15 PPB
08-40A Classroom 110 Drinking Fountain	7/27/16 16:50	8/4/16 8:13	607284640	LEAD	< 1 PPB	15 PPB
08-41A Nurse Sink Faucet	7/27/16 15:50	8/4/16 8:13	607284641	LEAD	< 1 PPB	15 PPB
08-42A Nurse Refrigerator Ice Maker	7/27/16 15:52	8/4/16 8:13	607284642	LEAD	1 PPB	15 PPB
08-43A Office Sink Faucet 1	7/27/16 15:52	8/4/16 8:13	607284643	LEAD	< 1 PPB	15 PPB
08-44A Office Sink Faucet 2	7/27/16 15:57	8/4/16 8:13	607284644	LEAD	4 PPB	15 PPB
<b>08-45A Classroom 100 Sink Faucet</b>	<b>7/27/16 17:00</b>	<b>8/4/16 8:14</b>	<b>607284645</b>	<b>LEAD</b>	<b>20 PPB</b>	<b>15 PPB</b>
08-46A Classroom 100 Drinking Fountain	7/27/16 17:06	8/4/16 8:14	607284646	LEAD	3 PPB	15 PPB
08-47A Classroom 102 Sink Faucet	7/27/16 17:08	8/4/16 8:16	607284647	LEAD	4 PPB	15 PPB
08-48A Classroom 102 Drinking Fountain	7/27/16 17:08	8/4/16 8:16	607284648	LEAD	1 PPB	15 PPB
08-49A Classroom 103 Sink Faucet	7/27/16 17:14	8/4/16 8:16	607284649	LEAD	2 PPB	15 PPB
08-50A Classroom 103 Drinking Fountain	7/27/16 17:14	8/4/16 8:16	607284650	LEAD	1 PPB	15 PPB
08-51A Room 104 Sink Faucet	7/27/16 17:20	8/4/16 8:17	607284651	LEAD	4 PPB	15 PPB
08-52A Classroom 106 Drinking Fountain	7/27/16 15:30	8/4/16 8:17	607284652	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
08-54A Classroom 107 Sink Faucet	7/27/16 17:35	8/4/16 8:17	607284653	LEAD	4 PPB	15 PPB
08-55A Classroom 107 Drinking Fountain	7/27/16 17:35	8/4/16 8:17	607284654	LEAD	2 PPB	15 PPB
08-56A Classroom 108 Sink Faucet	7/27/16 17:42	8/4/16 8:17	607284655	LEAD	4 PPB	15 PPB
08-57A Classroom 108 Drinking Fountain	7/27/16 17:42	8/4/16 8:18	607284656	LEAD	1 PPB	15 PPB
08-58A Classroom 208 Sink Faucet	7/27/16 14:32	8/4/16 8:19	607284657	LEAD	2 PPB	15 PPB
08-59A Classroom 208 Drinking Fountain	7/27/16 14:32	8/4/16 8:19	607284658	LEAD	2 PPB	15 PPB
08-60A Classroom 207 Sink Faucet	7/27/16 14:34	8/4/16 8:19	607284659	LEAD	3 PPB	15 PPB
08-61A Classroom 207 Drinking Fountain	7/27/16 14:34	8/4/16 8:19	607284660	LEAD	1 PPB	15 PPB
08-62A Classroom 206 Sink Faucet	7/27/16 14:36	8/4/16 8:20	607284661	LEAD	3 PPB	15 PPB
08-63A Classroom 206 Drinking Fountain	7/27/16 14:36	8/4/16 8:20	607284662	LEAD	2 PPB	15 PPB
08-64A Classroom 209 Sink Faucet	7/27/16 14:38	8/4/16 8:20	607284663	LEAD	3 PPB	15 PPB
08-65A Classroom 203 Sink Faucet	7/27/16 14:40	8/4/16 8:20	607284664	LEAD	2 PPB	15 PPB
08-66A Classroom 203 Drinking Fountain	7/27/16 14:40	8/4/16 8:20	607284665	LEAD	< 1 PPB	15 PPB
08-67A Classroom 202 Sink Faucet	7/27/16 14:42	8/4/16 8:21	607284666	LEAD	13 PPB	15 PPB
08-68A Classroom 202 Drinking Fountain	7/27/16 14:42	8/3/16 10:23	607284667	LEAD	< 1 PPB	15 PPB
08-69A Classroom 201 Sink Faucet	7/27/16 14:44	8/3/16 10:23	607284668	LEAD	5 PPB	15 PPB
08-70A Classroom 201 Drinking Fountain	7/27/16 14:44	8/3/16 10:23	607284669	LEAD	3 PPB	15 PPB
08-71A Classroom 200 Sink Faucet	7/27/16 14:46	8/3/16 10:22	607284670	LEAD	2 PPB	15 PPB
08-72A Classroom 200 Drinking Fountain	7/27/16 14:46	8/3/16 10:22	607284671	LEAD	2 PPB	15 PPB
08-73A Computer 213 Sink Faucet	7/27/16 18:57	8/3/16 10:22	607284672	LEAD	3 PPB	15 PPB
08-74A Computer 213 Drinking Fountain	7/27/16 18:57	8/3/16 10:22	607284673	LEAD	2 PPB	15 PPB
08-75A Computer 212 Sink Faucet	7/27/16 18:47	8/3/16 10:22	607284674	LEAD	12 PPB	15 PPB
08-76A Computer 212 Drinking Fountain	7/27/16 18:47	8/3/16 10:21	607284675	LEAD	< 1 PPB	15 PPB
08-77A Classroom 211 Sink Faucet	7/27/16 18:42	8/3/16 10:21	607284676	LEAD	4 PPB	15 PPB
08-78A Classroom 211 Drinking Fountain	7/27/16 18:42	8/3/16 10:28	607284677	LEAD	1 PPB	15 PPB
08-79A Classroom 210 Sink Faucet	7/27/16 18:33	8/3/16 10:28	607284678	LEAD	< 1 PPB	15 PPB
08-80A Classroom 210 Drinking Fountain	7/27/16 18:34	8/3/16 10:28	607284679	LEAD	1 PPB	15 PPB
08-81A Classroom 314 Sink Faucet	7/27/16 14:48	8/3/16 10:28	607284680	LEAD	2 PPB	15 PPB
08-82A Classroom 314 Drinking Fountain	7/27/16 14:48	8/3/16 10:28	607284681	LEAD	1 PPB	15 PPB
08-83A Classroom 316 Sink Faucet	7/27/16 14:50	8/3/16 10:29	607284682	LEAD	1 PPB	15 PPB
08-84A Classroom 316 Drinking Fountain	7/27/16 14:50	8/3/16 10:29	607284683	LEAD	< 1 PPB	15 PPB
08-85A Hallway Drinking Fountain 7	7/27/16 17:53	8/3/16 10:29	607284684	LEAD	< 1 PPB	15 PPB
08-86A Hallway Drinking Fountain 8	7/27/16 17:54	8/3/16 10:29	607284685	LEAD	1 PPB	15 PPB
08-89A Classroom 317 Sink Faucet	7/27/16 14:52	8/3/16 11:12	6072846107	LEAD	8 PPB	15 PPB
08-90A Classroom 317 Drinking Fountain	7/27/16 14:52	8/3/16 10:30	607284686	LEAD	4 PPB	15 PPB
08-91A Classroom 312 Sink Faucet	7/27/16 14:54	8/3/16 10:32	607284687	LEAD	4 PPB	15 PPB
08-92A Classroom 312 Drinking Fountain	7/27/16 14:54	8/3/16 10:41	607284688	LEAD	2 PPB	15 PPB
08-93A Classroom 311 Sink Faucet	7/27/16 17:51	8/3/16 10:41	607284689	LEAD	2 PPB	15 PPB
08-94A Classroom 311 Drinking Fountain	7/27/16 17:51	8/3/16 10:42	607284690	LEAD	2 PPB	15 PPB
08-95A Room 310 Sink Faucet	7/27/16 17:50	8/3/16 10:42	607284691	LEAD	3 PPB	15 PPB
08-96A Room 300 Sink Faucet	7/27/16 17:25	8/3/16 10:42	607284692	LEAD	3 PPB	15 PPB
08-97A Room 300 Drinking Fountain	7/27/16 17:25	8/3/16 10:42	607284693	LEAD	1 PPB	15 PPB
08-98A Room 301 Sink Faucet	7/27/16 17:28	8/3/16 10:42	607284694	LEAD	8 PPB	15 PPB
08-99A Room 301 Drinking Fountain	7/27/16 17:28	8/3/16 10:43	607284695	LEAD	1 PPB	15 PPB
08-100A Room 302 Sink Faucet	7/27/16 17:31	8/3/16 10:44	607284696	LEAD	6 PPB	15 PPB
08-101A Room 302 Drinking Fountain	7/27/16 17:31	8/3/16 10:56	607284697	LEAD	1 PPB	15 PPB
08-102A Room 303 Sink Faucet	7/27/16 17:35	8/3/16 10:56	607284698	LEAD	1 PPB	15 PPB
08-103A Room 303 Drinking Fountain	7/27/16 17:35	8/3/16 10:56	607284699	LEAD	< 1 PPB	15 PPB
08-104A Room 304 Sink Faucet	7/27/16 17:40	8/3/16 10:57	6072846100	LEAD	3 PPB	15 PPB
08-105A Room 306 Sink Faucet	7/27/16 17:43	8/3/16 10:57	6072846101	LEAD	3 PPB	15 PPB
08-106A Room 306 Drinking Fountain	7/27/16 17:43	8/3/16 10:57	6072846102	LEAD	2 PPB	15 PPB
08-107A Room 307 Sink Faucet	7/27/16 17:45	8/3/16 10:59	6072846103	LEAD	4 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
08-108A Room 307 Drinking Fountain	7/27/16 17:45	8/3/16 10:59	6072846104	LEAD	< 1 PPB	15 PPB
08-109A Room 308 Sink Faucet	7/27/16 17:48	8/3/16 11:00	6072846105	LEAD	3 PPB	15 PPB
08-110A Room 308 Drinking Fountain	7/27/16 17:48	8/3/16 11:01	6072846106	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
08-53A Classroom 106 Sink Faucet	9/23/2016 4:27	9/26/2016	58297	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Claggett Creek Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
08-45B Classroom 100 Sink Faucet	7/27/16 17:07	8/23/16 11:31	608170201	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level