

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level	
09-01A	Gymnasium Drinking Fountain	8/4/16 7:45	8/6/2016	1608316-01A	COPPER	0.1 PPM	1.3 PPM
09-02A	Kitchen Food Prep Sink Faucet	8/4/16 7:58	8/6/2016	1608316-02A	COPPER	0.1 PPM	1.3 PPM
09-03A	Bathroom Entry Drinking Fountain (1)	8/4/16 8:01	8/6/2016	1608316-03A	COPPER	0.2 PPM	1.3 PPM
09-04A	Bathroom Entry Drinking Fountain (2)	8/4/16 8:01	8/6/2016	1608316-04A	COPPER	0.1 PPM	1.3 PPM
09-05A	Music Room Sink Faucet	8/4/16 8:04	8/6/2016	1608316-05A	COPPER	0.2 PPM	1.3 PPM
09-06A	Music Room Drinking Fountain	8/4/16 8:04	8/6/2016	1608316-06A	COPPER	0.2 PPM	1.3 PPM
09-07A	DLC Sink Faucet	8/4/16 8:23	8/6/2016	1608316-07A	COPPER	0.3 PPM	1.3 PPM
09-08A	DLC Drinking Fountain	8/4/16 8:23	8/6/2016	1608316-08A	COPPER	0.2 PPM	1.3 PPM
09-09A	Nurse Sink Faucet	8/4/16 8:36	8/6/2016	1608316-09A	COPPER	0.1 PPM	1.3 PPM
09-10A	Nurse Drinking Fountain	8/4/16 8:36	8/6/2016	1608316-10A	COPPER	0.2 PPM	1.3 PPM
09-11A	A-Pod Sink Faucet	8/4/16 8:54	8/6/2016	1608316-11A	COPPER	0.2 PPM	1.3 PPM
09-12A	A-Pod Drinking Fountain	8/4/16 8:54	8/6/2016	1608316-12A	COPPER	0.1 PPM	1.3 PPM
09-13A	Room A-1 Sink Faucet	8/4/16 8:56	8/6/2016	1608316-13A	COPPER	0.1 PPM	1.3 PPM
09-14A	Room A-1 Drinking Fountain	8/4/16 8:56	8/6/2016	1608316-14A	COPPER	0.1 PPM	1.3 PPM
09-15A	Room A-2 Sink Faucet	8/4/16 8:58	8/6/2016	1608316-15A	COPPER	0.1 PPM	1.3 PPM
09-16A	Room A-2 Drinking Fountain	8/4/16 8:58	8/6/2016	1608316-16A	COPPER	0.2 PPM	1.3 PPM
09-17A	Room A-3 Sink Faucet	8/4/16 9:05	8/6/2016	1608316-17A	COPPER	0.1 PPM	1.3 PPM
09-18A	Room A-3 Drinking Fountain	8/4/16 9:05	8/6/2016	1608316-18A	COPPER	0.2 PPM	1.3 PPM
09-19A	Room A-4 Sink Faucet	8/4/16 9:02	8/6/2016	1608316-19A	COPPER	0.1 PPM	1.3 PPM
09-20A	Room A-4 Drinking Fountain	8/4/16 9:02	8/6/2016	1608316-20A	COPPER	0.2 PPM	1.3 PPM
09-21A	Room A-5 Sink Faucet	8/4/16 9:07	8/6/2016	1608316-21A	COPPER	0.2 PPM	1.3 PPM
09-22A	Room A-5 Drinking Fountain	8/4/16 9:07	8/6/2016	1608316-22A	COPPER	0.2 PPM	1.3 PPM
09-23A	Room A-6 Sink Faucet	8/4/16 9:10	8/6/2016	1608316-23A	COPPER	0.1 PPM	1.3 PPM
09-24A	Room A-6 Drinking Fountain	8/4/16 9:10	8/6/2016	1608316-24A	COPPER	0.2 PPM	1.3 PPM
09-25A	Faculty Lounge Sink Faucet	8/4/16 9:15	8/6/2016	1608316-25A	COPPER	0.1 PPM	1.3 PPM
09-26A	Faculty Lounge Refrigerated Drinking Fountain	8/4/16 9:14	8/6/2016	1608316-26A	COPPER	0.0 PPM	1.3 PPM
09-27A	Library Sink Faucet	8/4/16 9:32	8/6/2016	1608316-27A	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
09-28A Library Drinking Fountain	8/4/16 9:32	8/6/2016	1608316-28A	COPPER	0.1 PPM	1.3 PPM
09-29A B-Pod Sink Faucet	8/4/16 9:49	8/6/2016	1608316-29A	COPPER	0.1 PPM	1.3 PPM
09-30A B-Pod Drinking Fountain	8/4/16 9:49	8/6/2016	1608316-30A	COPPER	0.1 PPM	1.3 PPM
09-31A Room B-6 Sink Faucet	8/4/16 9:50	8/6/2016	1608316-31A	COPPER	0.1 PPM	1.3 PPM
09-32A Room B-6 Drinking Fountain	8/4/16 9:50	8/6/2016	1608316-32A	COPPER	0.1 PPM	1.3 PPM
09-33A Room B-5 Sink Faucet	8/4/16 9:51	8/6/2016	1608316-33A	COPPER	0.1 PPM	1.3 PPM
09-34A Room B-5 Drinking Fountain	8/4/16 9:51	8/6/2016	1608316-34A	COPPER	0.2 PPM	1.3 PPM
09-35A Room B-4 Sink Faucet	8/4/16 9:57	8/6/2016	1608316-35A	COPPER	0.2 PPM	1.3 PPM
09-36A Room B-4 Drinking Fountain	8/4/16 9:57	8/6/2016	1608316-36A	COPPER	0.1 PPM	1.3 PPM
09-37A Room B-3 Sink Faucet	8/4/16 9:59	8/6/2016	1608316-37A	COPPER	0.1 PPM	1.3 PPM
09-38A Room B-3 Drinking Fountain	8/4/16 9:59	8/6/2016	1608316-38A	COPPER	0.2 PPM	1.3 PPM
09-39A Room B-2 Sink Faucet	8/4/16 10:01	8/6/2016	1608316-39A	COPPER	0.2 PPM	1.3 PPM
09-40A Room B-2 Drinking Fountain	8/4/16 10:01	8/6/2016	1608316-40A	COPPER	0.1 PPM	1.3 PPM
09-41A Room B-1 Sink Faucet	8/4/16 10:03	8/6/2016	1608316-41A	COPPER	0.1 PPM	1.3 PPM
09-42A Room B-1 Drinking Fountain	8/4/16 10:03	8/6/2016	1608316-42A	COPPER	0.2 PPM	1.3 PPM
09-43A Bathroom Entry Drinking Fountain	8/4/16 10:09	8/6/2016	1608316-43A	COPPER	0.2 PPM	1.3 PPM
09-44A C-Pod Sink Faucet	8/4/16 10:27	8/6/2016	1608316-44A	COPPER	0.2 PPM	1.3 PPM
09-45A C-Pod Drinking Fountain	8/4/16 10:27	8/6/2016	1608316-45A	COPPER	0.2 PPM	1.3 PPM
09-46A Room C-6 Sink Faucet	8/4/16 10:29	8/6/2016	1608316-46A	COPPER	0.2 PPM	1.3 PPM
09-47A Room C-6 Drinking Fountain	8/4/16 10:29	8/6/2016	1608316-47A	COPPER	0.2 PPM	1.3 PPM
09-48A Room C-5 Sink Faucet	8/4/16 10:31	8/6/2016	1608316-48A	COPPER	0.1 PPM	1.3 PPM
09-49A Room C-5 Drinking Fountain	8/4/16 10:31	8/6/2016	1608316-49A	COPPER	0.2 PPM	1.3 PPM
09-50A Room C-4 Sink Faucet	8/4/16 10:33	8/6/2016	1608316-50A	COPPER	0.1 PPM	1.3 PPM
09-51A Room C-4 Drinking Fountain	8/4/16 10:33	8/6/2016	1608316-51A	COPPER	0.2 PPM	1.3 PPM
09-52A Room C-3 Sink Faucet	8/4/16 10:35	8/6/2016	1608316-52A	COPPER	0.2 PPM	1.3 PPM
09-53A Room C-3 Drinking Fountain	8/4/16 10:35	8/6/2016	1608316-53A	COPPER	0.2 PPM	1.3 PPM
09-54A Room C-2 Sink Faucet	8/4/16 10:37	8/6/2016	1608316-54A	COPPER	0.1 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
09-55A Room C-2 Drinking Fountain	8/4/16 10:37	8/6/2016	1608316-55A	COPPER	0.1 PPM	1.3 PPM
09-56A Room C-1 Sink Faucet	8/4/16 10:40	8/6/2016	1608316-56A	COPPER	0.2 PPM	1.3 PPM
09-57A Room C-1 Drinking Fountain	8/4/16 10:40	8/6/2016	1608316-57A	COPPER	0.2 PPM	1.3 PPM
09-58A Kitchenette in Café Sink Faucet	8/4/16 8:11	8/6/2016	1608316-58A	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
09-09B Nurse Sink Faucet	8/4/16 8:37	8/24/2016	1608317-09A	COPPER	0.2 PPM	1.3 PPM
09-15B Room A-2 Sink Faucet	8/4/16 8:59	8/24/2016	1608317-15A	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
09-09C Nurse Sink Faucet	9/30/2016 4:55	10/3/2016	59708	COPPER	0.1 PPM	1.3 PPM
09-15C Room A-2 Sink Faucet	9/30/2016 5:00	10/3/2016	59709	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level