

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
09-01A Gymnasium Drinking Fountain	8/4/16 7:45	8/6/2016	1608316-01A	LEAD	<1.0 PPB	15 PPB
09-02A Kitchen Food Prep Sink Faucet	8/4/16 7:58	8/6/2016	1608316-02A	LEAD	5 PPB	15 PPB
09-03A Bathroom Entry Drinking Fountain (1)	8/4/16 8:01	8/6/2016	1608316-03A	LEAD	<1.0 PPB	15 PPB
09-04A Bathroom Entry Drinking Fountain (2)	8/4/16 8:01	8/6/2016	1608316-04A	LEAD	<1.0 PPB	15 PPB
09-05A Music Room Sink Faucet	8/4/16 8:04	8/6/2016	1608316-05A	LEAD	10 PPB	15 PPB
09-06A Music Room Drinking Fountain	8/4/16 8:04	8/6/2016	1608316-06A	LEAD	<1.0 PPB	15 PPB
09-07A DLC Sink Faucet	8/4/16 8:23	8/6/2016	1608316-07A	LEAD	10 PPB	15 PPB
09-08A DLC Drinking Fountain	8/4/16 8:23	8/6/2016	1608316-08A	LEAD	<1.0 PPB	15 PPB
<b>09-09A Nurse Sink Faucet</b>	<b>8/4/16 8:36</b>	<b>8/6/2016</b>	<b>1608316-09A</b>	<b>LEAD</b>	<b>15 PPB</b>	<b>15 PPB</b>
09-10A Nurse Drinking Fountain	8/4/16 8:36	8/6/2016	1608316-10A	LEAD	<1.0 PPB	15 PPB
09-11A A-Pod Sink Faucet	8/4/16 8:54	8/6/2016	1608316-11A	LEAD	8 PPB	15 PPB
09-12A A-Pod Drinking Fountain	8/4/16 8:54	8/6/2016	1608316-12A	LEAD	<1.0 PPB	15 PPB
09-13A Room A-1 Sink Faucet	8/4/16 8:56	8/6/2016	1608316-13A	LEAD	11 PPB	15 PPB
09-14A Room A-1 Drinking Fountain	8/4/16 8:56	8/6/2016	1608316-14A	LEAD	<1.0 PPB	15 PPB
<b>09-15A Room A-2 Sink Faucet</b>	<b>8/4/16 8:58</b>	<b>8/6/2016</b>	<b>1608316-15A</b>	<b>LEAD</b>	<b>15 PPB</b>	<b>15 PPB</b>
09-16A Room A-2 Drinking Fountain	8/4/16 8:58	8/6/2016	1608316-16A	LEAD	<1.0 PPB	15 PPB
09-17A Room A-3 Sink Faucet	8/4/16 9:05	8/6/2016	1608316-17A	LEAD	8 PPB	15 PPB
09-18A Room A-3 Drinking Fountain	8/4/16 9:05	8/6/2016	1608316-18A	LEAD	<1.0 PPB	15 PPB
09-19A Room A-4 Sink Faucet	8/4/16 9:02	8/6/2016	1608316-19A	LEAD	8 PPB	15 PPB
09-20A Room A-4 Drinking Fountain	8/4/16 9:02	8/6/2016	1608316-20A	LEAD	<1.0 PPB	15 PPB
09-21A Room A-5 Sink Faucet	8/4/16 9:07	8/6/2016	1608316-21A	LEAD	7 PPB	15 PPB
09-22A Room A-5 Drinking Fountain	8/4/16 9:07	8/6/2016	1608316-22A	LEAD	<1.0 PPB	15 PPB
09-23A Room A-6 Sink Faucet	8/4/16 9:10	8/6/2016	1608316-23A	LEAD	13 PPB	15 PPB
09-24A Room A-6 Drinking Fountain	8/4/16 9:10	8/6/2016	1608316-24A	LEAD	<1.0 PPB	15 PPB
09-25A Faculty Lounge Sink Faucet	8/4/16 9:15	8/6/2016	1608316-25A	LEAD	<1.0 PPB	15 PPB
09-26A Faculty Lounge Refrigerated Drinking Fountain	8/4/16 9:14	8/6/2016	1608316-26A	LEAD	<1.0 PPB	15 PPB
09-27A Library Sink Faucet	8/4/16 9:32	8/6/2016	1608316-27A	LEAD	9 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
09-28A	Library Drinking Fountain	8/4/16 9:32	8/6/2016	1608316-28A	LEAD	1 PPB 15 PPB
09-29A	B-Pod Sink Faucet	8/4/16 9:49	8/6/2016	1608316-29A	LEAD	14 PPB 15 PPB
09-30A	B-Pod Drinking Fountain	8/4/16 9:49	8/6/2016	1608316-30A	LEAD	<1.0 PPB 15 PPB
09-31A	Room B-6 Sink Faucet	8/4/16 9:50	8/6/2016	1608316-31A	LEAD	10 PPB 15 PPB
09-32A	Room B-6 Drinking Fountain	8/4/16 9:50	8/6/2016	1608316-32A	LEAD	<1.0 PPB 15 PPB
09-33A	Room B-5 Sink Faucet	8/4/16 9:51	8/6/2016	1608316-33A	LEAD	13 PPB 15 PPB
09-34A	Room B-5 Drinking Fountain	8/4/16 9:51	8/6/2016	1608316-34A	LEAD	<1.0 PPB 15 PPB
09-35A	Room B-4 Sink Faucet	8/4/16 9:57	8/6/2016	1608316-35A	LEAD	9 PPB 15 PPB
09-36A	Room B-4 Drinking Fountain	8/4/16 9:57	8/6/2016	1608316-36A	LEAD	<1.0 PPB 15 PPB
09-37A	Room B-3 Sink Faucet	8/4/16 9:59	8/6/2016	1608316-37A	LEAD	13 PPB 15 PPB
09-38A	Room B-3 Drinking Fountain	8/4/16 9:59	8/6/2016	1608316-38A	LEAD	<1.0 PPB 15 PPB
09-39A	Room B-2 Sink Faucet	8/4/16 10:01	8/6/2016	1608316-39A	LEAD	11 PPB 15 PPB
09-40A	Room B-2 Drinking Fountain	8/4/16 10:01	8/6/2016	1608316-40A	LEAD	<1.0 PPB 15 PPB
09-41A	Room B-1 Sink Faucet	8/4/16 10:03	8/6/2016	1608316-41A	LEAD	12 PPB 15 PPB
09-42A	Room B-1 Drinking Fountain	8/4/16 10:03	8/6/2016	1608316-42A	LEAD	<1.0 PPB 15 PPB
09-43A	Bathroom Entry Drinking Fountain	8/4/16 10:09	8/6/2016	1608316-43A	LEAD	<1.0 PPB 15 PPB
09-44A	C-Pod Sink Faucet	8/4/16 10:27	8/6/2016	1608316-44A	LEAD	3 PPB 15 PPB
09-45A	C-Pod Drinking Fountain	8/4/16 10:27	8/6/2016	1608316-45A	LEAD	<1.0 PPB 15 PPB
09-46A	Room C-6 Sink Faucet	8/4/16 10:29	8/6/2016	1608316-46A	LEAD	11 PPB 15 PPB
09-47A	Room C-6 Drinking Fountain	8/4/16 10:29	8/6/2016	1608316-47A	LEAD	<1.0 PPB 15 PPB
09-48A	Room C-5 Sink Faucet	8/4/16 10:31	8/6/2016	1608316-48A	LEAD	9 PPB 15 PPB
09-49A	Room C-5 Drinking Fountain	8/4/16 10:31	8/6/2016	1608316-49A	LEAD	1 PPB 15 PPB
09-50A	Room C-4 Sink Faucet	8/4/16 10:33	8/6/2016	1608316-50A	LEAD	10 PPB 15 PPB
09-51A	Room C-4 Drinking Fountain	8/4/16 10:33	8/6/2016	1608316-51A	LEAD	<1.0 PPB 15 PPB
09-52A	Room C-3 Sink Faucet	8/4/16 10:35	8/6/2016	1608316-52A	LEAD	11 PPB 15 PPB
09-53A	Room C-3 Drinking Fountain	8/4/16 10:35	8/6/2016	1608316-53A	LEAD	<1.0 PPB 15 PPB
09-54A	Room C-2 Sink Faucet	8/4/16 10:37	8/6/2016	1608316-54A	LEAD	11 PPB 15 PPB

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (A) Sample Data  
 Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
09-55A Room C-2 Drinking Fountain	8/4/16 10:37	8/6/2016	1608316-55A	LEAD	<1.0 PPB	15 PPB
09-56A Room C-1 Sink Faucet	8/4/16 10:40	8/6/2016	1608316-56A	LEAD	9 PPB	15 PPB
09-57A Room C-1 Drinking Fountain	8/4/16 10:40	8/6/2016	1608316-57A	LEAD	<1.0 PPB	15 PPB
09-58A Kitchenette in Café Sink Faucet	8/4/16 8:11	8/6/2016	1608316-58A	LEAD	12 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Clear Lake Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
09-09C Nurse Sink Faucet	9/30/2016 4:55	10/3/2016	59708	LEAD	2 PPB	15 PPB
09-15C Room A-2 Sink Faucet	9/30/2016 5:00	10/3/2016	59709	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**