

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-01A Music 121 Drinking Fountain (Left)	7/28/16 11:44	8/3/16 12:26	607291301	LEAD	< 1 PPB	15 PPB
044-02A Music 121 Drinking Fountain (Right)	7/28/16 11:46	8/3/16 12:26	607291302	LEAD	< 1 PPB	15 PPB
044-03A Shop 123 Drinking Fountain (Left)	7/28/16 11:48	8/3/16 12:27	607291303	LEAD	< 1 PPB	15 PPB
044-04A Shop 123 Drinking Fountain (Right)	7/28/16 11:50	8/3/16 12:27	607291304	LEAD	< 1 PPB	15 PPB
044-05A Classroom 122 Sink Faucet	7/28/16 11:51	8/3/16 12:27	607291305	LEAD	4 PPB	15 PPB
044-06A Classroom 122 Drinking Fountain	7/28/16 11:51	8/3/16 12:27	607291306	LEAD	2 PPB	15 PPB
044-07A Choir 120 Drinking Fountain (Left)	7/28/16 11:55	8/3/16 12:27	607291307	LEAD	< 1 PPB	15 PPB
044-08A Choir 120 Drinking Fountain (Right)	7/28/16 11:57	8/3/16 12:30	607291308	LEAD	< 1 PPB	15 PPB
044-09A Main Gymnasium Drinking Fountain (Left)	7/28/16 11:59	8/3/16 12:31	607291309	LEAD	< 1 PPB	15 PPB
044-10A Main Gymnasium Drinking Fountain (Right)	7/28/16 12:00	8/3/16 12:31	607291310	LEAD	2 PPB	15 PPB
044-11A Auxillary Gymnasium Drinking Fountain (Left)	7/28/16 12:03	8/3/16 12:31	607291311	LEAD	< 1 PPB	15 PPB
044-12A Auxillary Gymnasium Drinking Fountain (Right)	7/28/16 12:04	8/3/16 12:31	607291312	LEAD	2 PPB	15 PPB
044-13A Girls Lockers Drinking Fountain (Left)	7/28/16 12:06	8/3/16 12:32	607291313	LEAD	1 PPB	15 PPB
044-14A Girls Lockers Drinking Fountain (Right)	7/28/16 12:07	8/3/16 12:32	607291314	LEAD	1 PPB	15 PPB
044-15A Boys Lockers Drinking Fountain (Left)	7/28/16 12:10	8/3/16 12:32	607291315	LEAD	1 PPB	15 PPB
044-16A Boys Lockers Drinking Fountain (Right)	7/28/16 12:11	8/3/16 12:34	607291316	LEAD	1 PPB	15 PPB
044-17A Home Economics Sink Faucet 1	7/28/16 12:21	8/3/16 12:34	607291317	LEAD	4 PPB	15 PPB
044-18A Home Economics Sink Faucet 2	7/28/16 14:29	8/3/16 12:43	607291318	LEAD	4 PPB	15 PPB
044-19A Home Economics Sink Faucet 3	7/28/16 12:23	8/3/16 12:44	607291319	LEAD	4 PPB	15 PPB
044-20A Home Economics Sink Faucet 4	7/28/16 12:24	8/3/16 12:44	607291320	LEAD	3 PPB	15 PPB
044-21A Home Economics Sink Faucet 5	7/28/16 12:25	8/3/16 12:44	607291321	LEAD	5 PPB	15 PPB
044-22A Home Economics Sink Faucet 6	7/28/16 12:26	8/3/16 12:44	607291322	LEAD	3 PPB	15 PPB
044-23A Home Economics Refrigerator Ice Maker 1	7/28/16 12:28	8/3/16 12:45	607291323	LEAD	< 1 PPB	15 PPB
044-24A Home Economics Refrigerator Ice Maker 2	7/28/16 12:30	8/3/16 12:45	607291324	LEAD	< 1 PPB	15 PPB
044-27A Student Store Sink Faucet	7/28/16 12:36	8/3/16 12:49	607291325	LEAD	4 PPB	15 PPB
044-28A Hallway Drinking Fountain 1	7/28/16 12:39	8/3/16 12:49	607291326	LEAD	< 1 PPB	15 PPB
044-29A Hallway Drinking Fountain 2	7/28/16 12:40	8/3/16 12:49	607291327	LEAD	< 1 PPB	15 PPB
044-30A Commons Drinking Fountain (Left)	7/28/16 12:43	8/3/16 12:52	607291328	LEAD	< 1 PPB	15 PPB
044-31A Commons Drinking Fountain (Right)	7/28/16 12:44	8/3/16 12:53	607291329	LEAD	< 1 PPB	15 PPB
044-32A Kitchen Ice Maker	7/28/16 12:49	8/3/16 12:53	607291330	LEAD	< 1 PPB	15 PPB
044-33A Kitchen Food Prep Sink Faucet	7/28/16 12:52	8/3/16 12:53	607291331	LEAD	3 PPB	15 PPB
044-34A Hallway Drinking Fountain 3	7/28/16 12:57	8/3/16 12:53	607291332	LEAD	< 1 PPB	15 PPB
044-35A Hallway Drinking Fountain 4	7/28/16 12:58	8/3/16 12:53	607291333	LEAD	< 1 PPB	15 PPB
044-36A Hallway Drinking Fountain 5	7/28/16 13:01	8/3/16 12:54	607291334	LEAD	< 1 PPB	15 PPB
044-37A Hallway Drinking Fountain 6	7/28/16 13:02	8/3/16 12:54	607291335	LEAD	< 1 PPB	15 PPB
044-38A Room 116 Sink Faucet	7/28/16 13:04	8/3/16 12:54	607291336	LEAD	8 PPB	15 PPB
044-39A Room 115 Sink Faucet	7/28/16 13:06	8/3/16 12:54	607291337	LEAD	7 PPB	15 PPB
044-40A Room 115 Drinking Fountain	7/28/16 13:06	8/3/16 12:57	607291338	LEAD	3 PPB	15 PPB
044-41A Room 114 Sink Faucet	7/28/16 13:09	8/3/16 12:57	607291339	LEAD	2 PPB	15 PPB
044-42A Room 114 Drinking Fountain	7/28/16 13:09	8/3/16 12:58	607291340	LEAD	3 PPB	15 PPB
044-43A Room 113 Sink Faucet	7/28/16 13:13	8/3/16 12:58	607291341	LEAD	< 1 PPB	15 PPB
044-44A Room 113 Drinking Fountain	7/28/16 13:13	8/3/16 13:00	607291342	LEAD	< 1 PPB	15 PPB
044-45A Room 112 Sink Faucet	7/28/16 13:16	8/3/16 13:00	607291343	LEAD	4 PPB	15 PPB
044-46A Room 112 Drinking Fountain	7/28/16 13:16	8/3/16 13:00	607291344	LEAD	1 PPB	15 PPB
044-47A Room 111 Drinking Fountain	7/28/16 13:20	8/3/16 13:00	607291345	LEAD	1 PPB	15 PPB
044-48A Room 111 Sink Faucet	7/28/16 13:20	8/3/16 13:01	607291346	LEAD	3 PPB	15 PPB
044-49A Room 110 Sink Faucet	7/28/16 13:23	8/3/16 13:04	607291347	LEAD	< 1 PPB	15 PPB
044-50A Room 110 Drinking Fountain	7/28/16 13:24	8/3/16 13:48	607291348	LEAD	2 PPB	15 PPB
044-51A Hallway Drinking Fountain 7	7/28/16 13:30	8/3/16 13:49	607291349	LEAD	< 1 PPB	15 PPB
044-52A Hallway Drinking Fountain 8	7/28/16 13:30	8/3/16 13:49	607291350	LEAD	< 1 PPB	15 PPB
044-53A Classroom 108 Drinking Fountain	7/28/16 13:34	8/3/16 13:49	607291351	LEAD	1 PPB	15 PPB
044-54A Classroom 108 Sink Faucet	7/28/16 13:33	8/3/16 13:49	607291352	LEAD	2 PPB	15 PPB
044-55A Classroom 101 Sink Faucet	7/28/16 13:38	8/3/16 13:49	607291353	LEAD	6 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-56A Classroom 101 Drinking Fountain	7/28/16 13:38	8/3/16 13:50	607291354	LEAD	7 PPB	15 PPB
044-57A Classroom 103 Sink Faucet	7/28/16 13:48	8/3/16 13:50	607291355	LEAD	6 PPB	15 PPB
044-58A Classroom 103 Drinking Fountain	7/28/16 13:42	8/3/16 13:50	607291356	LEAD	< 1 PPB	15 PPB
044-59A Classroom 104 Drinking Fountain	7/28/16 13:45	8/3/16 13:50	607291357	LEAD	4 PPB	15 PPB
044-60A Classroom 104 Sink Faucet	7/28/16 13:45	8/5/16 13:03	607291358	LEAD	1 PPB	15 PPB
<b>044-61A Classroom 105 Sink Faucet</b>	<b>7/28/16 13:49</b>	<b>8/5/16 13:04</b>	<b>607291359</b>	<b>LEAD</b>	<b>64 PPB</b>	<b>15 PPB</b>
044-62A Classroom 105 Drinking Fountain	7/28/16 13:56	8/5/16 13:04	607291360	LEAD	3 PPB	15 PPB
044-63A Staff Lounge Sink Faucet	7/28/16 12:55	8/5/16 13:04	607291361	LEAD	6 PPB	15 PPB
044-64A Hallway Drinking Fountain 9	7/28/16 12:42	8/5/16 13:04	607291362	LEAD	1 PPB	15 PPB
044-65A Hallway Drinking Fountain 10	7/28/16 12:44	8/5/16 13:04	607291363	LEAD	1 PPB	15 PPB
044-66A Classroom 209 Drinking Fountain	7/28/16 12:49	8/5/16 13:04	607291364	LEAD	6 PPB	15 PPB
044-67A Classroom 209 Sink Faucet	7/28/16 12:51	8/5/16 13:04	607291365	LEAD	4 PPB	15 PPB
044-68A Room 207 Sink Faucet	7/28/16 12:55	8/5/16 13:04	607291366	LEAD	6 PPB	15 PPB
044-69A Classroom 206 Sink Faucet	7/28/16 12:58	8/5/16 13:04	607291367	LEAD	4 PPB	15 PPB
044-70A Classroom 206 Drinking Fountain	7/28/16 13:00	8/5/16 13:04	607291368	LEAD	3 PPB	15 PPB
044-71A Classroom 201 Sink Faucet	7/28/16 13:02	8/5/16 13:04	607291369	LEAD	4 PPB	15 PPB
044-72A Classroom 201 Drinking Fountain	7/28/16 13:04	8/5/16 13:04	607291370	LEAD	< 1 PPB	15 PPB
044-73A Classroom 202 Sink Faucet	7/28/16 13:05	8/5/16 13:04	607291371	LEAD	3 PPB	15 PPB
044-74A Classroom 202 Drinking Fountain	7/28/16 13:07	8/5/16 13:04	607291372	LEAD	< 1 PPB	15 PPB
044-75A Classroom 203 Drinking Fountain	7/28/16 13:09	8/5/16 13:04	607291373	LEAD	3 PPB	15 PPB
044-76A Classroom 203 Sink Faucet	7/28/16 13:11	8/5/16 13:04	607291374	LEAD	3 PPB	15 PPB
044-77A Classroom 204 Sink Faucet	7/28/16 13:13	8/5/16 13:04	607291375	LEAD	5 PPB	15 PPB
044-78A Classroom 204 Drinking Fountain	7/28/16 13:15	8/5/16 13:04	607291376	LEAD	2 PPB	15 PPB
044-79A Classroom 205 Drinking Fountain	7/28/16 13:17	8/5/16 13:04	607291377	LEAD	< 1 PPB	15 PPB
044-80A Classroom 205 Sink Faucet	7/28/16 13:19	8/5/16 13:04	607291378	LEAD	3 PPB	15 PPB
044-81A Hallway Drinking Fountain 11	7/28/16 13:20	8/5/16 13:05	607291379	LEAD	< 1 PPB	15 PPB
044-82A Hallway Drinking Fountain 12	7/28/16 13:22	8/5/16 13:05	607291380	LEAD	< 1 PPB	15 PPB
044-83A Classroom 200 Sink Faucet	7/28/16 12:46	8/5/16 13:05	607291381	LEAD	7 PPB	15 PPB
044-84A Classroom 200 Drinking Fountain	7/28/16 12:48	8/5/16 13:06	6072913101	LEAD	3 PPB	15 PPB
044-85A Classroom 218 Drinking Fountain	7/28/16 13:24	8/5/16 13:05	607291382	LEAD	3 PPB	15 PPB
044-86A Classroom 218 Sink Faucet	7/28/16 13:26	8/5/16 13:05	607291383	LEAD	2 PPB	15 PPB
044-87A Room 216 Sink Faucet	7/28/16 13:30	8/5/16 13:05	607291384	LEAD	< 1 PPB	15 PPB
044-88A Classroom 215 Sink Faucet	7/28/16 13:32	8/5/16 13:05	607291385	LEAD	5 PPB	15 PPB
044-89A Classroom 215 Drinking Fountain	7/28/16 13:34	8/5/16 13:05	607291386	LEAD	2 PPB	15 PPB
044-90A Classroom 210 Sink Faucet	7/28/16 13:38	8/5/16 13:05	607291387	LEAD	5 PPB	15 PPB
044-91A Classroom 210 Drinking Fountain	7/28/16 13:38	8/5/16 13:05	607291388	LEAD	2 PPB	15 PPB
044-92A Classroom 211 Sink Faucet	7/28/16 13:40	8/5/16 13:05	607291389	LEAD	1 PPB	15 PPB
044-93A Classroom 211 Drinking Fountain	7/28/16 13:42	8/5/16 13:05	607291390	LEAD	2 PPB	15 PPB
044-94A Classroom 212 Drinking Fountain	7/28/16 13:45	8/5/16 13:05	607291391	LEAD	6 PPB	15 PPB
044-95A Classroom 212 Sink Faucet	7/28/16 13:47	8/5/16 13:05	607291392	LEAD	3 PPB	15 PPB
044-96A Classroom 213 Sink Faucet	7/28/16 13:50	8/5/16 13:05	607291393	LEAD	2 PPB	15 PPB
044-97A Classroom 213 Drinking Fountain	7/28/16 13:52	8/5/16 13:05	607291394	LEAD	1 PPB	15 PPB
044-98A Classroom 214 Drinking Fountain	7/28/16 13:56	8/5/16 13:05	607291395	LEAD	2 PPB	15 PPB
044-99A Classroom 214 Sink Faucet	7/28/16 13:58	8/5/16 13:05	607291396	LEAD	3 PPB	15 PPB
044-100A Classroom 219 Drinking Fountain	7/28/16 14:02	8/5/16 13:05	607291397	LEAD	8 PPB	15 PPB
044-101A Classroom 215 Sink Faucet	7/28/16 14:04	8/5/16 13:05	607291398	LEAD	8 PPB	15 PPB
044-102A Hallway Drinking Fountain 12	7/28/16 14:00	8/5/16 13:06	607291399	LEAD	5 PPB	15 PPB
044-103A Hallway Drinking Fountain 13	7/28/16 14:04	8/5/16 13:06	6072913100	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
044-25A Home Economics Refrigerator Ice Maker #3	9/22/2016 5:50	9/26/2016	57951	LEAD	<1 PPB	15 PPB
044-26A Home Economics Refrigerator Ice Maker #4	9/22/2016 5:51	9/26/2016	57952	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Crossler Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
044-61B Classroom 105 Sink Faucet	7/28/16 13:50	8/24/16 12:48	608173901	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**