

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Career Technical Education Center (CTEC)

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
73-01A Main Office Sink	8/6/2016 8:35	8/23/2016	49927	COPPER	0.3 PPM	1.3 PPM
73-02A Main Office Fridge Ice maker	8/6/2016 8:35	8/23/2016	49928	COPPER	0.0 PPM	1.3 PPM
73-03A Manufacturing Drinking fountain	8/6/2016 8:40	8/23/2016	49929	COPPER	0.6 PPM	1.3 PPM
73-04A Construction Drinking Fountain	8/6/2016 8:41	8/23/2016	49930	COPPER	0.7 PPM	1.3 PPM
73-05A Outside Kitchen Drinking Fountain	8/6/2016 8:47	8/23/2016	49931	COPPER	0.0 PPM	1.3 PPM
73-06A Outside Kitchen Bottle Filler	8/6/2016 8:47	8/23/2016	49932	COPPER	0.0 PPM	1.3 PPM
73-07A Room 201 Drinking Fountain	8/6/2016 8:43	8/23/2016	49933	COPPER	0.0 PPM	1.3 PPM
73-08A Room 201 Drinking Fountain	8/6/2016 8:43	8/23/2016	49934	COPPER	0.0 PPM	1.3 PPM
73-09A Room 201 Bottle Refill	8/6/2016 8:44	8/23/2016	49935	COPPER	0.0 PPM	1.3 PPM
73-10A Art Room Sink Faucet (Left)	8/6/2016 9:04	8/23/2016	49936	COPPER	0.5 PPM	1.3 PPM
73-11A Art Room Sink Faucet (Right)	8/6/2016 9:04	8/23/2016	49937	COPPER	0.1 PPM	1.3 PPM
73-12A Room 117 -Sink Faucet	8/6/2016 9:10	8/23/2016	49938	COPPER	0.1 PPM	1.3 PPM
73-13A Cosmetology Lobby Drinking Fountain	8/6/2016 8:51	8/23/2016	49939	COPPER	0.0 PPM	1.3 PPM
73-14A Cosmetology Lobby Drinking Fountain	8/6/2016 8:52	8/23/2016	49940	COPPER	0.0 PPM	1.3 PPM
73-15A Cosmetology Lobby Bottle Refill	8/6/2016 8:52	8/23/2016	49941	COPPER	0.0 PPM	1.3 PPM
73-16A Facial Room Sink Faucet	8/6/2016 9:13	8/23/2016	49942	COPPER	0.0 PPM	1.3 PPM
73-17A Cosmetogy Room Sink Faucet	8/6/2016 9:14	8/23/2016	49943	COPPER	0.0 PPM	1.3 PPM
73-18A Cosmetology Classroom Sink Faucet	8/6/2016 9:15	8/23/2016	49944	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level