

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Career Technical Education Center (CTEC)

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
73-01A Main Office Sink	8/6/2016 8:35	8/23/2016	49927	LEAD	1 PPB	15 PPB
73-02A Main Office Fridge Ice maker	8/6/2016 8:35	8/23/2016	49928	LEAD	<1 PPB	15 PPB
73-03A Manufacturing Drinking fountain	8/6/2016 8:40	8/23/2016	49929	LEAD	<1 PPB	15 PPB
73-04A Construction Drinking Fountain	8/6/2016 8:41	8/23/2016	49930	LEAD	<1 PPB	15 PPB
73-05A Outside Kitchen Drinking Fountain	8/6/2016 8:47	8/23/2016	49931	LEAD	<1 PPB	15 PPB
73-06A Outside Kitchen Bottle Filler	8/6/2016 8:47	8/23/2016	49932	LEAD	<1 PPB	15 PPB
73-07A Room 201 Drinking Fountain	8/6/2016 8:43	8/23/2016	49933	LEAD	<1 PPB	15 PPB
73-08A Room 201 Drinking Fountain	8/6/2016 8:43	8/23/2016	49934	LEAD	<1 PPB	15 PPB
73-09A Room 201 Bottle Refill	8/6/2016 8:44	8/23/2016	49935	LEAD	<1 PPB	15 PPB
73-10A Art Room Sink Faucet (Left)	8/6/2016 9:04	8/23/2016	49936	LEAD	<1 PPB	15 PPB
73-11A Art Room Sink Faucet (Right)	8/6/2016 9:04	8/23/2016	49937	LEAD	<1 PPB	15 PPB
73-12A Room 117 -Sink Faucet	8/6/2016 9:10	8/23/2016	49938	LEAD	<1 PPB	15 PPB
73-13A Cosmetology Lobby Drinking Fountain	8/6/2016 8:51	8/23/2016	49939	LEAD	<1 PPB	15 PPB
73-14A Cosmetology Lobby Drinking Fountain	8/6/2016 8:52	8/23/2016	49940	LEAD	<1 PPB	15 PPB
73-15A Cosmetology Lobby Bottle Refill	8/6/2016 8:52	8/23/2016	49941	LEAD	<1 PPB	15 PPB
73-16A Facial Room Sink Faucet	8/6/2016 9:13	8/23/2016	49942	LEAD	<1 PPB	15 PPB
73-17A Cosmetogy Room Sink Faucet	8/6/2016 9:14	8/23/2016	49943	LEAD	<1 PPB	15 PPB
73-18A Cosmetology Classroom Sink Faucet	8/6/2016 9:15	8/23/2016	49944	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level