

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Cummings Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|---|-------------------|---------------|--------------|------------|---------|--------------|
| 11-01A Drinking Fountain Corridor 32 at Room 9 | 7/28/2016 9:22 | 8/17/2016 | 47538 | LEAD | 1 PPB | 15 PPB |
| 11-02A Media Center Office Sink Faucet | 7/28/2016 9:26 | 8/17/2016 | 47539 | LEAD | 2 PPB | 15 PPB |
| 11-03A LRC Office Sink Faucet | 7/28/2016 9:30 | 8/17/2016 | 47540 | LEAD | 1 PPB | 15 PPB |
| 11-04A Classroom 8 Sink Faucet | 7/28/2016 9:37 | 8/17/2016 | 47541 | LEAD | 1 PPB | 15 PPB |
| 11-05A Classroom 8 Drinking Fountain | 7/28/2016 9:39 | 8/17/2016 | 47542 | LEAD | 2 PPB | 15 PPB |
| 11-06A Classroom 9 Sink Faucet | 7/28/2016 9:41 | 8/17/2016 | 47543 | LEAD | 3 PPB | 15 PPB |
| 11-07A Classroom 9 Drinking Fountain | 7/28/2016 9:41 | 8/17/2016 | 47544 | LEAD | 5 PPB | 15 PPB |
| 11-08A Classroom 7 Sink Faucet | 7/28/2016 9:49 | 8/17/2016 | 47545 | LEAD | 5 PPB | 15 PPB |
| 11-09A Classroom 7 Drinking Fountain | 7/28/2016 9:49 | 8/17/2016 | 47546 | LEAD | 5 PPB | 15 PPB |
| 11-10A Classroom 1 Sink Faucet | 7/28/2016 9:54 | 8/17/2016 | 47547 | LEAD | 1 PPB | 15 PPB |
| 11-11A Classroom 1 Drinking Fountain | 7/28/2016 9:54 | 8/17/2016 | 47548 | LEAD | 11 PPB | 15 PPB |
| 11-12A Corridor 32A Drinking Fountain at Room 6 | 7/28/2016 9:57 | 8/17/2016 | 47549 | LEAD | 5 PPB | 15 PPB |
| 11-13A Classroom 2 Sink Faucet | 7/28/2016 10:02 | 8/17/2016 | 47550 | LEAD | 2 PPB | 15 PPB |
| 11-14A Classroom 2 Drinking Fountain | 7/28/2016 10:02 | 8/17/2016 | 47551 | LEAD | <1 PPB | 15 PPB |
| 11-15A Classroom 6 Sink Faucet | 7/28/2016 10:05 | 8/17/2016 | 47552 | LEAD | 3 PPB | 15 PPB |
| 11-16A Classroom 6 Drinking Fountain | 7/28/2016 10:05 | 8/17/2016 | 47553 | LEAD | 4 PPB | 15 PPB |
| 11-17A Classroom 5 Sink Faucet | 7/28/2016 10:09 | 8/17/2016 | 47554 | LEAD | 23 PPB | 15 PPB |
| 11-18A Classroom 5 Drinking Fountain | 7/28/2016 10:09 | 8/17/2016 | 47555 | LEAD | 16 PPB | 15 PPB |
| 11-19A Classroom 3 Sink Faucet | 7/28/2016 10:13 | 8/17/2016 | 47556 | LEAD | 2 PPB | 15 PPB |
| 11-20A Classroom 3 Drinking Fountain | 7/28/2016 10:13 | 8/17/2016 | 47557 | LEAD | 6 PPB | 15 PPB |
| 11-21A Classroom 4 Sink Faucet | 7/28/2016 10:17 | 8/17/2016 | 47558 | LEAD | 4 PPB | 15 PPB |
| 11-22A Classroom 4 Drinking Fountain | 7/28/2016 10:17 | 8/17/2016 | 47559 | LEAD | 3 PPB | 15 PPB |
| 11-23A Corridor 32C Drinking Fountain at Room 9 | 7/28/2016 10:23 | 8/17/2016 | 47560 | LEAD | 2 PPB | 15 PPB |
| 11-24A Staff Room Sink Faucet | 7/28/2016 12:26 | 8/17/2016 | 47561 | LEAD | 1 PPB | 15 PPB |
| 11-25A Staff Room Drinking Fountain | 7/28/2016 10:26 | 8/17/2016 | 47562 | LEAD | 9 PPB | 15 PPB |
| 11-26A Main Office Sink Faucet | 7/28/2016 10:32 | 8/17/2016 | 47563 | LEAD | <1 PPB | 15 PPB |
| 11-27A Main Office Drinking Fountain | 7/28/2016 10:32 | 8/17/2016 | 47564 | LEAD | 2 PPB | 15 PPB |
| 11-28A Classroom 18 Sink Faucet | 7/28/2016 10:39 | 8/17/2016 | 47565 | LEAD | 3 PPB | 15 PPB |
| 11-29A Corridor 49 Drinking Fountain | 7/28/2016 10:43 | 8/17/2016 | 47566 | LEAD | 3 PPB | 15 PPB |
| 11-30A Classroom 10 Sink Faucet | 7/28/2016 10:46 | 8/17/2016 | 47567 | LEAD | 2 PPB | 15 PPB |

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Cummings Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|---|-------------------|---------------|--------------|------------|---------|--------------|
| 11-31A Classroom 10 Drinking Fountain | 7/28/2016 10:46 | 8/17/2016 | 47568 | LEAD | 2 PPB | 15 PPB |
| 11-32A Classroom 11 Sink Faucet | 7/28/2016 10:49 | 8/17/2016 | 47569 | LEAD | 2 PPB | 15 PPB |
| 11-33A Classroom 11 Drinking Fountain | 7/28/2016 10:49 | 8/17/2016 | 47570 | LEAD | 1 PPB | 15 PPB |
| 11-34A Classroom 12 Sink Faucet | 7/28/2016 10:53 | 8/17/2016 | 47571 | LEAD | 3 PPB | 15 PPB |
| 11-35A Classroom 12 Drinking Fountain | 7/28/2016 10:53 | 8/17/2016 | 47572 | LEAD | 1 PPB | 15 PPB |
| 11-36A Classroom 17 Sink Faucet | 7/28/2016 10:57 | 8/17/2016 | 47573 | LEAD | 1 PPB | 15 PPB |
| 11-37A Classroom 17 Drinking Fountain | 7/28/2016 10:57 | 8/17/2016 | 47574 | LEAD | <1 PPB | 15 PPB |
| 11-38A Classroom 16 Sink Faucet | 7/28/2016 11:01 | 8/17/2016 | 47575 | LEAD | 2 PPB | 15 PPB |
| 11-39A Classroom 16 Drinking Fountain | 7/28/2016 11:01 | 8/17/2016 | 47576 | LEAD | 5 PPB | 15 PPB |
| 11-40A Classroom 13 Sink Faucet | 7/28/2016 11:05 | 8/17/2016 | 47577 | LEAD | 2 PPB | 15 PPB |
| 11-41A Classroom 13 Drinking Fountain | 7/28/2016 11:05 | 8/17/2016 | 47578 | LEAD | <1 PPB | 15 PPB |
| 11-42A Classroom 14 Sink Faucet | 7/28/2016 11:09 | 8/17/2016 | 47579 | LEAD | 7 PPB | 15 PPB |
| 11-43A Classroom 14 Drinking Fountain | 7/28/2016 11:09 | 8/17/2016 | 47580 | LEAD | 2 PPB | 15 PPB |
| 11-44A Classroom 15 Sink Faucet | 7/28/2016 11:12 | 8/17/2016 | 47581 | LEAD | 3 PPB | 15 PPB |
| 11-45A Classroom 15 Drinking Fountain | 7/28/2016 11:12 | 8/17/2016 | 47582 | LEAD | 3 PPB | 15 PPB |
| 11-46A Hall Outside M.P Room Drinking Fountain | 7/28/2016 11:15 | 8/17/2016 | 47583 | LEAD | <1 PPB | 15 PPB |
| 11-47A M.P Room by Door 1-C Drinking Fountain | 7/28/2016 11:22 | 8/17/2016 | 47584 | LEAD | 11 PPB | 15 PPB |
| 11-48A M.P Room Boys Restroom Utility Sink | 7/28/2016 11:24 | 8/17/2016 | 47585 | LEAD | 11 PPB | 15 PPB |
| 11-49A Kitchen Utility Sink | 7/28/2016 11:27 | 8/17/2016 | 47586 | LEAD | <1 PPB | 15 PPB |
| 11-50A Kitchen Small Sink with Eye Wash Station | 7/28/2016 11:27 | 8/17/2016 | 47587 | LEAD | <1 PPB | 15 PPB |
| 11-51A Drinking Fountain LRC | 7/28/2016 9:33 | 8/17/2016 | 47588 | LEAD | 2 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Cummings Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 11-17B Classroom 5 Sink Faucet | 7/28/2016 10:10 | 9/1/2016 | 52920 | LEAD | 6 PPB | 15 PPB |
| 11-18B Classroom 5 Drinking Fountain | 7/28/2016 10:11 | 9/1/2016 | 52921 | LEAD | 9 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level