

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Englewood Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
013-01A Room 4 Drinking Fountain	8/10/2016 3:11	8/23/2016	50012	LEAD	6 PPB	15 PPB
013-02A Room 4 Sink Faucet	8/10/2016 3:11	8/23/2016	50013	LEAD	1 PPB	15 PPB
013-03A Room 3 Drinking Fountain	8/10/2016 3:15	8/23/2016	50014	LEAD	<1 PPB	15 PPB
013-04A Room 3 Sink Faucet	8/10/2016 3:15	8/23/2016	50015	LEAD	<1 PPB	15 PPB
013-05A Room 1 Drinking Fountain	8/10/2016 3:18	8/23/2016	50016	LEAD	<1 PPB	15 PPB
013-06A Room 1 Sink Faucet	8/10/2016 3:18	8/23/2016	50017	LEAD	<1 PPB	15 PPB
013-07A Room 2 Drinking Fountain	8/10/2016 3:22	8/23/2016	50018	LEAD	1 PPB	15 PPB
013-08A Room 2 Sink Faucet	8/10/2016 3:22	8/23/2016	50019	LEAD	<1 PPB	15 PPB
013-09A Hallway Drinking Fountain 1	8/10/2016 3:25	8/23/2016	50020	LEAD	<1 PPB	15 PPB
013-10A Room 5 Drinking Fountain	8/10/2016 3:20	8/23/2016	50021	LEAD	<1 PPB	15 PPB
013-11A Room 5 Sink Faucet	8/10/2016 3:20	8/23/2016	50022	LEAD	<1 PPB	15 PPB
013-12A Room 6 Sink Faucet	8/10/2016 3:25	8/23/2016	50023	LEAD	<1 PPB	15 PPB
013-13A Multi-Purpose Room Drinking Faucet	8/10/2016 3:14	8/23/2016	50024	LEAD	<1 PPB	15 PPB
013-14A Kitchen Sink Faucet	8/10/2016 3:16	8/23/2016	50025	LEAD	2 PPB	15 PPB
013-15A Kitchen Sink Faucet	8/10/2016 3:16	8/23/2016	50026	LEAD	2 PPB	15 PPB
013-16A A.V. Room Sink Faucet	8/10/2016 3:33	8/23/2016	50027	LEAD	<1 PPB	15 PPB
013-17A Hallway Drinking Fountain 2	8/10/2016 3:35	8/23/2016	50028	LEAD	2 PPB	15 PPB
013-18A Office Drinking Fountain	8/10/2016 3:37	8/23/2016	50029	LEAD	<1 PPB	15 PPB
013-19A Office Sink Faucet	8/10/2016 3:37	8/23/2016	50030	LEAD	2 PPB	15 PPB
013-20A Room 12 Drinking Fountain	8/10/2016 3:41	8/23/2016	50031	LEAD	<1 PPB	15 PPB
013-21A Room 12 Sink Faucet	8/10/2016 3:41	8/23/2016	50032	LEAD	<1 PPB	15 PPB
013-22A C.D.S. Room Sink Faucet	8/10/2016 3:33	8/23/2016	50033	LEAD	<1 PPB	15 PPB
013-23A Staff Breakroom Sink Faucet	8/10/2016 3:43	8/23/2016	50034	LEAD	<1 PPB	15 PPB
013-24A Room 10 Drinking Fountain	8/10/2016 3:41	8/23/2016	50035	LEAD	<1 PPB	15 PPB
013-25A Room 10 Sink Faucet	8/10/2016 3:41	8/23/2016	50036	LEAD	1 PPB	15 PPB
013-26A Office Sink Faucet	8/10/2016 3:36	8/23/2016	50037	LEAD	<1 PPB	15 PPB
013-27A Office Drinking Fountain	8/10/2016 3:36	8/23/2016	50038	LEAD	<1 PPB	15 PPB
013-28A Hallway Drinking Fountain 3	8/10/2016 3:45	8/23/2016	50039	LEAD	3 PPB	15 PPB
013-29A Room 8 Drinking Fountain	8/10/2016 3:50	8/23/2016	50040	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Englewood Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
013-30A Room 8 Sink Faucet	8/10/2016 3:50	8/23/2016	50041	LEAD	1 PPB	15 PPB
013-31A Room 7 Drinking Fountain	8/10/2016 3:50	8/23/2016	50042	LEAD	<1 PPB	15 PPB
013-32A Room 7 Sink Faucet	8/10/2016 3:50	8/23/2016	50043	LEAD	4 PPB	15 PPB
013-33A Room 14 Drinking Fountain	8/10/2016 3:56	8/23/2016	50044	LEAD	1 PPB	15 PPB
013-34A Room 14 Sink Faucet	8/10/2016 3:56	8/23/2016	50045	LEAD	3 PPB	15 PPB
013-35A Room 15 Drinking Fountain	8/10/2016 3:59	8/23/2016	50046	LEAD	<1 PPB	15 PPB
013-36A Room 15 Sink Faucet	8/10/2016 3:59	8/23/2016	50047	LEAD	<1 PPB	15 PPB
013-37A Hallway Drinking Fountain 4	8/10/2016 4:01	8/23/2016	50048	LEAD	2 PPB	15 PPB
013-38A Room 17 Drinking Fountain	8/10/2016 4:04	8/23/2016	50049	LEAD	1 PPB	15 PPB
013-39A Room 17 Sink Faucet	8/10/2016 4:04	8/23/2016	50050	LEAD	1 PPB	15 PPB
013-40A Room 16 Drinking Fountain	8/10/2016 4:07	8/23/2016	50051	LEAD	<1 PPB	15 PPB
013-41A Room 16 Sink Faucet	8/10/2016 4:07	8/23/2016	50052	LEAD	<1 PPB	15 PPB
013-42A Speech Room Drinking Fountain	8/10/2016 4:10	8/23/2016	50053	LEAD	<1 PPB	15 PPB
013-43A Speech Room Sink Faucet	8/10/2016 4:10	8/23/2016	50054	LEAD	<1 PPB	15 PPB
013-44A Room 18 Drinking Fountain	8/10/2016 4:01	8/23/2016	50055	LEAD	<1 PPB	15 PPB
013-45A Room 18 Sink Faucet	8/10/2016 4:01	8/23/2016	50056	LEAD	<1 PPB	15 PPB
013-46A Room 19 Drinking Fountain	8/10/2016 4:05	8/23/2016	50057	LEAD	<1 PPB	15 PPB
013-47A Room 19 Sink Faucet	8/10/2016 4:05	8/23/2016	50058	LEAD	3 PPB	15 PPB
013-48A Hallway Drinking Fountain 5	8/10/2016 3:58	8/23/2016	50059	LEAD	2 PPB	15 PPB
013-49A Room 20 Sink Faucet	8/10/2016 3:57	8/23/2016	50060	LEAD	<1 PPB	15 PPB
013-50A Gymnasium Drinking Fountain	8/10/2016 4:19	8/23/2016	50061	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level