

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-01A Gymnasium Drinking Fountain	7/26/2016 11:25	8/5/2016	44396	COPPER	0.4 PPM	1.3 PPM
14-02A Gymnasium Vestibule Drinking Fountain	7/26/2016 11:27	8/5/2016	44397	COPPER	0.3 PPM	1.3 PPM
14-03A Room 136 staff lounge Sink Faucet	7/26/2016 11:29	8/5/2016	44398	COPPER	0.4 PPM	1.3 PPM
14-04A Cafeteria/room 135 Sink Faucet	7/26/2016 11:30	8/5/2016	44399	COPPER	0.8 PPM	1.3 PPM
14-05A Cafeteria/room 135 Drinking Fountain	7/26/2016 11:33	8/5/2016	44400	COPPER	0.5 PPM	1.3 PPM
14-06A Kitchen Sink Faucet	7/26/2016 11:35	8/5/2016	44401	COPPER	0.5 PPM	1.3 PPM
14-07A Room 134 Sink Faucet	7/26/2016 11:37	8/5/2016	44402	COPPER	0.4 PPM	1.3 PPM
14-09A LRC Room 132 Sink Faucet (left)	7/26/2016 11:43	8/5/2016	44403	COPPER	0.9 PPM	1.3 PPM
14-10A LRC Room 132 Sink Faucet (right)	7/26/2016 11:45	8/5/2016	44404	COPPER	0.6 PPM	1.3 PPM
14-11A LRC Room 132 Drinking Fountain	7/26/2016 11:47	8/5/2016	44405	COPPER	0.4 PPM	1.3 PPM
14-12A C-6 Sink Faucet	7/26/2016 11:50	8/5/2016	44406	COPPER	0.8 PPM	1.3 PPM
14-13A C-6 Drinking Fountain	7/26/2016 11:52	8/5/2016	44407	COPPER	0.4 PPM	1.3 PPM
14-14A C-5 Sink Faucet	7/26/2016 11:54	8/5/2016	44408	COPPER	0.5 PPM	1.3 PPM
14-15A C-5 Drinking Fountain	7/26/2016 11:56	8/5/2016	44409	COPPER	0.5 PPM	1.3 PPM
14-16A C-4 Sink Faucet	7/26/2016 11:58	8/5/2016	44410	COPPER	0.7 PPM	1.3 PPM
14-17A C-4 Drinking Fountain	7/26/2016 12:00	8/5/2016	44411	COPPER	0.6 PPM	1.3 PPM
14-18A C-3 Sink Faucet	7/26/2016 12:02	8/5/2016	44412	COPPER	0.7 PPM	1.3 PPM
14-19A C-3 Drinking Fountain	7/26/2016 12:04	8/5/2016	44413	COPPER	0.5 PPM	1.3 PPM
14-20A C-2 Sink Faucet	7/26/2016 12:06	8/11/2016	44414	COPPER	1.5 PPM	1.3 PPM
14-21A C-2 Drinking Fountain	7/26/2016 12:08	8/5/2016	44415	COPPER	0.5 PPM	1.3 PPM
14-22A C-1 Sink Faucet	7/26/2016 12:10	8/5/2016	44416	COPPER	0.4 PPM	1.3 PPM
14-23A C-1 Drinking Fountain	7/26/2016 12:12	8/5/2016	44417	COPPER	0.6 PPM	1.3 PPM
14-24A B-6 Sink Faucet	7/26/2016 12:14	8/5/2016	44418	COPPER	0.5 PPM	1.3 PPM
14-25A B-6 Drinking Fountain	7/26/2016 12:16	8/5/2016	44419	COPPER	0.7 PPM	1.3 PPM
14-26A B-5 Sink Faucet	7/26/2016 12:18	8/5/2016	44420	COPPER	0.4 PPM	1.3 PPM
14-27A B-5 Drinking Fountain	7/26/2016 12:20	8/5/2016	44421	COPPER	0.6 PPM	1.3 PPM
14-28A B-4 Sink Faucet	7/26/2016 12:22	8/5/2016	44422	COPPER	0.5 PPM	1.3 PPM
14-29A B-4 Drinking Fountain	7/26/2016 12:24	8/5/2016	44423	COPPER	0.6 PPM	1.3 PPM
14-30A B-3 Sink Faucet	7/26/2016 12:26	8/5/2016	44424	COPPER	0.8 PPM	1.3 PPM
14-31A B-3 Drinking Fountain	7/26/2016 12:28	8/5/2016	44425	COPPER	0.5 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-32A B-2 Sink Faucet	7/26/2016 12:30	8/5/2016	44426	COPPER	0.5 PPM	1.3 PPM
14-33A B-2 Drinking Fountain	7/26/2016 12:32	8/5/2016	44427	COPPER	0.4 PPM	1.3 PPM
14-34A B-1 Sink Faucet	7/26/2016 12:34	8/5/2016	44428	COPPER	0.4 PPM	1.3 PPM
14-35A B-1 Drinking Fountain	7/26/2016 12:36	8/5/2016	44429	COPPER	0.5 PPM	1.3 PPM
14-36A Computer Lab Sink Faucet	7/26/2016 12:38	8/5/2016	44430	COPPER	0.4 PPM	1.3 PPM
14-37A Computer Lab Drinking Fountain	7/26/2016 12:40	8/5/2016	44431	COPPER	0.5 PPM	1.3 PPM
14-38A Library Storage Sink Faucet	7/26/2016 12:42	8/5/2016	44432	COPPER	0.1 PPM	1.3 PPM
14-39A Health Room Sink Faucet	7/26/2016 12:44	8/5/2016	44433	COPPER	0.5 PPM	1.3 PPM
14-40A A- Pod Girls Restroom Drinking Fountain	7/26/2016 12:46	8/5/2016	44434	COPPER	0.1 PPM	1.3 PPM
14-41A A-6 Sink Faucet	7/26/2016 12:48	8/5/2016	44435	COPPER	0.4 PPM	1.3 PPM
14-42A A-6 Drinking Fountain	7/26/2016 12:50	8/5/2016	44436	COPPER	0.5 PPM	1.3 PPM
14-43A A-6 Sink Faucet	7/26/2016 12:52	8/5/2016	44437	COPPER	0.6 PPM	1.3 PPM
14-44A A-5 Sink Faucet	7/26/2016 12:54	8/5/2016	44438	COPPER	0.5 PPM	1.3 PPM
14-45A A-5 Sink Faucet	7/26/2016 12:56	8/5/2016	44439	COPPER	0.4 PPM	1.3 PPM
14-46A A-5 Drinking Fountain	7/26/2016 12:58	8/5/2016	44440	COPPER	0.6 PPM	1.3 PPM
14-47A A-4 Sink Faucet	7/26/2016 13:00	8/5/2016	44441	COPPER	0.5 PPM	1.3 PPM
14-48A A-4 Drinking Fountain	7/26/2016 13:02	8/5/2016	44442	COPPER	0.5 PPM	1.3 PPM
14-49A A-3 Sink Faucet	7/26/2016 13:04	8/5/2016	44443	COPPER	0.5 PPM	1.3 PPM
14-50A A-3 Drinking Fountain	7/26/2016 13:06	8/5/2016	44444	COPPER	0.5 PPM	1.3 PPM
14-51A A-2 Sink Faucet	7/26/2016 13:08	8/5/2016	44445	COPPER	0.2 PPM	1.3 PPM
14-52A A-2 Drinking Fountain	7/26/2016 13:10	8/5/2016	44446	COPPER	0.2 PPM	1.3 PPM
14-53A A-1 Sink Faucet	7/26/2016 13:12	8/5/2016	44447	COPPER	0.2 PPM	1.3 PPM
14-54A A-1 Drinking Fountain	7/26/2016 12:14	8/5/2016	44448	COPPER	0.5 PPM	1.3 PPM
14-55A A-Pod Boys Restroom Drinking Fountain	7/26/2016 13:16	8/5/2016	44449	COPPER	0.1 PPM	1.3 PPM
14-56A Room 157 Sink Faucet	7/26/2016 13:18	8/5/2016	44450	COPPER	0.3 PPM	1.3 PPM
14-57A D-7 Sink Faucet	7/26/2016 13:25	8/5/2016	44451	COPPER	0.4 PPM	1.3 PPM
14-58A D-7 Drinking Fountain	7/26/2016 13:27	8/5/2016	44452	COPPER	0.1 PPM	1.3 PPM
14-59A D-8 Sink Faucet	7/26/2016 13:29	8/5/2016	44453	COPPER	0.2 PPM	1.3 PPM
14-60A D-8 Drinking Fountain	7/26/2016 13:31	8/5/2016	44454	COPPER	0.0 PPM	1.3 PPM
14-61A D-1 Sink Faucet	7/26/2016 13:33	8/5/2016	44455	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools
 Copper Water Sampling Results
 First Draw (A) Sample Data
 Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-62A D-1 Drinking Fountain	7/26/2016 13:35	8/5/2016	44456	COPPER	0.1 PPM	1.3 PPM
14-63A D-2 Sink Faucet	7/26/2016 13:37	8/5/2016	44457	COPPER	0.2 PPM	1.3 PPM
14-64A D-2 Drinking Fountain	7/26/2016 13:39	8/5/2016	44458	COPPER	0.1 PPM	1.3 PPM
14-65A D-3 Sink Faucet	7/26/2016 13:41	8/5/2016	44459	COPPER	0.3 PPM	1.3 PPM
14-66A D-3 Drinking Fountain	7/26/2016 13:43	8/5/2016	44460	COPPER	0.1 PPM	1.3 PPM
14-67A D-4 Sink Faucet	7/26/2016 13:45	8/5/2016	44461	COPPER	0.3 PPM	1.3 PPM
14-68A D-4 Drinking Fountain	7/26/2016 13:47	8/5/2016	44462	COPPER	0.1 PPM	1.3 PPM
14-69A Hall B/C Pod Drinking Fountain	7/26/2016 13:20	8/5/2016	44463	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-08A Media Center Drinking Fountain	9/30/2016 6:41	10/3/2016	59712	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-20B C-2 Sink Faucet	7/26/2016 12:07	9/1/2016	52934	COPPER	0.6 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level