

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-01A Gymnasium Drinking Fountain	7/26/2016 11:25	8/5/2016	44396	LEAD	<1 PPB	15 PPB
14-02A Gymnasium Vestibule Drinking Fountain	7/26/2016 11:27	8/5/2016	44397	LEAD	2 PPB	15 PPB
14-03A Room 136 staff lounge Sink Faucet	7/26/2016 11:29	8/5/2016	44398	LEAD	7 PPB	15 PPB
14-04A Cafeteria/room 135 Sink Faucet	7/26/2016 11:30	8/5/2016	44399	LEAD	5 PPB	15 PPB
14-05A Cafeteria/room 135 Drinking Fountain	7/26/2016 11:33	8/5/2016	44400	LEAD	2 PPB	15 PPB
14-06A Kitchen Sink Faucet	7/26/2016 11:35	8/5/2016	44401	LEAD	3 PPB	15 PPB
14-07A Room 134 Sink Faucet	7/26/2016 11:37	8/5/2016	44402	LEAD	18 PPB	15 PPB
14-09A LRC Room 132 Sink Faucet (left)	7/26/2016 11:43	8/5/2016	44403	LEAD	24 PPB	15 PPB
14-10A LRC Room 132 Sink Faucet (right)	7/26/2016 11:45	8/5/2016	44404	LEAD	17 PPB	15 PPB
14-11A LRC Room 132 Drinking Fountain	7/26/2016 11:47	8/5/2016	44405	LEAD	3 PPB	15 PPB
14-12A C-6 Sink Faucet	7/26/2016 11:50	8/5/2016	44406	LEAD	17 PPB	15 PPB
14-13A C-6 Drinking Fountain	7/26/2016 11:52	8/5/2016	44407	LEAD	1 PPB	15 PPB
14-14A C-5 Sink Faucet	7/26/2016 11:54	8/5/2016	44408	LEAD	11 PPB	15 PPB
14-15A C-5 Drinking Fountain	7/26/2016 11:56	8/5/2016	44409	LEAD	8 PPB	15 PPB
14-16A C-4 Sink Faucet	7/26/2016 11:58	8/5/2016	44410	LEAD	15 PPB	15 PPB
14-17A C-4 Drinking Fountain	7/26/2016 12:00	8/5/2016	44411	LEAD	2 PPB	15 PPB
14-18A C-3 Sink Faucet	7/26/2016 12:02	8/5/2016	44412	LEAD	5 PPB	15 PPB
14-19A C-3 Drinking Fountain	7/26/2016 12:04	8/5/2016	44413	LEAD	2 PPB	15 PPB
14-20A C-2 Sink Faucet	7/26/2016 12:06	8/11/2016	44414	LEAD	32 PPB	15 PPB
14-21A C-2 Drinking Fountain	7/26/2016 12:08	8/5/2016	44415	LEAD	3 PPB	15 PPB
14-22A C-1 Sink Faucet	7/26/2016 12:10	8/5/2016	44416	LEAD	5 PPB	15 PPB
14-23A C-1 Drinking Fountain	7/26/2016 12:12	8/5/2016	44417	LEAD	1 PPB	15 PPB
14-24A B-6 Sink Faucet	7/26/2016 12:14	8/5/2016	44418	LEAD	3 PPB	15 PPB
14-25A B-6 Drinking Fountain	7/26/2016 12:16	8/5/2016	44419	LEAD	2 PPB	15 PPB
14-26A B-5 Sink Faucet	7/26/2016 12:18	8/5/2016	44420	LEAD	3 PPB	15 PPB
14-27A B-5 Drinking Fountain	7/26/2016 12:20	8/5/2016	44421	LEAD	4 PPB	15 PPB
14-28A B-4 Sink Faucet	7/26/2016 12:22	8/5/2016	44422	LEAD	4 PPB	15 PPB
14-29A B-4 Drinking Fountain	7/26/2016 12:24	8/5/2016	44423	LEAD	3 PPB	15 PPB
14-30A B-3 Sink Faucet	7/26/2016 12:26	8/5/2016	44424	LEAD	9 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-31A B-3 Drinking Fountain	7/26/2016 12:28	8/5/2016	44425	LEAD	4 PPB	15 PPB
14-32A B-2 Sink Faucet	7/26/2016 12:30	8/5/2016	44426	LEAD	9 PPB	15 PPB
14-33A B-2 Drinking Fountain	7/26/2016 12:32	8/5/2016	44427	LEAD	4 PPB	15 PPB
14-34A B-1 Sink Faucet	7/26/2016 12:34	8/5/2016	44428	LEAD	16 PPB	15 PPB
14-35A B-1 Drinking Fountain	7/26/2016 12:36	8/5/2016	44429	LEAD	2 PPB	15 PPB
14-36A Computer Lab Sink Faucet	7/26/2016 12:38	8/5/2016	44430	LEAD	12 PPB	15 PPB
14-37A Computer Lab Drinking Fountain	7/26/2016 12:40	8/5/2016	44431	LEAD	7 PPB	15 PPB
14-38A Library Storage Sink Faucet	7/26/2016 12:42	8/5/2016	44432	LEAD	14 PPB	15 PPB
14-39A Health Room Sink Faucet	7/26/2016 12:44	8/5/2016	44433	LEAD	3 PPB	15 PPB
14-40A A- Pod Girls Restroom Drinking Fountain	7/26/2016 12:46	8/5/2016	44434	LEAD	3 PPB	15 PPB
14-41A A-6 Sink Faucet	7/26/2016 12:48	8/5/2016	44435	LEAD	10 PPB	15 PPB
14-42A A-6 Drinking Fountain	7/26/2016 12:50	8/5/2016	44436	LEAD	2 PPB	15 PPB
14-43A A-6 Sink Faucet	7/26/2016 12:52	8/5/2016	44437	LEAD	8 PPB	15 PPB
14-44A A-5 Sink Faucet	7/26/2016 12:54	8/5/2016	44438	LEAD	10 PPB	15 PPB
14-45A A-5 Sink Faucet	7/26/2016 12:56	8/5/2016	44439	LEAD	3 PPB	15 PPB
14-46A A-5 Drinking Fountain	7/26/2016 12:58	8/5/2016	44440	LEAD	5 PPB	15 PPB
14-47A A-4 Sink Faucet	7/26/2016 13:00	8/5/2016	44441	LEAD	10 PPB	15 PPB
14-48A A-4 Drinking Fountain	7/26/2016 13:02	8/5/2016	44442	LEAD	<1 PPB	15 PPB
14-49A A-3 Sink Faucet	7/26/2016 13:04	8/5/2016	44443	LEAD	9 PPB	15 PPB
14-50A A-3 Drinking Fountain	7/26/2016 13:06	8/5/2016	44444	LEAD	2 PPB	15 PPB
14-51A A-2 Sink Faucet	7/26/2016 13:08	8/5/2016	44445	LEAD	3 PPB	15 PPB
14-52A A-2 Drinking Fountain	7/26/2016 13:10	8/5/2016	44446	LEAD	1 PPB	15 PPB
14-53A A-1 Sink Faucet	7/26/2016 13:12	8/5/2016	44447	LEAD	2 PPB	15 PPB
14-54A A-1 Drinking Fountain	7/26/2016 12:14	8/5/2016	44448	LEAD	4 PPB	15 PPB
14-55A A-Pod Boys Restroom Drinking Fountain	7/26/2016 13:16	8/5/2016	44449	LEAD	3 PPB	15 PPB
14-56A Room 157 Sink Faucet	7/26/2016 13:18	8/5/2016	44450	LEAD	8 PPB	15 PPB
14-57A D-7 Sink Faucet	7/26/2016 13:25	8/5/2016	44451	LEAD	12 PPB	15 PPB
14-58A D-7 Drinking Fountain	7/26/2016 13:27	8/5/2016	44452	LEAD	2 PPB	15 PPB
14-59A D-8 Sink Faucet	7/26/2016 13:29	8/5/2016	44453	LEAD	8 PPB	15 PPB

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (A) Sample Data  
 Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-60A D-8 Drinking Fountain	7/26/2016 13:31	8/5/2016	44454	LEAD	2 PPB	15 PPB
14-61A D-1 Sink Faucet	7/26/2016 13:33	8/5/2016	44455	LEAD	2 PPB	15 PPB
14-62A D-1 Drinking Fountain	7/26/2016 13:35	8/5/2016	44456	LEAD	<1 PPB	15 PPB
14-63A D-2 Sink Faucet	7/26/2016 13:37	8/5/2016	44457	LEAD	1 PPB	15 PPB
14-64A D-2 Drinking Fountain	7/26/2016 13:39	8/5/2016	44458	LEAD	<1 PPB	15 PPB
14-65A D-3 Sink Faucet	7/26/2016 13:41	8/5/2016	44459	LEAD	1 PPB	15 PPB
14-66A D-3 Drinking Fountain	7/26/2016 13:43	8/5/2016	44460	LEAD	<1 PPB	15 PPB
14-67A D-4 Sink Faucet	7/26/2016 13:45	8/5/2016	44461	LEAD	3 PPB	15 PPB
14-68A D-4 Drinking Fountain	7/26/2016 13:47	8/5/2016	44462	LEAD	<1 PPB	15 PPB
14-69A Hall B/C Pod Drinking Fountain	7/26/2016 13:20	8/5/2016	44463	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-08A Media Center Drinking Fountain	9/30/2016 6:41	10/3/2016	59712	LEAD	18 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 Flushed (B) Sample Data  
 Eyre Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
14-07B Room 134 Sink Faucet	7/26/2016 11:38	9/1/2016	52929	LEAD	6 PPB	15 PPB
14-09B LRC Room 132 Sink Faucet (left)	7/26/2016 11:44	9/1/2016	52930	LEAD	2 PPB	15 PPB
14-10B LRC Room 132 Sink Faucet (right)	7/26/2016 11:46	9/1/2016	52931	LEAD	3 PPB	15 PPB
14-12B C-6 Sink Faucet	7/26/2016 11:51	9/1/2016	52932	LEAD	1 PPB	15 PPB
14-16B C-4 Sink Faucet	7/26/2016 11:59	9/1/2016	52933	LEAD	1 PPB	15 PPB
14-20B C-2 Sink Faucet	7/26/2016 12:07	9/1/2016	52934	LEAD	2 PPB	15 PPB
14-34B B-1 Sink Faucet	7/26/2016 12:35	9/1/2016	52935	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**