

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Forest Ridge Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Level
15-01A Gymnasium Drinking Fountain	8/3/16 3:07	8/11/16 11:30	608040001	LEAD	< 1 PPB	15 PPB
15-02A Multi Purpose Room Sink Faucet	8/3/16 3:09	8/11/16 11:30	608040002	LEAD	< 1 PPB	15 PPB
15-03A Multi Purpose Ice Maker	8/3/16 3:10	8/11/16 11:30	608040003	LEAD	1 PPB	15 PPB
15-04A Kitchen Sink Faucet	8/3/16 3:12	8/11/16 11:31	608040004	LEAD	3 PPB	15 PPB
15-05A Music Room Drinking Fountain	8/3/16 3:16	8/11/16 11:31	608040005	LEAD	< 1 PPB	15 PPB
15-06A Music Room Sink Faucet	8/3/16 3:16	8/11/16 11:31	608040006	LEAD	< 1 PPB	15 PPB
15-07A Office Copy Room Drinking Fountain	8/3/16 3:19	8/11/16 11:31	608040007	LEAD	5 PPB	15 PPB
15-08A Office Copy Room Sink Faucet	8/3/16 3:19	8/11/16 11:31	608040008	LEAD	2 PPB	15 PPB
15-09A Office Break Room Sink Faucet	8/3/16 3:22	8/11/16 11:31	608040009	LEAD	< 1 PPB	15 PPB
15-10A Health Room Drinking Fountain	8/3/16 3:25	8/11/16 11:31	608040010	LEAD	1 PPB	15 PPB
15-11A Health Room Sink Faucet	8/3/16 3:25	8/11/16 11:31	608040011	LEAD	< 1 PPB	15 PPB
15-12A Health Room Ice Maker	8/3/16 4:35	8/11/16 11:31	608040012	LEAD	3 PPB	15 PPB
15-13A Office Break Room Ice Maker	8/3/16 4:35	8/16/16 12:41	608040013	LEAD	2 PPB	15 PPB
15-14A B1 Drinking Fountain	8/3/16 3:29	8/10/16 17:36	608040014	LEAD	2 PPB	15 PPB
15-15A B1 Sink Faucet	8/3/16 3:29	8/10/16 17:36	608040015	LEAD	1 PPB	15 PPB
15-16A B2 Drinking Fountain	8/3/16 3:32	8/10/16 17:36	608040016	LEAD	3 PPB	15 PPB
15-17A B2 Sink Faucet	8/3/16 3:32	8/10/16 17:36	608040017	LEAD	1 PPB	15 PPB
15-18A B3 Drinking Fountain	8/3/16 3:35	8/10/16 17:36	608040018	LEAD	2 PPB	15 PPB
15-19A B3 Sink Faucet	8/3/16 3:35	8/10/16 17:36	608040019	LEAD	1 PPB	15 PPB
15-20A B4 Drinking Fountain	8/3/16 3:37	8/10/16 17:36	608040020	LEAD	< 1 PPB	15 PPB
15-21A B4 Sink Faucet	8/3/16 3:37	8/10/16 17:36	608040021	LEAD	< 1 PPB	15 PPB
15-22A B5 Drinking Fountain	8/3/16 3:39	8/10/16 17:36	608040022	LEAD	1 PPB	15 PPB
15-23A B5 Sink Faucet	8/3/16 3:39	8/10/16 17:36	608040023	LEAD	< 1 PPB	15 PPB
15-24A B6 Drinking Fountain	8/3/16 3:41	8/10/16 17:37	608040024	LEAD	< 1 PPB	15 PPB
15-25A B6 Sink Faucet	8/3/16 3:41	8/10/16 17:37	608040025	LEAD	< 1 PPB	15 PPB
15-26A C1 Drinking Fountain	8/3/16 3:46	8/10/16 17:37	608040026	LEAD	< 1 PPB	15 PPB
15-27A C1 Sink Faucet	8/3/16 3:46	8/10/16 17:37	608040027	LEAD	2 PPB	15 PPB
15-28A C2 Drinking Fountain	8/3/16 3:48	8/10/16 17:37	608040028	LEAD	7 PPB	15 PPB
15-29A C2 Sink Faucet	8/3/16 3:48	8/10/16 17:37	608040029	LEAD	2 PPB	15 PPB
15-30A C3 Drinking Fountain	8/3/16 3:50	8/10/16 17:37	608040030	LEAD	< 1 PPB	15 PPB
15-31A C3 Sink Faucet	8/3/16 3:50	8/10/16 17:37	608040031	LEAD	2 PPB	15 PPB
15-32A C4 Drinking Fountain	8/3/16 3:53	8/10/16 17:37	608040032	LEAD	1 PPB	15 PPB
15-33A C4 Sink Faucet	8/3/16 3:53	8/10/16 17:37	608040033	LEAD	< 1 PPB	15 PPB
15-34A C5 Drinking Fountain	8/3/16 3:55	8/10/16 17:37	608040034	LEAD	2 PPB	15 PPB
15-35A C5 Sink Faucet	8/3/16 3:55	8/10/16 17:37	608040035	LEAD	< 1 PPB	15 PPB
15-36A C6 Drinking Fountain	8/3/16 3:59	8/10/16 17:37	608040036	LEAD	< 1 PPB	15 PPB
15-37A C6 Sink Faucet	8/3/16 3:57	8/10/16 17:37	608040037	LEAD	< 1 PPB	15 PPB
15-38A Media Center Sink Faucet	8/3/16 4:00	8/10/16 17:38	608040038	LEAD	< 1 PPB	15 PPB
15-39A A1 Drinking Fountain	8/3/16 4:06	8/10/16 17:38	608040039	LEAD	1 PPB	15 PPB
15-40A A1 Sink Faucet	8/3/16 4:06	8/10/16 17:38	608040040	LEAD	< 1 PPB	15 PPB
15-41A A2 Drinking Fountain	8/3/16 4:08	8/10/16 17:38	608040041	LEAD	< 1 PPB	15 PPB
15-42A A2 Sink Faucet	8/3/16 4:08	8/10/16 17:38	608040042	LEAD	< 1 PPB	15 PPB
15-43A A3 Drinking Fountain	8/3/16 4:12	8/10/16 17:38	608040043	LEAD	1 PPB	15 PPB
15-44A A3 Sink Faucet	8/3/16 4:12	8/10/16 17:39	608040044	LEAD	< 1 PPB	15 PPB
15-45A A4 Drinking Fountain	8/3/16 4:15	8/10/16 17:39	608040045	LEAD	3 PPB	15 PPB
15-46A A4 Sink Faucet	8/3/16 4:14	8/10/16 17:39	608040046	LEAD	< 1 PPB	15 PPB
15-47A A5 Drinking Fountain	8/3/16 4:17	8/10/16 17:39	608040047	LEAD	1 PPB	15 PPB
15-48A A5 Sink Faucet	8/3/16 4:17	8/10/16 17:39	608040048	LEAD	< 1 PPB	15 PPB
15-49A A6 Drinking Fountain	8/3/16 4:19	8/10/16 17:39	608040049	LEAD	19 PPB	15 PPB
15-50A A6 Sink Faucet	8/3/16 4:19	8/10/16 17:39	608040050	LEAD	< 1 PPB	15 PPB
15-51A A7 Drinking Fountain	8/3/16 4:22	8/10/16 17:39	608040051	LEAD	< 1 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Forest Ridge Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Level
15-52A A7 Sink Faucet	8/3/16 4:22	8/10/16 17:39	608040052	LEAD	1 PPB	15 PPB
15-53A Drinking Fountain by Cafe Boys Restroom	8/3/16 4:27	8/10/16 17:39	608040053	LEAD	< 1 PPB	15 PPB
15-54A Drinking Fountain by Cafe Girls Restroom	8/3/16 4:27	8/10/16 16:49	608040054	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Forest Ridge Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Level
15-49B A6 Drinking Fountain	8/3/16 4:20	8/25/16 11:18	608230401	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level