

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Fruitland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
068-01A Classroom 3 Sink Faucet	7/21/2016 10:30	7/28/2016	43566	COPPER	0.1 PPM	1.3 PPM
068-02A Classroom 4 Sink Faucet	7/21/2016 10:32	7/28/2016	43567	COPPER	0.1 PPM	1.3 PPM
068-03A Classroom 2 Sink Faucet	7/21/2016 10:35	7/28/2016	43568	COPPER	0.0 PPM	1.3 PPM
068-04A Classroom 2 Drinking Fountain	7/21/2016 10:37	7/28/2016	43569	COPPER	<0.005 PPM	1.3 PPM
068-05A Classroom 1 Sink Faucet	7/21/2016 10:40	7/28/2016	43570	COPPER	0.0 PPM	1.3 PPM
068-06A Hallway Drinking Fountain 1	7/21/2016 10:42	7/28/2016	43571	COPPER	<0.005 PPM	1.3 PPM
068-07A Hallway Drinking Fountain 2	7/21/2016 10:44	7/28/2016	43572	COPPER	<0.005 PPM	1.3 PPM
068-08A Staff Kitchen/Break Sink Faucet	7/21/2016 10:47	7/28/2016	43573	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**