

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Gubser Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
021-01A Gymnasium Drinking Fountain	7/21/16 6:47	7/29/16 10:16	607250001	COPPER	0.0 PPM	1.3 PPM
021-02A Hallway Drinking Fountain 1	7/21/16 6:51	7/29/16 10:17	607250002	COPPER	0.1 PPM	1.3 PPM
021-03A Cafeteria Sink Faucet	7/21/16 6:54	7/29/16 10:17	607250003	COPPER	0.0 PPM	1.3 PPM
021-04A Cafeteria Drinking Fountain	7/21/16 6:56	7/29/16 10:17	607250004	COPPER	0.0 PPM	1.3 PPM
021-05A Community Room Sink Faucet	7/21/16 6:59	7/29/16 10:17	607250005	COPPER	0.1 PPM	1.3 PPM
021-06A Hallway Drinking Fountain 2	7/21/16 7:02	7/29/16 10:17	607250006	COPPER	0.0 PPM	1.3 PPM
021-07A Kitchen Food Prep Sink Faucet	7/21/16 7:05	7/29/16 10:17	607250007	COPPER	0.0 PPM	1.3 PPM
021-08A Music Room Sink Faucet	7/21/16 7:09	7/29/16 10:17	607250008	COPPER	0.1 PPM	1.3 PPM
021-09A Music Room Drinking Fountain	7/21/16 7:11	7/29/16 10:17	607250009	COPPER	0.1 PPM	1.3 PPM
021-10A LRC 120 Sink Faucet	7/21/16 7:19	7/29/16 11:49	607250010	COPPER	0.0 PPM	1.3 PPM
021-11A Boys Bathroom Drinking Fountain	7/21/16 7:22	7/29/16 10:29	607250011	COPPER	0.0 PPM	1.3 PPM
021-12A Classroom A1 Sink Faucet	7/21/16 7:25	7/29/16 10:29	607250012	COPPER	0.1 PPM	1.3 PPM
021-13A Classroom A1 Drinking Fountain	7/21/16 7:27	7/29/16 10:29	607250013	COPPER	0.0 PPM	1.3 PPM
021-14A Classroom A2 Sink Faucet	7/21/16 7:30	7/29/16 10:29	607250014	COPPER	0.4 PPM	1.3 PPM
021-15A Classroom A2 Drinking Fountain	7/21/16 7:32	7/29/16 10:29	607250015	COPPER	0.0 PPM	1.3 PPM
021-16A Classroom A3 Sink Faucet	7/21/16 7:35	7/29/16 10:29	607250016	COPPER	0.2 PPM	1.3 PPM
021-17A Classroom A3 Drinking Fountain	7/21/16 7:38	7/29/16 10:29	607250017	COPPER	0.0 PPM	1.3 PPM
021-18A Classroom A4 Sink Faucet	7/21/16 7:41	7/29/16 10:29	607250018	COPPER	0.1 PPM	1.3 PPM
021-19A Classroom A4 Drinking Fountain	7/21/16 7:43	7/29/16 10:29	607250019	COPPER	0.0 PPM	1.3 PPM
021-20A Classroom A5 Sink Faucet	7/21/16 7:46	7/29/16 11:52	607250020	COPPER	0.1 PPM	1.3 PPM
021-21A Classroom A5 Drinking Fountain	7/21/16 7:48	7/29/16 10:31	607250021	COPPER	0.1 PPM	1.3 PPM
021-22A Classroom A5 Sink Faucet	7/21/16 7:20	7/29/16 10:31	607250022	COPPER	0.1 PPM	1.3 PPM
021-23A Classroom A6 Sink Faucet	7/21/16 7:57	7/29/16 10:31	607250023	COPPER	0.1 PPM	1.3 PPM
021-24A Classroom A6 Sink Faucet	7/21/16 8:01	7/29/16 10:31	607250024	COPPER	0.0 PPM	1.3 PPM
021-25A Classroom A6 Drinking Fountain	7/21/16 8:03	7/29/16 10:31	607250025	COPPER	0.1 PPM	1.3 PPM
021-26A Girls Bathroom Drinking Fountain	7/21/16 8:06	7/29/16 10:32	607250026	COPPER	0.0 PPM	1.3 PPM
021-27A Health 111 Sink Faucet	7/21/16 8:07	7/29/16 10:32	607250027	COPPER	0.1 PPM	1.3 PPM
021-28A Hallway Drinking Fountain 3	7/21/16 8:13	7/29/16 10:32	607250028	COPPER	0.1 PPM	1.3 PPM
021-29A Classroom B1 Sink Faucet	7/21/16 8:16	7/29/16 10:32	607250029	COPPER	0.1 PPM	1.3 PPM
021-30A Classroom B1 Drinking Fountain	7/21/16 8:18	7/29/16 11:54	607250030	COPPER	0.1 PPM	1.3 PPM
021-31A Classroom B2 Sink Faucet	7/21/16 8:21	8/1/16 9:28	607250031	COPPER	1.1 PPM	1.3 PPM
021-32A Classroom B2 Drinking Fountain	7/21/16 8:23	7/29/16 12:29	607250032	COPPER	0.1 PPM	1.3 PPM
021-33A Classroom B3 Sink Faucet	7/21/16 8:26	7/29/16 12:29	607250033	COPPER	0.2 PPM	1.3 PPM
021-34A Classroom B3 Drinking Fountain	7/21/16 8:28	7/29/16 12:29	607250034	COPPER	0.1 PPM	1.3 PPM
021-35A Classroom B4 Sink Faucet	7/21/16 8:31	7/29/16 12:29	607250035	COPPER	0.1 PPM	1.3 PPM
021-36A Classroom B4 Drinking Fountain	7/21/16 8:33	7/29/16 12:29	607250036	COPPER	0.1 PPM	1.3 PPM
021-37A Classroom B5 Sink Faucet	7/21/16 8:36	7/29/16 12:29	607250037	COPPER	0.1 PPM	1.3 PPM
021-38A Classroom B5 Drinking Fountain	7/21/16 8:38	7/29/16 12:29	607250038	COPPER	0.0 PPM	1.3 PPM
021-39A Classroom B6 Sink Faucet	7/21/16 8:41	7/29/16 12:30	607250039	COPPER	0.1 PPM	1.3 PPM
021-40A Classroom B6 Drinking Fountain	7/21/16 8:43	7/29/16 12:34	607250040	COPPER	0.1 PPM	1.3 PPM
021-41A Hallway Drinking Fountain 4	7/21/16 8:46	7/29/16 12:34	607250041	COPPER	0.1 PPM	1.3 PPM
021-42A Classroom C1 Sink Faucet	7/21/16 8:50	7/29/16 12:35	607250042	COPPER	0.1 PPM	1.3 PPM
021-43A Classroom C1 Drinking Fountain	7/21/16 8:52	7/29/16 12:35	607250043	COPPER	0.0 PPM	1.3 PPM
021-44A Classroom C2 Sink Faucet	7/21/16 8:54	7/29/16 12:35	607250044	COPPER	0.1 PPM	1.3 PPM
021-45A Classroom C2 Drinking Fountain	7/21/16 8:56	7/29/16 12:35	607250045	COPPER	0.1 PPM	1.3 PPM
021-46A Classroom C3 Sink Faucet	7/21/16 8:59	7/29/16 12:35	607250046	COPPER	0.1 PPM	1.3 PPM
021-47A Classroom C3 Drinking Fountain	7/21/16 9:01	7/29/16 12:35	607250047	COPPER	0.1 PPM	1.3 PPM
021-48A Classroom C4 Sink Faucet	7/21/16 9:04	7/29/16 12:35	607250048	COPPER	0.1 PPM	1.3 PPM
021-49A Classroom C4 Drinking Fountain	7/21/16 9:06	7/29/16 12:35	607250049	COPPER	0.1 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Gubser Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
021-50A Classroom C5 Sink Faucet	7/21/16 9:09	7/29/16 12:36	607250050	COPPER	0.2 PPM	1.3 PPM
021-51A Classroom C5 Drinking Fountain	7/21/16 9:11	7/29/16 12:36	607250051	COPPER	0.1 PPM	1.3 PPM
021-52A Classroom C6 Sink Faucet	7/21/16 9:14	7/29/16 12:36	607250052	COPPER	0.1 PPM	1.3 PPM
021-53A Classroom C6 Drinking Fountain	7/21/16 9:16	7/29/16 12:36	607250053	COPPER	0.0 PPM	1.3 PPM
021-54A Music Room Second Sink	7/21/16 7:13	7/29/16 12:36	607250054	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level