

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Hammond Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
20-01A Food Prep Sink Faucet	8/2/2016 3:10	8/24/2016	50672	LEAD	<1 PPB	15 PPB
20-02A Kitchenette Off Multi Purpose Room Sink Faucet	8/2/2016 3:12	8/24/2016	50673	LEAD	2 PPB	15 PPB
20-03A Boys Restroom Water Fountain 1	8/2/2016 3:14	8/24/2016	50674	LEAD	<1 PPB	15 PPB
20-04A Boys Restroom Water Fountain 2	8/2/2016 3:16	8/24/2016	50675	LEAD	<1 PPB	15 PPB
20-05A Music Room Sink Faucet	8/2/2016 3:18	8/24/2016	50676	LEAD	2 PPB	15 PPB
20-06A Music Room Drinking Fountain	8/2/2016 3:18	8/24/2016	50677	LEAD	2 PPB	15 PPB
20-07A Gymnasium Drinking Fountain 1	8/2/2016 3:20	8/24/2016	50678	LEAD	<1 PPB	15 PPB
20-08A Gymnasium Drinking Fountain 2	8/2/2016 3:22	8/24/2016	50679	LEAD	<1 PPB	15 PPB
20-09A Nurse's Station Drinking Fountain	8/2/2016 3:22	8/24/2016	50680	LEAD	<1 PPB	15 PPB
20-10A Nurse's station Sink Faucet	8/2/2016 3:22	8/24/2016	50681	LEAD	1 PPB	15 PPB
20-11A Teacher Work Room Drinking Fountain	8/2/2016 3:24	8/24/2016	50682	LEAD	2 PPB	15 PPB
20-12A Teacher Work Room Sink Faucet	8/2/2016 3:24	8/24/2016	50683	LEAD	1 PPB	15 PPB
20-13A Teacher Work Room Sink Faucet	8/2/2016 3:24	8/24/2016	50684	LEAD	1 PPB	15 PPB
20-15A Classroom A1 Drinking Fountain	8/2/2016 3:35	8/24/2016	50685	LEAD	<1 PPB	15 PPB
20-16A Classroom A1 Sink Faucet	8/2/2016 3:35	8/24/2016	50686	LEAD	1 PPB	15 PPB
20-17A Classroom A2 Drinking Fountain	8/2/2016 3:37	8/24/2016	50687	LEAD	<1 PPB	15 PPB
20-18A Classroom A2 Sink Faucet	8/2/2016 3:37	8/24/2016	50688	LEAD	1 PPB	15 PPB
20-19A Classroom A3 Drinking Fountain	8/2/2016 3:39	8/24/2016	50689	LEAD	<1 PPB	15 PPB
20-20A Classroom A3 Sink Faucet	8/2/2016 3:39	8/24/2016	50690	LEAD	<1 PPB	15 PPB
20-21A Classroom A4 Drinking Fountain	8/2/2016 3:41	8/24/2016	50691	LEAD	<1 PPB	15 PPB
20-22A Classroom A4 Sink Faucet	8/2/2016 3:41	8/24/2016	50692	LEAD	<1 PPB	15 PPB
20-23A Classroom A5 Drinking Fountain	8/2/2016 3:43	8/24/2016	50693	LEAD	<1 PPB	15 PPB
20-24A Classroom A5 Sink Faucet	8/2/2016 3:43	8/24/2016	50694	LEAD	<1 PPB	15 PPB
20-25A Classroom A6 Drinking Fountain	8/2/2016 3:45	8/24/2016	50695	LEAD	<1 PPB	15 PPB
20-26A Classroom A6 Sink Faucet	8/2/2016 3:45	8/24/2016	50696	LEAD	<1 PPB	15 PPB
20-27A Classroom A7 Drinking Fountain	8/2/2016 3:47	8/24/2016	50697	LEAD	<1 PPB	15 PPB
20-28A Classroom A7 Sink Faucet	8/2/2016 3:47	8/24/2016	50698	LEAD	<1 PPB	15 PPB
20-29A Library Sink Faucet	8/2/2016 3:49	8/24/2016	50699	LEAD	<1 PPB	15 PPB
20-30A Classroom B1 Drinking Fountain	8/2/2016 3:52	8/24/2016	50700	LEAD	1 PPB	15 PPB
20-31A Classroom B1 Sink Faucet	8/2/2016 3:52	8/24/2016	50701	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Hammond Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
20-32A Classroom B2 Drinking Fountain	8/2/2016 3:54	8/24/2016	50702	LEAD	<1 PPB	15 PPB
20-33A Classroom B2 Sink Faucet	8/2/2016 3:54	8/24/2016	50703	LEAD	1 PPB	15 PPB
20-34A Classroom B3 Drinking Fountain	8/2/2016 3:56	8/24/2016	50704	LEAD	<1 PPB	15 PPB
20-35A Classroom B3 Sink Faucet	8/2/2016 3:56	8/24/2016	50705	LEAD	<1 PPB	15 PPB
20-36A Classroom B4 Drinking Fountain	8/2/2016 3:58	8/24/2016	50706	LEAD	1 PPB	15 PPB
20-37A Classroom B4 Sink Faucet	8/2/2016 3:58	8/24/2016	50707	LEAD	2 PPB	15 PPB
20-38A Classroom B5 Drinking Fountain	8/2/2016 4:00	8/24/2016	50708	LEAD	<1 PPB	15 PPB
20-39A Classroom B5 Sink Faucet	8/2/2016 4:00	8/24/2016	50709	LEAD	<1 PPB	15 PPB
20-40A Classroom B6 Drinking Fountain	8/2/2016 4:02	8/24/2016	50710	LEAD	<1 PPB	15 PPB
20-41A Classroom B6 Sink Faucet	8/2/2016 4:02	8/24/2016	50711	LEAD	<1 PPB	15 PPB
20-42A Classroom C1 Drinking Fountain	8/2/2016 4:05	8/24/2016	50712	LEAD	<1 PPB	15 PPB
20-43A Classroom C1 Sink Faucet	8/2/2016 4:05	8/24/2016	50713	LEAD	2 PPB	15 PPB
20-44A Classroom C2 Drinking Fountain	8/2/2016 4:07	8/24/2016	50714	LEAD	<1 PPB	15 PPB
20-45A Classroom C2 Drinking Fountain	8/2/2016 4:07	8/24/2016	50715	LEAD	3 PPB	15 PPB
20-46A Classroom C3 Sink Faucet	8/2/2016 4:09	8/24/2016	50716	LEAD	<1 PPB	15 PPB
20-47A Classroom C3 Drinking Fountain	8/2/2016 4:09	8/24/2016	50717	LEAD	<1 PPB	15 PPB
20-48A Classroom C4 Sink Faucet	8/2/2016 4:11	8/24/2016	50718	LEAD	<1 PPB	15 PPB
20-49A Classroom C4 Drinking Fountain	8/2/2016 4:11	8/24/2016	50719	LEAD	<1 PPB	15 PPB
20-50A Classroom C5 Sink Faucet	8/2/2016 4:13	8/24/2016	50720	LEAD	<1 PPB	15 PPB
20-51A Classroom C5 Drinking Fountain	8/2/2016 4:13	8/25/2016	50721	LEAD	1 PPB	15 PPB
20-52A Classroom C6 Sink Faucet	8/2/2016 4:15	8/25/2016	50722	LEAD	<1 PPB	15 PPB
20-53A Classroom C6 Drinking Fountain	8/2/2016 4:15	8/25/2016	50723	LEAD	<1 PPB	15 PPB
20-54A Portable Classroom D1 Sink Faucet	8/2/2016 4:20	8/25/2016	50724	LEAD	<1 PPB	15 PPB
20-55A Portable Classroom D1 Drinking Fountain	8/2/2016 4:20	8/25/2016	50725	LEAD	2 PPB	15 PPB
20-56A Portable Classroom D2 Sink Faucet	8/2/2016 4:22	8/25/2016	50726	LEAD	<1 PPB	15 PPB
20-57A Portable Classroom D2 Drinking Fountain	8/2/2016 4:22	8/25/2016	50727	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level