

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-01A Staff Room (12) Sink Faucet	7/28/2016 12:59	8/16/2016	45529	COPPER	0.1 PPM	1.3 PPM
29-02A Drinking Fountain in Hall Between Boys & Girls Restrooms	7/28/2016 13:02	8/16/2016	45530	COPPER	0.0 PPM	1.3 PPM
29-03A Room 20 (Library) Office Sink Faucet	7/28/2016 13:05	8/16/2016	45531	COPPER	0.1 PPM	1.3 PPM
29-04A Room 20 (Library) Office Drinking Fountain	7/28/2016 13:05	8/16/2016	45532	COPPER	0.1 PPM	1.3 PPM
29-05A Room 13 Sink Faucet	7/28/2016 13:09	8/16/2016	45533	COPPER	0.1 PPM	1.3 PPM
29-06A Room 13 Drinking Fountain	7/28/2016 13:09	8/16/2016	45534	COPPER	0.1 PPM	1.3 PPM
29-07A Classroom 14 Sink Faucet	7/28/2016 13:14	8/16/2016	45535	COPPER	0.1 PPM	1.3 PPM
29-08A Classroom 14 Drinking Fountain	7/28/2016 13:15	8/16/2016	45536	COPPER	0.1 PPM	1.3 PPM
29-09A Classroom 19 Sink Faucet	7/28/2016 13:19	8/16/2016	45537	COPPER	0.1 PPM	1.3 PPM
29-10A Classroom 19 Drinking Fountain	7/28/2016 13:20	8/16/2016	45538	COPPER	0.3 PPM	1.3 PPM
29-11A Classroom 18 Sink Faucet	7/28/2016 13:24	8/16/2016	45539	COPPER	0.1 PPM	1.3 PPM
29-12A Classroom 18 Drinking Fountain	7/28/2016 13:25	8/16/2016	45540	COPPER	0.3 PPM	1.3 PPM
29-13A Classroom 15 Sink Faucet	7/28/2016 13:29	8/16/2016	45541	COPPER	0.1 PPM	1.3 PPM
29-14A Classroom 15 Drinking Fountain	7/28/2016 13:30	8/16/2016	45542	COPPER	0.2 PPM	1.3 PPM
29-15A Classroom 15 Sink Faucet	7/28/2016 13:35	8/16/2016	45543	COPPER	0.3 PPM	1.3 PPM
29-16A Classroom 16 Drinking Fountain	7/28/2016 13:35	8/16/2016	45544	COPPER	0.3 PPM	1.3 PPM
29-17A Classroom 17 Sink Faucet	7/28/2016 13:38	8/16/2016	45545	COPPER	0.2 PPM	1.3 PPM
29-18A Classroom 17 Drinking Fountain	7/28/2016 13:38	8/16/2016	45546	COPPER	0.2 PPM	1.3 PPM
29-19A Kitchen Storage Room Sink	7/28/2016 13:52	8/16/2016	45547	COPPER	0.1 PPM	1.3 PPM
29-20A Kitchen Left Faucet on Triple Sink	7/28/2016 14:01	8/16/2016	45548	COPPER	0.1 PPM	1.3 PPM
29-21A Kitchen Center Faucet Triple Sink	7/28/2016 14:01	8/16/2016	45549	COPPER	0.1 PPM	1.3 PPM
29-22A Kitchen Right Sink Faucet	7/28/2016 14:03	8/16/2016	45550	COPPER	0.4 PPM	1.3 PPM
29-23A Kitchen Sink Faucet Right of Dishwasher	7/28/2016 14:04	8/16/2016	45551	COPPER	0.1 PPM	1.3 PPM
29-24A Hall Between Kitchen & MPR Drinking Fountain	7/28/2016 14:07	8/16/2016	45552	COPPER	0.1 PPM	1.3 PPM
29-25A Faculty Workroom Sink Faucet	7/28/2016 14:11	8/16/2016	45553	COPPER	0.1 PPM	1.3 PPM
29-26A Classroom 1 Sink Faucet	7/28/2016 14:14	8/16/2016	45554	COPPER	0.1 PPM	1.3 PPM
29-27A Classroom 1 Drinking Fountain	7/28/2016 14:15	8/16/2016	45555	COPPER	0.1 PPM	1.3 PPM
29-28A Classroom 11 Sink Faucet	7/28/2016 14:18	8/16/2016	45556	COPPER	0.1 PPM	1.3 PPM
29-29A Classroom 11 Drinking Fountain	7/28/2016 14:19	8/16/2016	45557	COPPER	0.1 PPM	1.3 PPM
29-30A Classroom 2 Sink Faucet	7/28/2016 14:22	8/16/2016	45558	COPPER	0.1 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-31A Classroom 2 Drinking Fountain	7/28/2016 14:23	8/16/2016	45559	COPPER	0.1 PPM	1.3 PPM
29-32A Classroom 10 Sink Faucet	7/28/2016 14:27	8/16/2016	45560	COPPER	0.1 PPM	1.3 PPM
29-33A Classroom 10 Drinking Fountain	7/28/2016 14:28	8/16/2016	45561	COPPER	0.1 PPM	1.3 PPM
29-34A Classroom 3 Sink Faucet	7/28/2016 14:30	8/16/2016	45562	COPPER	0.1 PPM	1.3 PPM
29-35A Calsroom 3 Drinking Fountain	7/28/2016 14:31	8/16/2016	45563	COPPER	0.1 PPM	1.3 PPM
29-36A Hallway Drinking Fountain Across from Room 4	7/28/2016 14:34	8/16/2016	45564	COPPER	0.1 PPM	1.3 PPM
29-37A Classroom 4 Sink Faucet	7/28/2016 14:37	8/16/2016	45565	COPPER	0.1 PPM	1.3 PPM
29-38A Calsroom 4 Drinking Fountain	7/28/2016 14:38	8/16/2016	45566	COPPER	0.1 PPM	1.3 PPM
29-39A Classroom 9 Sink Faucet	7/28/2016 14:42	8/16/2016	45567	COPPER	0.2 PPM	1.3 PPM
29-40A Classroom 9 Drinking Fountain	7/28/2016 14:43	8/16/2016	45568	COPPER	0.1 PPM	1.3 PPM
29-41A Classroom 5 Sink Faucet	7/28/2016 14:48	8/16/2016	45569	COPPER	0.1 PPM	1.3 PPM
29-42A Classroom 5 Drinking Fountain	7/28/2016 14:49	8/16/2016	45570	COPPER	0.1 PPM	1.3 PPM
29-43A Classroom 8 Sink Faucet	7/28/2016 14:53	8/16/2016	45571	COPPER	0.2 PPM	1.3 PPM
29-44A Classroom 8 Drinking Fountain	7/28/2016 14:54	8/16/2016	45572	COPPER	0.1 PPM	1.3 PPM
29-45A Classroom 6 Sink Faucet	7/28/2016 14:56	8/16/2016	45573	COPPER	0.2 PPM	1.3 PPM
29-46A Classroom 6 Drinking Fountain	7/28/2016 14:57	8/16/2016	45574	COPPER	0.1 PPM	1.3 PPM
29-47A Classroom 7 Sink Faucet	7/28/2016 15:01	8/16/2016	45575	COPPER	0.3 PPM	1.3 PPM
29-48A Classroom 7 Drinking Fountain	7/28/2016 15:02	8/16/2016	45576	COPPER	0.1 PPM	1.3 PPM
29-49A Gymnasium Drinking Fountain	7/28/2016 15:06	8/16/2016	45577	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level