

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-01A Staff Room (12) Sink Faucet	7/28/2016 12:59	8/16/2016	45529	LEAD	2 PPB	15 PPB
29-02A Drinking Fountain in Hall Between Boys & Girls Restrooms	7/28/2016 13:02	8/16/2016	45530	LEAD	<1 PPB	15 PPB
29-03A Room 20 (Library) Office Sink Faucet	7/28/2016 13:05	8/16/2016	45531	LEAD	<1 PPB	15 PPB
29-04A Room 20 (Library) Office Drinking Fountain	7/28/2016 13:05	8/16/2016	45532	LEAD	21 PPB	15 PPB
29-05A Room 13 Sink Faucet	7/28/2016 13:09	8/16/2016	45533	LEAD	14 PPB	15 PPB
29-06A Room 13 Drinking Fountain	7/28/2016 13:09	8/16/2016	45534	LEAD	<1 PPB	15 PPB
29-07A Classroom 14 Sink Faucet	7/28/2016 13:14	8/16/2016	45535	LEAD	2 PPB	15 PPB
29-08A Classroom 14 Drinking Fountain	7/28/2016 13:15	8/16/2016	45536	LEAD	<1 PPB	15 PPB
29-09A Classroom 19 Sink Faucet	7/28/2016 13:19	8/16/2016	45537	LEAD	2 PPB	15 PPB
29-10A Classroom 19 Drinking Fountain	7/28/2016 13:20	8/16/2016	45538	LEAD	1 PPB	15 PPB
29-11A Classroom 18 Sink Faucet	7/28/2016 13:24	8/16/2016	45539	LEAD	1 PPB	15 PPB
29-12A Classroom 18 Drinking Fountain	7/28/2016 13:25	8/16/2016	45540	LEAD	2 PPB	15 PPB
29-13A Classroom 15 Sink Faucet	7/28/2016 13:29	8/16/2016	45541	LEAD	2 PPB	15 PPB
29-14A Classroom 15 Drinking Fountain	7/28/2016 13:30	8/16/2016	45542	LEAD	<1 PPB	15 PPB
29-15A Classroom 15 Sink Faucet	7/28/2016 13:35	8/16/2016	45543	LEAD	<1 PPB	15 PPB
29-16A Classroom 16 Drinking Fountain	7/28/2016 13:35	8/16/2016	45544	LEAD	<1 PPB	15 PPB
29-17A Classroom 17 Sink Faucet	7/28/2016 13:38	8/16/2016	45545	LEAD	<1 PPB	15 PPB
29-18A Classroom 17 Drinking Fountain	7/28/2016 13:38	8/16/2016	45546	LEAD	<1 PPB	15 PPB
29-19A Kitchen Storage Room Sink	7/28/2016 13:52	8/16/2016	45547	LEAD	<1 PPB	15 PPB
29-20A Kitchen Left Faucet on Triple Sink	7/28/2016 14:01	8/16/2016	45548	LEAD	14 PPB	15 PPB
29-21A Kitchen Center Faucet Triple Sink	7/28/2016 14:01	8/16/2016	45549	LEAD	48 PPB	15 PPB
29-22A Kitchen Right Sink Faucet	7/28/2016 14:03	8/16/2016	45550	LEAD	42 PPB	15 PPB
29-23A Kitchen Sink Faucet Right of Dishwasher	7/28/2016 14:04	8/16/2016	45551	LEAD	2 PPB	15 PPB
29-24A Hall Between Kitchen & MPR Drinking Fountain	7/28/2016 14:07	8/16/2016	45552	LEAD	<1 PPB	15 PPB
29-25A Faculty Workroom Sink Faucet	7/28/2016 14:11	8/16/2016	45553	LEAD	<1 PPB	15 PPB
29-26A Classroom 1 Sink Faucet	7/28/2016 14:14	8/16/2016	45554	LEAD	3 PPB	15 PPB
29-27A Classroom 1 Drinking Fountain	7/28/2016 14:15	8/16/2016	45555	LEAD	<1 PPB	15 PPB
29-28A Classroom 11 Sink Faucet	7/28/2016 14:18	8/16/2016	45556	LEAD	5 PPB	15 PPB
29-29A Classroom 11 Drinking Fountain	7/28/2016 14:19	8/16/2016	45557	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-30A Classroom 2 Sink Faucet	7/28/2016 14:22	8/16/2016	45558	LEAD	6 PPB	15 PPB
29-31A Classroom 2 Drinking Fountain	7/28/2016 14:23	8/16/2016	45559	LEAD	<1 PPB	15 PPB
29-32A Classroom 10 Sink Faucet	7/28/2016 14:27	8/16/2016	45560	LEAD	2 PPB	15 PPB
29-33A Classroom 10 Drinking Fountain	7/28/2016 14:28	8/16/2016	45561	LEAD	2 PPB	15 PPB
29-34A Classroom 3 Sink Faucet	7/28/2016 14:30	8/16/2016	45562	LEAD	3 PPB	15 PPB
29-35A Calsroom 3 Drinking Fountain	7/28/2016 14:31	8/16/2016	45563	LEAD	<1 PPB	15 PPB
29-36A Hallway Drinking Fountain Across from Room 4	7/28/2016 14:34	8/16/2016	45564	LEAD	<1 PPB	15 PPB
29-37A Classroom 4 Sink Faucet	7/28/2016 14:37	8/16/2016	45565	LEAD	3 PPB	15 PPB
29-38A Calsroom 4 Drinking Fountain	7/28/2016 14:38	8/16/2016	45566	LEAD	2 PPB	15 PPB
29-39A Classroom 9 Sink Faucet	7/28/2016 14:42	8/16/2016	45567	LEAD	7 PPB	15 PPB
29-40A Classroom 9 Drinking Fountain	7/28/2016 14:43	8/16/2016	45568	LEAD	<1 PPB	15 PPB
29-41A Classroom 5 Sink Faucet	7/28/2016 14:48	8/16/2016	45569	LEAD	2 PPB	15 PPB
29-42A Classroom 5 Drinking Fountain	7/28/2016 14:49	8/16/2016	45570	LEAD	<1 PPB	15 PPB
29-43A Classroom 8 Sink Faucet	7/28/2016 14:53	8/16/2016	45571	LEAD	2 PPB	15 PPB
29-44A Classroom 8 Drinking Fountain	7/28/2016 14:54	8/16/2016	45572	LEAD	<1 PPB	15 PPB
<b>29-45A Classroom 6 Sink Faucet</b>	<b>7/28/2016 14:56</b>	<b>8/16/2016</b>	<b>45573</b>	<b>LEAD</b>	<b>17 PPB</b>	<b>15 PPB</b>
29-46A Classroom 6 Drinking Fountain	7/28/2016 14:57	8/16/2016	45574	LEAD	<1 PPB	15 PPB
29-47A Classroom 7 Sink Faucet	7/28/2016 15:01	8/16/2016	45575	LEAD	4 PPB	15 PPB
29-48A Classroom 7 Drinking Fountain	7/28/2016 15:02	8/16/2016	45576	LEAD	1 PPB	15 PPB
29-49A Gymnasium Drinking Fountain	7/28/2016 15:06	8/16/2016	45577	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
30 Second Draw (B) Sample Data  
Hayesville Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
29-04B Room 20 (Library) Office Water Fountain	7/28/2016 13:06	9/1/2016	52938	LEAD	2 PPB	15 PPB
29-21B Kitchen Center Faucet on Triple Sink	7/28/2016 14:03	9/1/2016	52939	LEAD	<1 PPB	15 PPB
29-22B Kitchen Right Sink Faucet	7/28/2016 14:04	9/1/2016	52940	LEAD	<1 PPB	15 PPB
29-45B Classroom 6 Sink Faucet	7/28/2016 15:07	9/1/2016	52941	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**