

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Highland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
23-01A Room 1 Drinking Fountain	8/6/16 12:16	8/10/2016	1608453-01A	LEAD	8 PPB	15 PPB
23-02A Room 1 Sink Faucet	8/6/16 12:16	8/10/2016	1608453-02A	LEAD	2 PPB	15 PPB
23-03A Room 2 Sink Faucet	8/6/16 12:18	8/10/2016	1608453-03A	LEAD	2 PPB	15 PPB
23-04A Room 2 Drinking Fountain	8/6/16 12:18	8/10/2016	1608453-04A	LEAD	<1.0 PPB	15 PPB
23-05A Room 3 Drinking Fountain	8/6/16 12:20	8/10/2016	1608453-05A	LEAD	10 PPB	15 PPB
23-06A Room 3 Sink Faucet	8/6/16 12:20	8/10/2016	1608453-06A	LEAD	3 PPB	15 PPB
23-07A Room 4 Drinking Fountain	8/6/16 12:22	8/10/2016	1608453-07A	LEAD	8 PPB	15 PPB
23-08A Room 4 Sink Faucet	8/6/16 12:23	8/10/2016	1608453-08A	LEAD	2 PPB	15 PPB
23-09A Hall by Custodian Drinking Fountain 1	8/6/16 12:24	8/10/2016	1608453-09A	LEAD	6 PPB	15 PPB
23-10A Room 5 Drinking Fountain	8/6/16 12:26	8/10/2016	1608453-10A	LEAD	10 PPB	15 PPB
23-11A Room 5 Sink Faucet	8/6/16 12:26	8/10/2016	1608453-11A	LEAD	2 PPB	15 PPB
23-12A Room 6 Drinking Fountain	8/6/16 12:29	8/10/2016	1608453-12A	LEAD	4 PPB	15 PPB
23-13A Room 6 Sink Faucet	8/6/16 12:29	8/10/2016	1608453-13A	LEAD	2 PPB	15 PPB
23-14A Room 7 Drinking Fountain	8/6/16 12:46	8/10/2016	1608453-14A	LEAD	5 PPB	15 PPB
23-15A Room 7 Sink Faucet	8/6/16 12:46	8/10/2016	1608453-15A	LEAD	2 PPB	15 PPB
23-16A Room 8 Drinking Fountain	8/6/16 12:49	8/10/2016	1608453-16A	LEAD	4 PPB	15 PPB
23-17A Room 8 Sink Faucet	8/6/16 12:49	8/10/2016	1608453-17A	LEAD	2 PPB	15 PPB
23-18A Hall Drinking Fountain 2	8/6/16 12:52	8/10/2016	1608453-18A	LEAD	4 PPB	15 PPB
23-19A Health Room Nurse's Station Sink Faucet	8/6/16 12:54	8/10/2016	1608453-19A	LEAD	3 PPB	15 PPB
23-20A Health Room Nurse's Station Drinking Fountain	8/6/16 12:54	8/10/2016	1608453-20A	LEAD	2 PPB	15 PPB
23-21A Room 9 Drinking Fountain	8/6/16 12:56	8/11/2016	1608453-21A	LEAD	8 PPB	15 PPB
23-22A Room 9 Sink Faucet	8/6/16 12:56	8/11/2016	1608453-22A	LEAD	2 PPB	15 PPB
23-23A Staff Room Alcove Sink Faucet	8/6/16 12:58	8/11/2016	1608453-23A	LEAD	1 PPB	15 PPB
23-24A Room 11 Drinking Fountain	8/6/16 13:00	8/11/2016	1608453-24A	LEAD	5 PPB	15 PPB
23-25A Room 11 Sink Faucet	8/6/16 13:00	8/11/2016	1608453-25A	LEAD	2 PPB	15 PPB
23-26A Library Sink Faucet	8/6/16 13:05	8/11/2016	1608453-26A	LEAD	8 PPB	15 PPB
23-27A Library Drinking Fountain	8/6/16 13:05	8/11/2016	1608453-27A	LEAD	3 PPB	15 PPB
23-29A Computer Room 16 Sink Faucet	8/6/16 13:19	8/11/2016	1608453-28A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Highland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
23-30A Room 18 Sink Faucet	8/6/16 13:22	8/11/2016	1608453-29A	LEAD	2 PPB	15 PPB
23-31A Room 18 Drinking Fountain	8/6/16 13:22	8/11/2016	1608453-30A	LEAD	2 PPB	15 PPB
23-32A Room 19 Sink Faucet	8/6/16 13:26	8/11/2016	1608453-31A	LEAD	2 PPB	15 PPB
23-33A Room 19 Drinking Fountain	8/6/16 13:26	8/11/2016	1608453-32A	LEAD	3 PPB	15 PPB
23-34A Room 12 Drinking Fountain	8/6/16 13:29	8/11/2016	1608453-33A	LEAD	<1.0 PPB	15 PPB
23-35A Room 12 Sink Faucet	8/6/16 13:29	8/11/2016	1608453-34A	LEAD	1 PPB	15 PPB
23-36A Room 15 Drinking Fountain	8/6/16 13:31	8/11/2016	1608453-35A	LEAD	4 PPB	15 PPB
23-37A Room 15 Sink Faucet	8/6/16 13:31	8/11/2016	1608453-36A	LEAD	<1.0 PPB	15 PPB
23-38A 3rd Floor Hall Drinking Fountain by Custodial Room 3	8/6/16 13:32	8/11/2016	1608453-37A	LEAD	2 PPB	15 PPB
23-39A Room 13 Drinking Fountain	8/6/16 13:35	8/11/2016	1608453-38A	LEAD	3 PPB	15 PPB
23-40A Room 13 Sink Faucet	8/6/16 13:35	8/11/2016	1608453-39A	LEAD	2 PPB	15 PPB
23-41A Room 12 Drinking Fountain	8/6/16 13:37	8/11/2016	1608453-40A	LEAD	4 PPB	15 PPB
23-42A Room 12 Sink Faucet	8/6/16 13:37	8/11/2016	1608453-41A	LEAD	2 PPB	15 PPB
23-43A Gymnasium Restroom Drinking Fountain	8/6/16 13:49	8/11/2016	1608453-42A	LEAD	<1.0 PPB	15 PPB
23-44A Music Room Sink Faucet	8/6/16 13:52	8/11/2016	1608453-43A	LEAD	1 PPB	15 PPB
23-45A Room 28 Portable Sink Faucet	8/6/16 13:59	8/11/2016	1608453-44A	LEAD	1 PPB	15 PPB
23-46A Room 28 Drinking Fountain	8/6/16 13:59	8/11/2016	1608453-45A	LEAD	1 PPB	15 PPB
23-47A Room 28 Sink Faucet	8/6/16 14:01	8/11/2016	1608453-46A	LEAD	<1.0 PPB	15 PPB
23-48A Room 28 Drinking Fountain	8/6/16 14:01	8/11/2016	1608453-47A	LEAD	<1.0 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Highland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
23-28A Computer Room 16 Drinking Fountain	9/23/2016 4:41	9/26/2016	58300	LEAD	15 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level