

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Hoover Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
24-01A Staff Room Sink Faucet	8/12/16 4:55	8/16/2016	1608858-01A	COPPER	0.2 PPM	1.3 PPM
24-02A Hall Drinking Fountain by Staff Restroom #1	8/12/16 4:57	8/16/2016	1608858-02A	COPPER	0.5 PPM	1.3 PPM
24-03A Room 3 Drinking Fountain	8/12/16 4:59	8/16/2016	1608858-03A	COPPER	0.6 PPM	1.3 PPM
24-04A Room 3 Sink Faucet	8/12/16 5:01	8/16/2016	1608858-04A	COPPER	0.3 PPM	1.3 PPM
24-05A Library Sink Faucet	8/12/16 5:03	8/16/2016	1608858-05A	COPPER	0.4 PPM	1.3 PPM
24-06A Room 14 Sink Faucet	8/12/16 5:06	8/17/2016	1608858-06A	COPPER	0.3 PPM	1.3 PPM
24-07A Room 14 Drinking Fountain	8/12/16 5:06	8/16/2016	1608858-07A	COPPER	0.4 PPM	1.3 PPM
24-08A Room 15 Sink Faucet	8/12/16 5:09	8/17/2016	1608858-08A	COPPER	0.3 PPM	1.3 PPM
24-09A Room 15 Drinking Fountain	8/12/16 5:09	8/16/2016	1608858-09A	COPPER	0.5 PPM	1.3 PPM
24-10A Room 16 Sink Faucet	8/12/16 5:12	8/16/2016	1608858-10A	COPPER	0.4 PPM	1.3 PPM
24-11A Room 16 Drinking Fountain	8/12/16 5:12	8/16/2016	1608858-11A	COPPER	0.5 PPM	1.3 PPM
24-12A Drinking Fountain	8/12/16 5:15	8/16/2016	1608858-12A	COPPER	0.6 PPM	1.3 PPM
24-13A Hall Drinking Fountain #2	8/12/16 5:17	8/16/2016	1608858-13A	COPPER	0.8 PPM	1.3 PPM
24-14A Room 13 Drinking Fountain	8/12/16 5:22	8/16/2016	1608858-14A	COPPER	0.5 PPM	1.3 PPM
24-15A Room 13 Sink Faucet	8/12/16 5:22	8/16/2016	1608858-15A	COPPER	0.4 PPM	1.3 PPM
24-16A Room 4 Drinking Fountain	8/12/16 5:25	8/16/2016	1608858-16A	COPPER	0.4 PPM	1.3 PPM
24-17A Room 4 Sink Faucet	8/12/16 5:25	8/17/2016	1608858-17A	COPPER	0.3 PPM	1.3 PPM
24-18A Room 12 Drinking Fountain	8/12/16 5:27	8/16/2016	1608858-18A	COPPER	0.5 PPM	1.3 PPM
24-19A Room 12 Sink Faucet	8/12/16 5:27	8/16/2016	1608858-19A	COPPER	0.6 PPM	1.3 PPM
24-20A Room 5 Drinking Fountain	8/12/16 5:30	8/16/2016	1608858-20A	COPPER	0.5 PPM	1.3 PPM
24-21A Room 5 Sink Faucet	8/12/16 5:30	8/17/2016	1608858-21A	COPPER	0.6 PPM	1.3 PPM
24-22A Hall Drinking Fountain Opposite Room 12 #3	8/12/16 5:33	8/16/2016	1608858-22A	COPPER	0.6 PPM	1.3 PPM
24-23A Room 11 Drinking Fountain	8/12/16 5:34	8/16/2016	1608858-23A	COPPER	0.5 PPM	1.3 PPM
24-24A Room 11 Sink Faucet	8/12/16 5:34	8/16/2016	1608858-24A	COPPER	0.4 PPM	1.3 PPM
24-25A Room 6 Drinking Fountain	8/12/16 5:37	8/17/2016	1608858-25A	COPPER	0.4 PPM	1.3 PPM
24-26A Room 6 Sink Faucet	8/12/16 5:37	8/16/2016	1608858-26A	COPPER	0.4 PPM	1.3 PPM
24-27A Room 10 Drinking Fountain	8/12/16 5:40	8/16/2016	1608858-27A	COPPER	0.5 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Hoover Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
24-28A Room 10 Sink Faucet	8/12/16 5:40	8/17/2016	1608858-28A	COPPER	0.5 PPM	1.3 PPM
24-29A Room 7 Drinking Fountain	8/12/16 5:43	8/16/2016	1608858-29A	COPPER	0.4 PPM	1.3 PPM
24-30A Room 7 Sink Faucet	8/12/16 5:43	8/16/2016	1608858-30A	COPPER	0.3 PPM	1.3 PPM
24-31A Hall Drinking Fountain	8/12/16 5:50	8/16/2016	1608858-31A	COPPER	0.6 PPM	1.3 PPM
24-32A Room 8 Drinking Fountain	8/12/16 5:52	8/16/2016	1608858-32A	COPPER	0.5 PPM	1.3 PPM
24-33A Room 8 Sink Faucet	8/12/16 5:52	8/16/2016	1608858-33A	COPPER	0.4 PPM	1.3 PPM
24-34A Room 9 Drinking Fountain	8/12/16 5:54	8/16/2016	1608858-34A	COPPER	0.5 PPM	1.3 PPM
24-35A Room 9 Sink Faucet	8/12/16 5:54	8/16/2016	1608858-35A	COPPER	0.5 PPM	1.3 PPM
24-36A Nurses Station Sink Faucet	8/12/16 6:03	8/17/2016	1608858-36A	COPPER	0.3 PPM	1.3 PPM
24-37A Room 17 Sink Faucet	8/12/16 6:04	8/16/2016	1608858-37A	COPPER	0.2 PPM	1.3 PPM
24-38A Room 17 Drinking Fountain	8/12/16 6:04	8/16/2016	1608858-38A	COPPER	0.4 PPM	1.3 PPM
24-39A Room 18 Sink Faucet	8/12/16 6:07	8/17/2016	1608858-39A	COPPER	0.4 PPM	1.3 PPM
24-40A Room 18 Drinking Fountain	8/12/16 6:07	8/16/2016	1608858-40A	COPPER	0.5 PPM	1.3 PPM
24-41A Room 2 Drinking Fountain	8/12/16 6:10	8/16/2016	1608858-41A	COPPER	0.5 PPM	1.3 PPM
24-42A Room 2 Sink Faucet	8/12/16 6:10	8/16/2016	1608858-42A	COPPER	0.4 PPM	1.3 PPM
24-43A Room 19 Sink Faucet	8/12/16 6:13	8/16/2016	1608858-43A	COPPER	0.3 PPM	1.3 PPM
24-44A Room 19 Drinking Fountain	8/12/16 6:13	8/17/2016	1608858-44A	COPPER	0.4 PPM	1.3 PPM
24-45A Room 1 Drinking Fountain	8/12/16 6:16	8/16/2016	1608858-45A	COPPER	0.7 PPM	1.3 PPM
24-46A Room 1 Sink Faucet	8/12/16 6:16	8/16/2016	1608858-46A	COPPER	0.5 PPM	1.3 PPM
24-47A Hall Drinking Fountain #4	8/12/16 6:19	8/16/2016	1608858-47A	COPPER	0.6 PPM	1.3 PPM
24-48A Cafeteria Drinking Fountain	8/12/16 6:21	8/16/2016	1608858-48A	COPPER	0.6 PPM	1.3 PPM
24-49A Kitchen Double Sink Faucet	8/12/16 6:24	8/16/2016	1608858-49A	COPPER	0.4 PPM	1.3 PPM
24-50A Kitchen Single Sink Faucet	8/12/16 6:24	8/16/2016	1608858-50A	COPPER	0.4 PPM	1.3 PPM
24-51A Gym Drinking Fountain	8/12/16 6:29	8/16/2016	1608858-51A	COPPER	0.3 PPM	1.3 PPM
24-52A Music Room Sink Faucet	8/12/16 6:32	8/17/2016	1608858-52A	COPPER	0.6 PPM	1.3 PPM
24-53A Office Sink Faucet	8/12/16 6:42	8/16/2016	1608858-53A	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Hoover Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
--------------------------------------	-------------------	---------------	--------------	------------	---------	--------------

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Copper Water Sampling Results
 Flushed (B) Sample Data
 Hoover Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
24-52B Music Room Sink Faucet	8/12/16 6:33 AM	9/2/2016	1608859-52A	COPPER	0.7 PPM	1.3 PPM
EPA Action Level for Copper in Schools is 1.3 PPM						
SKPS Action Level for Copper is 1.3 PPM						
Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level						