

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Hoover Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
24-01A Staff Room Sink Faucet	8/12/16 4:55	8/16/2016	1608858-01A	LEAD	3 PPB	15 PPB
24-02A Hall Drinking Fountain by Staff Restroom #1	8/12/16 4:57	8/16/2016	1608858-02A	LEAD	2 PPB	15 PPB
24-03A Room 3 Drinking Fountain	8/12/16 4:59	8/16/2016	1608858-03A	LEAD	3 PPB	15 PPB
24-04A Room 3 Sink Faucet	8/12/16 5:01	8/16/2016	1608858-04A	LEAD	<1.0 PPB	15 PPB
24-05A Library Sink Faucet	8/12/16 5:03	8/16/2016	1608858-05A	LEAD	3 PPB	15 PPB
24-06A Room 14 Sink Faucet	8/12/16 5:06	8/17/2016	1608858-06A	LEAD	4 PPB	15 PPB
24-07A Room 14 Drinking Fountain	8/12/16 5:06	8/16/2016	1608858-07A	LEAD	1 PPB	15 PPB
24-08A Room 15 Sink Faucet	8/12/16 5:09	8/17/2016	1608858-08A	LEAD	4 PPB	15 PPB
24-09A Room 15 Drinking Fountain	8/12/16 5:09	8/16/2016	1608858-09A	LEAD	1 PPB	15 PPB
24-10A Room 16 Sink Faucet	8/12/16 5:12	8/16/2016	1608858-10A	LEAD	3 PPB	15 PPB
24-11A Room 16 Drinking Fountain	8/12/16 5:12	8/16/2016	1608858-11A	LEAD	<1.0 PPB	15 PPB
24-12A Drinking Fountain	8/12/16 5:15	8/16/2016	1608858-12A	LEAD	<1.0 PPB	15 PPB
24-13A Hall Drinking Fountain #2	8/12/16 5:17	8/16/2016	1608858-13A	LEAD	<1.0 PPB	15 PPB
24-14A Room 13 Drinking Fountain	8/12/16 5:22	8/16/2016	1608858-14A	LEAD	2 PPB	15 PPB
24-15A Room 13 Sink Faucet	8/12/16 5:22	8/16/2016	1608858-15A	LEAD	2 PPB	15 PPB
24-16A Room 4 Drinking Fountain	8/12/16 5:25	8/16/2016	1608858-16A	LEAD	<1.0 PPB	15 PPB
24-17A Room 4 Sink Faucet	8/12/16 5:25	8/17/2016	1608858-17A	LEAD	6 PPB	15 PPB
24-18A Room 12 Drinking Fountain	8/12/16 5:27	8/16/2016	1608858-18A	LEAD	4 PPB	15 PPB
24-19A Room 12 Sink Faucet	8/12/16 5:27	8/16/2016	1608858-19A	LEAD	3 PPB	15 PPB
24-20A Room 5 Drinking Fountain	8/12/16 5:30	8/16/2016	1608858-20A	LEAD	<1.0 PPB	15 PPB
24-21A Room 5 Sink Faucet	8/12/16 5:30	8/17/2016	1608858-21A	LEAD	3 PPB	15 PPB
24-22A Hall Drinking Fountain Opposite Room 12 #3	8/12/16 5:33	8/16/2016	1608858-22A	LEAD	1 PPB	15 PPB
24-23A Room 11 Drinking Fountain	8/12/16 5:34	8/16/2016	1608858-23A	LEAD	4 PPB	15 PPB
24-24A Room 11 Sink Faucet	8/12/16 5:34	8/16/2016	1608858-24A	LEAD	2 PPB	15 PPB
24-25A Room 6 Drinking Fountain	8/12/16 5:37	8/17/2016	1608858-25A	LEAD	9 PPB	15 PPB
24-26A Room 6 Sink Faucet	8/12/16 5:37	8/16/2016	1608858-26A	LEAD	3 PPB	15 PPB
24-27A Room 10 Drinking Fountain	8/12/16 5:40	8/16/2016	1608858-27A	LEAD	5 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Hoover Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
24-28A Room 10 Sink Faucet	8/12/16 5:40	8/17/2016	1608858-28A	LEAD	2 PPB	15 PPB
24-29A Room 7 Drinking Fountain	8/12/16 5:43	8/16/2016	1608858-29A	LEAD	3 PPB	15 PPB
24-30A Room 7 Sink Faucet	8/12/16 5:43	8/16/2016	1608858-30A	LEAD	6 PPB	15 PPB
24-31A Hall Drinking Fountain	8/12/16 5:50	8/16/2016	1608858-31A	LEAD	5 PPB	15 PPB
24-32A Room 8 Drinking Fountain	8/12/16 5:52	8/16/2016	1608858-32A	LEAD	2 PPB	15 PPB
24-33A Room 8 Sink Faucet	8/12/16 5:52	8/16/2016	1608858-33A	LEAD	<1.0 PPB	15 PPB
24-34A Room 9 Drinking Fountain	8/12/16 5:54	8/16/2016	1608858-34A	LEAD	6 PPB	15 PPB
24-35A Room 9 Sink Faucet	8/12/16 5:54	8/16/2016	1608858-35A	LEAD	1 PPB	15 PPB
24-36A Nurses Station Sink Faucet	8/12/16 6:03	8/17/2016	1608858-36A	LEAD	3 PPB	15 PPB
24-37A Room 17 Sink Faucet	8/12/16 6:04	8/16/2016	1608858-37A	LEAD	3 PPB	15 PPB
24-38A Room 17 Drinking Fountain	8/12/16 6:04	8/16/2016	1608858-38A	LEAD	<1.0 PPB	15 PPB
24-39A Room 18 Sink Faucet	8/12/16 6:07	8/17/2016	1608858-39A	LEAD	2 PPB	15 PPB
24-40A Room 18 Drinking Fountain	8/12/16 6:07	8/16/2016	1608858-40A	LEAD	2 PPB	15 PPB
24-41A Room 2 Drinking Fountain	8/12/16 6:10	8/16/2016	1608858-41A	LEAD	2 PPB	15 PPB
24-42A Room 2 Sink Faucet	8/12/16 6:10	8/16/2016	1608858-42A	LEAD	3 PPB	15 PPB
24-43A Room 19 Sink Faucet	8/12/16 6:13	8/16/2016	1608858-43A	LEAD	6 PPB	15 PPB
24-44A Room 19 Drinking Fountain	8/12/16 6:13	8/17/2016	1608858-44A	LEAD	<1.0 PPB	15 PPB
24-45A Room 1 Drinking Fountain	8/12/16 6:16	8/16/2016	1608858-45A	LEAD	2 PPB	15 PPB
24-46A Room 1 Sink Faucet	8/12/16 6:16	8/16/2016	1608858-46A	LEAD	9 PPB	15 PPB
24-47A Hall Drinking Fountain #4	8/12/16 6:19	8/16/2016	1608858-47A	LEAD	1 PPB	15 PPB
24-48A Cafeteria Drinking Fountain	8/12/16 6:21	8/16/2016	1608858-48A	LEAD	<1.0 PPB	15 PPB
24-49A Kitchen Double Sink Faucet	8/12/16 6:24	8/16/2016	1608858-49A	LEAD	<1.0 PPB	15 PPB
24-50A Kitchen Single Sink Faucet	8/12/16 6:24	8/16/2016	1608858-50A	LEAD	<1.0 PPB	15 PPB
24-51A Gymnasium Drinking Fountain	8/12/16 6:29	8/16/2016	1608858-51A	LEAD	<1.0 PPB	15 PPB
24-52A Music Room Sink Faucet	8/12/16 6:32	8/17/2016	1608858-52A	LEAD	20 PPB	15 PPB
24-53A Office Sink Faucet	8/12/16 6:42	8/16/2016	1608858-53A	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Hoover Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
--------------------------------------	-------------------	---------------	--------------	------------	---------	--------------

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 Flushed (B) Sample Data
 Hoover Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
24-52B Music Room Sink Faucet	8/12/16 6:33 AM	9/2/2016	1608859-52A	LEAD	2 PPB	15 PPB
EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level						