

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Houck Middle School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
25-01A	Boys Locker Room Drinking Fountain	7/25/16 9:08 AM	7/31/16	1607C18-01A	COPPER	0.5 PPM	1.3 PPM
25-02A	Locker Room Hall Drinking Fountain	7/25/16 9:11 AM	7/31/16	1607C18-02A	COPPER	0.8 PPM	1.3 PPM
25-03A	Girls Locker Room Drinking Fountain	7/25/16 9:16 AM	7/31/16	1607C18-03A	COPPER	0.8 PPM	1.3 PPM
25-04A	Gymnasium Drinking Fountain (North)	7/25/16 9:20 AM	7/31/16	1607C18-04A	COPPER	0.6 PPM	1.3 PPM
25-05A	Gymnasium Drinking Fountain (East)	7/25/16 9:22 AM	7/31/16	1607C18-05A	COPPER	0.5 PPM	1.3 PPM
25-06A	Auxillary Gymnasium Drinking Fountain	7/25/16 9:27 AM	7/31/16	1607C18-06A	COPPER	0.6 PPM	1.3 PPM
25-07A	Room 125 Drinking Fountain	7/25/16 9:31 AM	7/31/16	1607C18-07A	COPPER	0.7 PPM	1.3 PPM
25-08A	Room 123 Sink Faucet	7/25/16 9:34 AM	7/31/16	1607C18-08A	COPPER	0.5 PPM	1.3 PPM
25-09A	Room 122 Sink Faucet 1	7/25/16 9:39 AM	7/31/16	1607C18-09A	COPPER	0.3 PPM	1.3 PPM
25-10A	Room 122 Sink Faucet 2	7/25/16 9:41 AM	7/31/16	1607C18-10A	COPPER	0.3 PPM	1.3 PPM
25-11A	Room 122 Sink Faucet 3	7/25/16 9:43 AM	7/31/16	1607C18-11A	COPPER	0.5 PPM	1.3 PPM
25-12A	Room 122 Sink Faucet 4	7/25/16 9:44 AM	7/31/16	1607C18-12A	COPPER	0.3 PPM	1.3 PPM
25-13A	Room 122 Sink Faucet 5	7/25/16 9:45 AM	7/31/16	1607C18-13A	COPPER	0.6 PPM	1.3 PPM
25-14A	Room 122 Sink Faucet 6	7/25/16 9:49 AM	7/31/16	1607C18-14A	COPPER	0.6 PPM	1.3 PPM
25-15A	Band Room 126 Drinking Fountain	7/25/16 9:53 AM	7/31/16	1607C18-15A	COPPER	0.3 PPM	1.3 PPM
25-16A	Choir Room 127 Drinking Fountain	7/25/16 9:55 AM	7/31/16	1607C18-16A	COPPER	0.5 PPM	1.3 PPM
25-17A	Student Store Drinking Fountain	7/25/16 9:58 AM	7/31/16	1607C18-17A	COPPER	0.6 PPM	1.3 PPM
25-18A	Student Store Sink Faucet	7/25/16 10:00 AM	7/31/16	1607C18-18A	COPPER	0.4 PPM	1.3 PPM
25-19A	Cafeteria Sink Faucet	7/25/16 10:24 AM	7/31/16	1607C18-19A	COPPER	0.3 PPM	1.3 PPM
25-20A	Cafeteria Ice Machine	7/25/16 10:28 AM	7/31/16	1607C18-20A	COPPER	<0.005 PPM	1.3 PPM
25-21A	Staff Room Sink Faucet	7/25/16 10:31 AM	7/31/16	1607C18-21A	COPPER	0.4 PPM	1.3 PPM
25-22A	Main Hall Drinking Fountain (Left)	7/25/16 10:35 AM	7/31/16	1607C18-22A	COPPER	0.4 PPM	1.3 PPM
25-23A	Main Hall Drinking Fountain (Right)	7/25/16 10:37 AM	7/31/16	1607C18-23A	COPPER	0.3 PPM	1.3 PPM
25-24A	Room 129 Sink Faucet	7/25/16 10:43 AM	7/31/16	1607C18-24A	COPPER	0.4 PPM	1.3 PPM
25-25A	Room 129 Drinking Fountain	7/25/16 10:43 AM	7/31/16	1607C18-25A	COPPER	0.5 PPM	1.3 PPM
25-26A	Room 121 Sink Faucet	7/25/16 10:48 AM	7/31/16	1607C18-26A	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools
 Copper Water Sampling Results
 First Draw (A) Sample Data
 Houck Middle School

25-27A	Room 121 Drinking Fountain	7/25/16 10:48 AM	7/31/16	1607C18-27A	COPPER	0.4	PPM	1.3 PPM
25-28A	Room 120 Sink Faucet	7/25/16 10:52 AM	7/31/16	1607C18-28A	COPPER	0.4	PPM	1.3 PPM
25-29A	Room 120 Drinking Fountain	7/25/16 10:53 AM	7/31/16	1607C18-29A	COPPER	0.2	PPM	1.3 PPM
25-30A	Main Office Sink Faucet	7/25/16 10:57 AM	7/31/16	1607C18-30A	COPPER	0.7	PPM	1.3 PPM
25-31A	Health Room Sink Faucet	7/25/16 10:59 AM	7/31/16	1607C18-31A	COPPER	0.4	PPM	1.3 PPM
25-32A	Conference Room Sink Faucet	7/25/16 11:03 AM	7/31/16	1607C18-32A	COPPER	0.6	PPM	1.3 PPM
25-33A	Teachers Library Sink Faucet	7/25/16 11:08 AM	7/31/16	1607C18-33A	COPPER	0.4	PPM	1.3 PPM
25-34A	Media Center Work Room Sink Faucet	7/25/16 11:10 AM	7/31/16	1607C18-34A	COPPER	0.4	PPM	1.3 PPM
25-35A	Registrar Office Sink Faucet	7/25/16 11:16 AM	7/31/16	1607C18-35A	COPPER	0.7	PPM	1.3 PPM
25-36A	Room 117 Sink Faucet	7/25/16 11:18 AM	7/31/16	1607C18-36A	COPPER	0.7	PPM	1.3 PPM
25-37A	Room 117 Drinking Fountain	7/25/16 11:50 AM	7/31/16	1607C18-37A	COPPER	0.4	PPM	1.3 PPM
25-38A	Room 118 Sink Faucet	7/25/16 11:53 AM	7/31/16	1607C18-38A	COPPER	0.4	PPM	1.3 PPM
25-39A	Room 118 Drinking Fountain	7/25/16 11:53 AM	7/31/16	1607C18-39A	COPPER	0.2	PPM	1.3 PPM
25-40A	Room 101 Sink Faucet	7/25/16 11:58 AM	7/31/16	1607C18-40A	COPPER	0.4	PPM	1.3 PPM
25-41A	Room 116 Sink Faucet	7/25/16 11:59 AM	7/31/16	1607C18-41A	COPPER	0.5	PPM	1.3 PPM
25-42A	Room 110 Sink Faucet	7/25/16 12:03 PM	7/31/16	1607C18-42A	COPPER	0.5	PPM	1.3 PPM
25-43A	Room 110 Drinking Fountain	7/25/16 12:03 PM	7/31/16	1607C18-43A	COPPER	0.4	PPM	1.3 PPM
25-44A	Room 111 Sink Faucet	7/25/16 12:12 PM	7/31/16	1607C18-44A	COPPER	0.5	PPM	1.3 PPM
25-45A	Room 111 Drinking Fountain	7/25/16 12:13 PM	7/31/16	1607C18-45A	COPPER	0.4	PPM	1.3 PPM
25-46A	Room 115 Sink Faucet	7/25/16 12:16 PM	7/31/16	1607C18-46A	COPPER	0.6	PPM	1.3 PPM
25-47A	Room 115 Drinking Fountain	7/25/16 12:16 PM	7/31/16	1607C18-47A	COPPER	0.6	PPM	1.3 PPM
25-48A	Science Lab Hall Drinking Fountain (Left)	7/25/16 12:19 PM	7/31/16	1607C18-48A	COPPER	0.9	PPM	1.3 PPM
25-49A	Science Lab Hall Drinking Fountain (Right)	7/25/16 12:20 PM	7/31/16	1607C18-49A	COPPER	0.9	PPM	1.3 PPM
25-50A	Room 109 Sink Faucet	7/25/16 12:24 PM	7/31/16	1607C18-50A	COPPER	0.5	PPM	1.3 PPM
25-51A	Room 109 Drinking Fountain	7/25/16 12:25 PM	7/31/16	1607C18-51A	COPPER	0.4	PPM	1.3 PPM
25-52A	Room 108 Sink Faucet	7/25/16 12:41 PM	7/31/16	1607C18-52A	COPPER	0.4	PPM	1.3 PPM
25-53A	Room 108 Drinking Fountain	7/25/16 12:41 PM	7/31/16	1607C18-53A	COPPER	0.4	PPM	1.3 PPM
25-54A	Room 103 Sink Faucet	7/25/16 12:45 PM	7/31/16	1607C18-54A	COPPER	0.5	PPM	1.3 PPM
25-55A	Room 103 Drinking Fountain	7/25/16 12:45 PM	7/31/16	1607C18-55A	COPPER	0.4	PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Houck Middle School

25-56A	Room 104 Sink Faucet	7/25/16 12:48 PM	7/31/16	1607C18-56A	COPPER	0.6	PPM	1.3 PPM
25-57A	Room 104 Drinking Fountain	7/25/16 12:48 PM	7/31/16	1607C18-57A	COPPER	0.5	PPM	1.3 PPM
25-58A	Room 105 Sink Faucet	7/25/16 12:52 PM	7/31/16	1607C18-58A	COPPER	0.5	PPM	1.3 PPM
25-59A	Room 105 Drinking Fountain	7/25/16 12:52 PM	7/31/16	1607C18-59A	COPPER	0.3	PPM	1.3 PPM
25-60A	B Wing Hall Drinking Fountain	7/25/16 12:56 PM	7/31/16	1607C18-60A	COPPER	1.0	PPM	1.3 PPM
25-61A	B Wing Hall Fountain	7/25/16 12:57 PM	7/31/16	1607C18-61A	COPPER	0.9	PPM	1.3 PPM
25-62A	Room 106 Sink Faucet	7/25/16 1:01 PM	7/31/16	1607C18-62A	COPPER	0.5	PPM	1.3 PPM
25-63A	Room 106 Drinking Fountain	7/25/16 1:01 PM	7/31/16	1607C18-63A	COPPER	0.3	PPM	1.3 PPM
25-64A	Room 107 Sink Faucet	7/25/16 1:05 PM	7/31/16	1607C18-64A	COPPER	0.7	PPM	1.3 PPM
25-65A	Room 107 Drinking Fountain	7/25/16 1:05 PM	7/31/16	1607C18-65A	COPPER	0.5	PPM	1.3 PPM
25-66A	Room 207 Sink Faucet	7/25/16 2:14 PM	7/31/16	1607C18-66A	COPPER	0.4	PPM	1.3 PPM
25-67A	Room 207 Drinking Fountain	7/25/16 2:14 PM	7/31/16	1607C18-67A	COPPER	0.4	PPM	1.3 PPM
25-68A	Room 206 Sink Faucet	7/25/16 2:16 PM	7/31/16	1607C18-68A	COPPER	0.5	PPM	1.3 PPM
25-69A	Room 206 Drinking Fountain	7/25/16 2:16 PM	7/31/16	1607C18-69A	COPPER	0.4	PPM	1.3 PPM
25-70A	2nd Floor East Hall Drinking Fountain (Left)	7/25/16 2:20 PM	7/31/16	1607C18-70A	COPPER	0.7	PPM	1.3 PPM
25-71A	2nd Floor East Hall Drinking Fountain (Right)	7/25/16 2:21 PM	7/31/16	1607C18-71A	COPPER	0.5	PPM	1.3 PPM
25-72A	Room 205 Sink Faucet	7/25/16 2:27 PM	7/31/16	1607C18-72A	COPPER	0.5	PPM	1.3 PPM
25-73A	Room 205 Drinking Fountain	7/25/16 2:27 PM	7/31/16	1607C18-73A	COPPER	0.4	PPM	1.3 PPM
25-74A	Room 204 Sink Faucet	7/25/16 2:29 PM	7/31/16	1607C18-74A	COPPER	0.5	PPM	1.3 PPM
25-75A	Room 204 Drinking Fountain	7/25/16 2:29 PM	7/31/16	1607C18-75A	COPPER	0.4	PPM	1.3 PPM
25-76A	Room 203 Sink Faucet	7/25/16 2:32 PM	7/31/16	1607C18-76A	COPPER	0.5	PPM	1.3 PPM
25-77A	Room 203 Drinking Fountain	7/25/16 2:32 PM	7/31/16	1607C18-77A	COPPER	0.4	PPM	1.3 PPM
25-78A	Room 208 Sink Faucet	7/25/16 2:36 PM	7/31/16	1607C18-78A	COPPER	0.6	PPM	1.3 PPM
25-79A	Room 208 Drinking Fountain	7/25/16 2:36 PM	7/31/16	1607C18-79A	COPPER	0.4	PPM	1.3 PPM
25-80A	Room 209 Sink Faucet	7/25/16 2:40 PM	7/31/16	1607C18-80A	COPPER	0.4	PPM	1.3 PPM
25-81A	Room 209 Drinking Fountain	7/25/16 2:40 PM	8/1/16	1607C18-81A	COPPER	0.3	PPM	1.3 PPM
25-82A	Room 207 Sink Faucet	7/25/16 2:46 PM	8/1/16	1607C18-82A	COPPER	0.4	PPM	1.3 PPM
25-83A	Room 208 Sink Faucet	7/25/16 2:48 PM	8/1/16	1607C18-83A	COPPER	0.3	PPM	1.3 PPM
25-84A	Room 210 Sink Faucet	7/25/16 2:55 PM	8/1/16	1607C18-84A	COPPER	0.4	PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Houck Middle School

25-85A	Room 210 Drinking Fountain	7/25/16 2:55 PM	8/1/16	1607C18-85A	COPPER	0.3	PPM	1.3 PPM
25-86A	Room 211 Sink Faucet	7/25/16 2:58 PM	8/1/16	1607C18-86A	COPPER	0.5	PPM	1.3 PPM
25-87A	Room 211 Drinking Fountain	7/25/16 2:58 PM	8/1/16	1607C18-87A	COPPER	0.4	PPM	1.3 PPM
25-88A	Room 216 Sink Faucet	7/25/16 3:02 PM	8/1/16	1607C18-88A	COPPER	0.5	PPM	1.3 PPM
25-89A	Room 216 Drinking Fountain	7/25/16 3:02 PM	8/1/16	1607C18-89A	COPPER	0.4	PPM	1.3 PPM
25-90A	Room 215 Sink Faucet	7/25/16 3:06 PM	8/1/16	1607C18-90A	COPPER	0.4	PPM	1.3 PPM
25-91A	Room 215 Drinking Fountain	7/25/16 3:06 PM	8/1/16	1607C18-91A	COPPER	0.4	PPM	1.3 PPM
25-92A	Room 214 Sink Faucet	7/25/16 3:09 PM	8/1/16	1607C18-92A	COPPER	0.5	PPM	1.3 PPM
25-93A	Room 214 Drinking Fountain	7/25/16 3:09 PM	8/1/16	1607C18-93A	COPPER	0.4	PPM	1.3 PPM
25-94A	2nd Floor West Hall Drinking Fountain	7/25/16 3:14 PM	8/1/16	1607C18-94A	COPPER	0.6	PPM	1.3 PPM
25-95A	2nd Floor West Hall Drinking Fountain	7/25/16 3:15 PM	8/1/16	1607C18-95A	COPPER	0.5	PPM	1.3 PPM
25-96A	Room 213 Sink Faucet	7/25/16 3:17 PM	8/1/16	1607C18-96A	COPPER	0.5	PPM	1.3 PPM
25-97A	Room 213 Drinking Fountain	7/25/16 3:17 PM	8/1/16	1607C18-97A	COPPER	0.4	PPM	1.3 PPM
25-98A	Room 212 Sink Faucet	7/25/16 3:20 PM	8/1/16	1607C18-98A	COPPER	0.4	PPM	1.3 PPM
25-99A	Room 212 Drinking Fountain	7/25/16 3:20 PM	8/1/16	1607C18-99A	COPPER	0.4	PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level