

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Houck Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
25-01A Boys Locker Room Drinking Fountain	7/25/16 9:08 AM	7/31/16	1607C18-01A	LEAD	<1.0 PPB	15 PPB
25-02A Locker Room Hall Drinking Fountain	7/25/16 9:11 AM	7/31/16	1607C18-02A	LEAD	<1.0 PPB	15 PPB
25-03A Girls Locker Room Drinking Fountain	7/25/16 9:16 AM	7/31/16	1607C18-03A	LEAD	2 PPB	15 PPB
25-04A Gymnasium Drinking Fountain (North)	7/25/16 9:20 AM	7/31/16	1607C18-04A	LEAD	1 PPB	15 PPB
25-05A Gymnasium Drinking Fountain (East)	7/25/16 9:22 AM	7/31/16	1607C18-05A	LEAD	2 PPB	15 PPB
25-06A Auxillary Gymnasium Drinking Fountain	7/25/16 9:27 AM	7/31/16	1607C18-06A	LEAD	1 PPB	15 PPB
25-07A Room 125 Drinking Fountain	7/25/16 9:31 AM	7/31/16	1607C18-07A	LEAD	<1.0 PPB	15 PPB
25-08A Room 123 Sink Faucet	7/25/16 9:34 AM	7/31/16	1607C18-08A	LEAD	2 PPB	15 PPB
25-09A Room 122 Sink Faucet 1	7/25/16 9:39 AM	7/31/16	1607C18-09A	LEAD	3 PPB	15 PPB
25-10A Room 122 Sink Faucet 2	7/25/16 9:41 AM	7/31/16	1607C18-10A	LEAD	2 PPB	15 PPB
25-11A Room 122 Sink Faucet 3	7/25/16 9:43 AM	7/31/16	1607C18-11A	LEAD	5 PPB	15 PPB
25-12A Room 122 Sink Faucet 4	7/25/16 9:44 AM	7/31/16	1607C18-12A	LEAD	4 PPB	15 PPB
25-13A Room 122 Sink Faucet 5	7/25/16 9:45 AM	7/31/16	1607C18-13A	LEAD	7 PPB	15 PPB
25-14A Room 122 Sink Faucet 6	7/25/16 9:49 AM	7/31/16	1607C18-14A	LEAD	<1.0 PPB	15 PPB
25-15A Band Room 126 Drinking Fountain	7/25/16 9:53 AM	7/31/16	1607C18-15A	LEAD	1 PPB	15 PPB
25-16A Choir Room 127 Drinking Fountain	7/25/16 9:55 AM	7/31/16	1607C18-16A	LEAD	<1.0 PPB	15 PPB
25-17A Student Store Drinking Fountain	7/25/16 9:58 AM	7/31/16	1607C18-17A	LEAD	1 PPB	15 PPB
25-18A Student Store Sink Faucet	7/25/16 10:00 AM	7/31/16	1607C18-18A	LEAD	5 PPB	15 PPB
25-19A Cafeteria Sink Faucet	7/25/16 10:24 AM	7/31/16	1607C18-19A	LEAD	4 PPB	15 PPB
25-20A Cafeteria Ice Machine	7/25/16 10:28 AM	7/31/16	1607C18-20A	LEAD	<1.0 PPB	15 PPB
25-21A Staff Room Sink Faucet	7/25/16 10:31 AM	7/31/16	1607C18-21A	LEAD	10 PPB	15 PPB
25-22A Main Hall Drinking Fountain (Left)	7/25/16 10:35 AM	7/31/16	1607C18-22A	LEAD	2 PPB	15 PPB
25-23A Main Hall Drinking Fountain (Right)	7/25/16 10:37 AM	7/31/16	1607C18-23A	LEAD	1 PPB	15 PPB
25-24A Room 129 Sink Faucet	7/25/16 10:43 AM	7/31/16	1607C18-24A	LEAD	2 PPB	15 PPB
25-25A Room 129 Drinking Fountain	7/25/16 10:43 AM	7/31/16	1607C18-25A	LEAD	<1.0 PPB	15 PPB
25-26A Room 121 Sink Faucet	7/25/16 10:48 AM	7/31/16	1607C18-26A	LEAD	1 PPB	15 PPB
25-27A Room 121 Drinking Fountain	7/25/16 10:48 AM	7/31/16	1607C18-27A	LEAD	5 PPB	15 PPB
25-28A Room 120 Sink Faucet	7/25/16 10:52 AM	7/31/16	1607C18-28A	LEAD	6 PPB	15 PPB
25-29A Room 120 Drinking Fountain	7/25/16 10:53 AM	7/31/16	1607C18-29A	LEAD	3 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Houck Middle School

25-30A	Main Office Sink Faucet	7/25/16 10:57 AM	7/31/16	1607C18-30A	LEAD	2	PPB	15 PPB
25-31A	Health Room Sink Faucet	7/25/16 10:59 AM	7/31/16	1607C18-31A	LEAD	2	PPB	15 PPB
25-32A	Conference Room Sink Faucet	7/25/16 11:03 AM	7/31/16	1607C18-32A	LEAD	5	PPB	15 PPB
25-33A	Teachers Library Sink Faucet	7/25/16 11:08 AM	7/31/16	1607C18-33A	LEAD	8	PPB	15 PPB
25-34A	Media Center Work Room Sink Faucet	7/25/16 11:10 AM	7/31/16	1607C18-34A	LEAD	2	PPB	15 PPB
25-35A	Registrar Office Sink Faucet	7/25/16 11:16 AM	7/31/16	1607C18-35A	LEAD	2	PPB	15 PPB
25-36A	Room 117 Sink Faucet	7/25/16 11:18 AM	7/31/16	1607C18-36A	LEAD	3	PPB	15 PPB
25-37A	Room 117 Drinking Fountain	7/25/16 11:50 AM	7/31/16	1607C18-37A	LEAD	<1.0	PPB	15 PPB
25-38A	Room 118 Sink Faucet	7/25/16 11:53 AM	7/31/16	1607C18-38A	LEAD	2	PPB	15 PPB
25-39A	Room 118 Drinking Fountain	7/25/16 11:53 AM	7/31/16	1607C18-39A	LEAD	<1.0	PPB	15 PPB
25-40A	Room 101 Sink Faucet	7/25/16 11:58 AM	7/31/16	1607C18-40A	LEAD	7	PPB	15 PPB
25-41A	Room 116 Sink Faucet	7/25/16 11:59 AM	7/31/16	1607C18-41A	LEAD	3	PPB	15 PPB
25-42A	Room 110 Sink Faucet	7/25/16 12:03 PM	7/31/16	1607C18-42A	LEAD	6	PPB	15 PPB
25-43A	Room 110 Drinking Fountain	7/25/16 12:03 PM	7/31/16	1607C18-43A	LEAD	2	PPB	15 PPB
25-44A	Room 111 Sink Faucet	7/25/16 12:12 PM	7/31/16	1607C18-44A	LEAD	2	PPB	15 PPB
25-45A	Room 111 Drinking Fountain	7/25/16 12:13 PM	7/31/16	1607C18-45A	LEAD	1	PPB	15 PPB
25-46A	Room 115 Sink Faucet	7/25/16 12:16 PM	7/31/16	1607C18-46A	LEAD	6	PPB	15 PPB
25-47A	Room 115 Drinking Fountain	7/25/16 12:16 PM	7/31/16	1607C18-47A	LEAD	2	PPB	15 PPB
25-48A	Science Lab Hall Drinking Fountain (Left)	7/25/16 12:19 PM	7/31/16	1607C18-48A	LEAD	<1.0	PPB	15 PPB
25-49A	Science Lab Hall Drinking Fountain (Right)	7/25/16 12:20 PM	7/31/16	1607C18-49A	LEAD	1	PPB	15 PPB
25-50A	Room 109 Sink Faucet	7/25/16 12:24 PM	7/31/16	1607C18-50A	LEAD	3	PPB	15 PPB
25-51A	Room 109 Drinking Fountain	7/25/16 12:25 PM	7/31/16	1607C18-51A	LEAD	2	PPB	15 PPB
25-52A	Room 108 Sink Faucet	7/25/16 12:41 PM	7/31/16	1607C18-52A	LEAD	5	PPB	15 PPB
25-53A	Room 108 Drinking Fountain	7/25/16 12:41 PM	7/31/16	1607C18-53A	LEAD	3	PPB	15 PPB
25-54A	Room 103 Sink Faucet	7/25/16 12:45 PM	7/31/16	1607C18-54A	LEAD	4	PPB	15 PPB
25-55A	Room 103 Drinking Fountain	7/25/16 12:45 PM	7/31/16	1607C18-55A	LEAD	3	PPB	15 PPB
25-56A	Room 104 Sink Faucet	7/25/16 12:48 PM	7/31/16	1607C18-56A	LEAD	4	PPB	15 PPB
25-57A	Room 104 Drinking Fountain	7/25/16 12:48 PM	7/31/16	1607C18-57A	LEAD	3	PPB	15 PPB
25-58A	Room 105 Sink Faucet	7/25/16 12:52 PM	7/31/16	1607C18-58A	LEAD	4	PPB	15 PPB
25-59A	Room 105 Drinking Fountain	7/25/16 12:52 PM	7/31/16	1607C18-59A	LEAD	2	PPB	15 PPB
25-60A	B Wing Hall Drinking Fountain	7/25/16 12:56 PM	7/31/16	1607C18-60A	LEAD	<1.0	PPB	15 PPB
25-61A	B Wing Hall Fountain	7/25/16 12:57 PM	7/31/16	1607C18-61A	LEAD	<1.0	PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Houck Middle School

25-62A	Room 106 Sink Faucet	7/25/16 1:01 PM	7/31/16	1607C18-62A	LEAD	4	PPB	15 PPB
25-63A	Room 106 Drinking Fountain	7/25/16 1:01 PM	7/31/16	1607C18-63A	LEAD	2	PPB	15 PPB
25-64A	Room 107 Sink Faucet	7/25/16 1:05 PM	7/31/16	1607C18-64A	LEAD	3	PPB	15 PPB
25-65A	Room 107 Drinking Fountain	7/25/16 1:05 PM	7/31/16	1607C18-65A	LEAD	3	PPB	15 PPB
25-66A	Room 207 Sink Faucet	7/25/16 2:14 PM	7/31/16	1607C18-66A	LEAD	4	PPB	15 PPB
25-67A	Room 207 Drinking Fountain	7/25/16 2:14 PM	7/31/16	1607C18-67A	LEAD	4	PPB	15 PPB
25-68A	Room 206 Sink Faucet	7/25/16 2:16 PM	7/31/16	1607C18-68A	LEAD	4	PPB	15 PPB
25-69A	Room 206 Drinking Fountain	7/25/16 2:16 PM	7/31/16	1607C18-69A	LEAD	1	PPB	15 PPB
25-70A	2nd Floor East Hall Drinking Fountain (Left)	7/25/16 2:20 PM	7/31/16	1607C18-70A	LEAD	<1.0	PPB	15 PPB
25-71A	2nd Floor East Hall Drinking Fountain (Right)	7/25/16 2:21 PM	7/31/16	1607C18-71A	LEAD	<1.0	PPB	15 PPB
25-72A	Room 205 Sink Faucet	7/25/16 2:27 PM	7/31/16	1607C18-72A	LEAD	6	PPB	15 PPB
25-73A	Room 205 Drinking Fountain	7/25/16 2:27 PM	7/31/16	1607C18-73A	LEAD	3	PPB	15 PPB
25-74A	Room 204 Sink Faucet	7/25/16 2:29 PM	7/31/16	1607C18-74A	LEAD	6	PPB	15 PPB
25-75A	Room 204 Drinking Fountain	7/25/16 2:29 PM	7/31/16	1607C18-75A	LEAD	2	PPB	15 PPB
25-76A	Room 203 Sink Faucet	7/25/16 2:32 PM	7/31/16	1607C18-76A	LEAD	5	PPB	15 PPB
25-77A	Room 203 Drinking Fountain	7/25/16 2:32 PM	7/31/16	1607C18-77A	LEAD	3	PPB	15 PPB
25-78A	Room 208 Sink Faucet	7/25/16 2:36 PM	7/31/16	1607C18-78A	LEAD	6	PPB	15 PPB
25-79A	Room 208 Drinking Fountain	7/25/16 2:36 PM	7/31/16	1607C18-79A	LEAD	2	PPB	15 PPB
25-80A	Room 209 Sink Faucet	7/25/16 2:40 PM	7/31/16	1607C18-80A	LEAD	5	PPB	15 PPB
25-81A	Room 209 Drinking Fountain	7/25/16 2:40 PM	8/1/16	1607C18-81A	LEAD	3	PPB	15 PPB
25-82A	Room 207 Sink Faucet	7/25/16 2:46 PM	8/1/16	1607C18-82A	LEAD	6	PPB	15 PPB
25-83A	Room 208 Sink Faucet	7/25/16 2:48 PM	8/1/16	1607C18-83A	LEAD	6	PPB	15 PPB
25-84A	Room 210 Sink Faucet	7/25/16 2:55 PM	8/1/16	1607C18-84A	LEAD	6	PPB	15 PPB
25-85A	Room 210 Drinking Fountain	7/25/16 2:55 PM	8/1/16	1607C18-85A	LEAD	3	PPB	15 PPB
25-86A	Room 211 Sink Faucet	7/25/16 2:58 PM	8/1/16	1607C18-86A	LEAD	8	PPB	15 PPB
25-87A	Room 211 Drinking Fountain	7/25/16 2:58 PM	8/1/16	1607C18-87A	LEAD	6	PPB	15 PPB
25-88A	Room 216 Sink Faucet	7/25/16 3:02 PM	8/1/16	1607C18-88A	LEAD	9	PPB	15 PPB
25-89A	Room 216 Drinking Fountain	7/25/16 3:02 PM	8/1/16	1607C18-89A	LEAD	9	PPB	15 PPB
25-90A	Room 215 Sink Faucet	7/25/16 3:06 PM	8/1/16	1607C18-90A	LEAD	4	PPB	15 PPB
25-91A	Room 215 Drinking Fountain	7/25/16 3:06 PM	8/1/16	1607C18-91A	LEAD	4	PPB	15 PPB
25-92A	Room 214 Sink Faucet	7/25/16 3:09 PM	8/1/16	1607C18-92A	LEAD	9	PPB	15 PPB
25-93A	Room 214 Drinking Fountain	7/25/16 3:09 PM	8/1/16	1607C18-93A	LEAD	2	PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Houck Middle School

25-94A	2nd Floor West Hall Drinking Fountain	7/25/16 3:14 PM	8/1/16	1607C18-94A	LEAD	<1.0	PPB	15 PPB
25-95A	2nd Floor West Hall Drinking Fountain	7/25/16 3:15 PM	8/1/16	1607C18-95A	LEAD	<1.0	PPB	15 PPB
25-96A	Room 213 Sink Faucet	7/25/16 3:17 PM	8/1/16	1607C18-96A	LEAD	6	PPB	15 PPB
25-97A	Room 213 Drinking Fountain	7/25/16 3:17 PM	8/1/16	1607C18-97A	LEAD	2	PPB	15 PPB
25-98A	Room 212 Sink Faucet	7/25/16 3:20 PM	8/1/16	1607C18-98A	LEAD	2	PPB	15 PPB
25-99A	Room 212 Drinking Fountain	7/25/16 3:20 PM	8/1/16	1607C18-99A	LEAD	4	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level