

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
028-01A Hallway Drinking Fountain 1	7/29/16 11:45	8/11/16 11:22	608013201	LEAD	< 1 PPB	15 PPB
028-02A Boys Lockers Drinking Fountain	7/29/16 11:48	8/11/16 11:23	608013202	LEAD	1 PPB	15 PPB
028-03A Gymnasium Drinking Fountain	7/29/16 11:50	8/11/16 11:21	608013203	LEAD	< 1 PPB	15 PPB
028-04A Gymnasium Drinking Fountain	7/29/16 11:52	8/11/16 11:21	608013204	LEAD	5 PPB	15 PPB
028-05A Girls Lockers Drinking Fountain	7/29/16 11:54	8/11/16 11:21	608013205	LEAD	1 PPB	15 PPB
028-06A Auxillary Gymnasium Drinking Fountain	7/29/16 11:59	8/11/16 11:21	608013206	LEAD	3 PPB	15 PPB
028-07A Auxillary Gymnasium Drinking Fountain	7/29/16 12:00	8/11/16 11:22	608013207	LEAD	< 1 PPB	15 PPB
028-08A Hallway Drinking Fountain 2	7/29/16 12:05	8/11/16 11:22	608013208	LEAD	1 PPB	15 PPB
028-12A Staff Lounge Sink Faucet	7/29/16 12:12	8/11/16 11:22	608013209	LEAD	2 PPB	15 PPB
028-13A Classroom 105 Sink Faucet	7/29/16 12:15	8/11/16 11:22	608013210	LEAD	5 PPB	15 PPB
028-14A Classroom 105 Drinking Fountain	7/29/16 12:15	8/11/16 11:23	608013211	LEAD	< 1 PPB	15 PPB
028-15A Classroom 102 Sink Faucet	7/29/16 12:19	8/11/16 11:23	608013212	LEAD	< 1 PPB	15 PPB
028-16A Classroom 102 Drinking Fountain	7/29/16 12:19	8/11/16 11:25	608013213	LEAD	< 1 PPB	15 PPB
028-17A Office Conference Sink Faucet	7/29/16 12:23	8/11/16 11:23	608013214	LEAD	3 PPB	15 PPB
028-18A Library Break Area Sink Faucet	7/29/16 12:27	8/11/16 11:23	608013215	LEAD	2 PPB	15 PPB
028-19A Hallway Drinking Fountain 5	7/29/16 12:31	8/11/16 11:23	608013216	LEAD	3 PPB	15 PPB
028-20A Classroom 410 Sink Faucet	7/29/16 12:34	8/11/16 11:23	608013217	LEAD	< 1 PPB	15 PPB
028-21A Classroom 410 Drinking Fountain	7/29/16 12:34	8/11/16 11:23	608013218	LEAD	2 PPB	15 PPB
028-22A Home Economics Sink Faucet (1)	7/29/16 12:40	8/11/16 11:24	608013219	LEAD	6 PPB	15 PPB
028-23A Home Economics Sink Faucet (2)	7/29/16 12:41	8/11/16 11:24	608013220	LEAD	2 PPB	15 PPB
028-24A Home Economics Sink Faucet (3)	7/29/16 12:42	8/11/16 11:24	608013221	LEAD	2 PPB	15 PPB
028-25A Home Economics Sink Faucet (4)	7/29/16 12:43	8/11/16 11:24	608013222	LEAD	4 PPB	15 PPB
028-26A Home Economics Sink Faucet (5)	7/29/16 12:44	8/11/16 11:24	608013223	LEAD	4 PPB	15 PPB
028-27A Home Economics Sink Faucet (6)	7/29/16 12:45	8/11/16 11:24	608013224	LEAD	3 PPB	15 PPB
028-28A Home Economics Sink Faucet (7)	7/29/16 12:46	8/11/16 11:24	608013225	LEAD	6 PPB	15 PPB
028-29A Hallway Drinking Fountain 6	7/29/16 12:51	8/11/16 11:26	608013226	LEAD	< 1 PPB	15 PPB
028-30A Classroom 310 Sink Faucet	7/29/16 12:56	8/11/16 11:24	608013227	LEAD	4 PPB	15 PPB
028-31A Classroom 310 Drinking Fountain	7/29/16 12:56	8/11/16 11:24	608013228	LEAD	4 PPB	15 PPB
028-32A Classroom 308 Sink Faucet	7/29/16 13:00	8/11/16 11:29	608013229	LEAD	1 PPB	15 PPB
028-33A Classroom 308 Drinking Fountain	7/29/16 13:00	8/11/16 11:29	608013230	LEAD	3 PPB	15 PPB
028-34A Hallway Drinking Fountain 7	7/29/16 13:04	8/12/16 12:35	608013231	LEAD	2 PPB	15 PPB
028-35A Hallway Drinking Fountain 8	7/29/16 13:07	8/11/16 11:29	608013232	LEAD	< 1 PPB	15 PPB
028-36A Hallway Drinking Fountain 9	7/29/16 13:10	8/11/16 11:29	608013233	LEAD	1 PPB	15 PPB
028-37A Office/Health Sink Faucet	7/29/16 13:15	8/11/16 11:29	608013234	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
028-09A Cafeteria Drinking Fountain	9/22/2016 5:30	9/26/2016	57947	LEAD	<1 PPB	15 PPB
028-10A Hallway Drinking Fountain #3	9/22/2016 5:32	9/26/2016	57948	LEAD	1 PPB	15 PPB
028-11A Hallway Drinking Fountain #4	9/22/2016 5:34	9/26/2016	57949	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
028-16B Classroom 102 Drinking Fountain	7/29/16 12:20	8/25/16 11:18	608231501	LEAD	< 1 PPB	15 PPB
028-34B Hallway Drinking Fountain 7	7/29/16 13:05	8/25/16 11:19	608231502	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Judson Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
028-09C Cafeteria Drinking Fountain	1/6/2017 6:25	1/9/2017	790	LEAD	1 PPB	15 PPB
028-10C Hallway Drinking Fountain #3	1/6/2017 6:27	1/9/2017	791	LEAD	<1 PPB	15 PPB
028-11C Hallway Drinking Fountain #4	1/6/2017 6:28	1/9/2017	792	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level