

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Lake Labish Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
075-01A Health Sink Faucet	9/14/2016 6:22	9/15/2016	55846	COPPER	0.8 PPM	1.3 PPM
075-02A Faculty Lounge Sink Faucet	9/14/2016 6:26	9/15/2016	55848	COPPER	0.5 PPM	1.3 PPM
075-04A Hallway Drinking Fountain 1	9/14/2016 6:19	9/15/2016	55850	COPPER	0.4 PPM	1.3 PPM
075-05A Classroom 1 Sink Faucet	9/14/2016 6:31	9/15/2016	55852	COPPER	0.3 PPM	1.3 PPM
075-06A Classroom 2 Sink Faucet	9/14/2016 6:35	9/15/2016	55854	COPPER	0.3 PPM	1.3 PPM
075-07A Classroom 4 Sink Faucet	9/14/2016 6:42	9/15/2016	55856	COPPER	0.3 PPM	1.3 PPM
075-08A Classroom 5 Sink Faucet	9/14/2016 6:48	9/15/2016	55858	COPPER	0.3 PPM	1.3 PPM
075-09A Classroom 7 Sink Faucet	9/14/2016 6:53	9/15/2016	55860	COPPER	0.0 PPM	1.3 PPM
075-10A Classroom 6 Sink Facuet	9/14/2016 6:56	9/15/2016	55862	COPPER	0.1 PPM	1.3 PPM

EPA Action Level forCopper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Lake Labish Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
075-03A Gymnasium Drinking Fountain	9/30/2016 4:38	10/3/2016	59703	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level