

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (A) Sample Data  
 Lake Labish Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
075-01A Health Sink Faucet	9/14/2016 6:22	9/15/2016	55846	LEAD	13 PPB	15 PPB
075-02A Faculty Lounge Sink Faucet	9/14/2016 6:26	9/15/2016	55848	LEAD	3 PPB	15 PPB
075-04A Hallway Drinking Fountain 1	9/14/2016 6:19	9/15/2016	55850	LEAD	<1 PPB	15 PPB
075-05A Classroom 1 Sink Faucet	9/14/2016 6:31	9/15/2016	55852	LEAD	1 PPB	15 PPB
075-06A Classroom 2 Sink Faucet	9/14/2016 6:35	9/15/2016	55854	LEAD	3 PPB	15 PPB
075-07A Classroom 4 Sink Faucet	9/14/2016 6:42	9/15/2016	55856	LEAD	39 PPB	15 PPB
075-08A Classroom 5 Sink Faucet	9/14/2016 6:48	9/15/2016	55858	LEAD	55 PPB	15 PPB
075-09A Classroom 7 Sink Faucet	9/14/2016 6:53	9/15/2016	55860	LEAD	4 PPB	15 PPB
075-10A Classroom 6 Sink Facuet	9/14/2016 6:56	9/15/2016	55862	LEAD	15 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Lake Labish Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
075-03A Gymnasium Drinking Fountain	9/30/2016 4:38	10/3/2016	59703	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Lake Labish Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
075-07B Classroom 4 Sink Faucet	9/14/2016 6:42	9/15/2016	57693	LEAD	3 PPB	15 PPB
075-08B Classroom 5 Sink Faucet	9/14/2016 6:48	9/15/2016	57694	LEAD	7 PPB	15 PPB
075-10B Classroom 6 Sink Facuet	9/14/2016 6:56	9/15/2016	57695	LEAD	5 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level