

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Lee Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Limit
026-01A Gymnasium Drinking Fountain	8/6/16 10:04	8/15/16 9:35	608085001	LEAD	< 1 PPB	15 PPB
026-02A Kitchen Food Prep Sink Faucet	8/6/16 10:07	8/15/16 9:38	608085002	LEAD	1 PPB	15 PPB
026-03A Cafeteria Sink Faucet (Closet)	8/6/16 10:09	8/15/16 9:38	608085003	LEAD	2 PPB	15 PPB
026-04A Bathroom Drinking Fountain	8/6/16 10:13	8/15/16 9:38	608085004	LEAD	< 1 PPB	15 PPB
026-05A Bathroom Drinking Fountain	8/6/16 10:13	8/15/16 9:38	608085005	LEAD	< 1 PPB	15 PPB
026-06A Music Room Sink Faucet	8/6/16 10:16	8/15/16 9:38	608085006	LEAD	3 PPB	15 PPB
026-07A Music Room Drinking Fountain	8/6/16 10:16	8/15/16 9:38	608085007	LEAD	< 1 PPB	15 PPB
026-08A Health/Nurse Sink Faucet	8/6/16 10:20	8/15/16 9:38	608085008	LEAD	2 PPB	15 PPB
026-09A Health/Nurse Drinking Fountain	8/6/16 10:20	8/15/16 9:38	608085009	LEAD	3 PPB	15 PPB
026-10A Workroom Sink Faucet	8/6/16 10:26	8/15/16 9:38	608085010	LEAD	9 PPB	15 PPB
026-11A Workroom Drinking Fountain	8/6/16 10:26	8/15/16 9:38	608085011	LEAD	10 PPB	15 PPB
026-12A Staff Lounge Sink Faucet	8/6/16 10:29	8/15/16 9:38	608085012	LEAD	< 1 PPB	15 PPB
026-13A Classroom A-7 Drinking Fountain	8/6/16 10:33	8/15/16 9:38	608085013	LEAD	3 PPB	15 PPB
026-14A Classroom A-7 Sink Faucet	8/6/16 10:33	8/15/16 9:38	608085014	LEAD	< 1 PPB	15 PPB
026-15A Classroom A-6 Drinking Fountain	8/6/16 10:42	8/15/16 9:38	608085015	LEAD	3 PPB	15 PPB
026-16A Classroom A-6 Sink Faucet	8/6/16 10:42	8/15/16 9:38	608085016	LEAD	1 PPB	15 PPB
026-17A Classroom A-5 Drinking Fountain	8/6/16 10:44	8/15/16 9:38	608085017	LEAD	4 PPB	15 PPB
026-18A Classroom A-5 Sink Faucet	8/6/16 10:44	8/15/16 9:38	608085018	LEAD	2 PPB	15 PPB
026-19A Classroom A-4 Drinking Fountain	8/6/16 10:46	8/15/16 9:38	608085019	LEAD	4 PPB	15 PPB
026-20A Classroom A-4 Sink Faucet	8/6/16 10:46	8/15/16 9:38	608085020	LEAD	1 PPB	15 PPB
026-21A Classroom A-3 Drinking Fountain	8/6/16 10:48	8/15/16 9:38	608085021	LEAD	4 PPB	15 PPB
026-22A Classroom A-3 Sink Faucet	8/6/16 10:48	8/15/16 9:43	608085022	LEAD	2 PPB	15 PPB
026-23A Classroom A-2 Drinking Fountain	8/6/16 10:51	8/15/16 9:48	608085023	LEAD	5 PPB	15 PPB
026-24A Classroom A-2 Sink Faucet	8/6/16 10:51	8/15/16 9:48	608085024	LEAD	5 PPB	15 PPB
026-25A Classroom A-1 Drinking Fountain	8/6/16 10:53	8/15/16 9:48	608085025	LEAD	5 PPB	15 PPB
026-26A Classroom A-1 Sink Faucet	8/6/16 10:53	8/15/16 9:48	608085026	LEAD	< 1 PPB	15 PPB
026-27A Classroom B-8 Drinking Fountain	8/6/16 11:00	8/15/16 9:48	608085027	LEAD	3 PPB	15 PPB
026-28A Classroom B-8 Sink Faucet	8/6/16 11:00	8/15/16 9:48	608085028	LEAD	1 PPB	15 PPB
026-29A Classroom B-9 Drinking Fountain	8/6/16 11:02	8/15/16 9:48	608085029	LEAD	< 1 PPB	15 PPB
026-30A Classroom B-9 Sink Faucet	8/6/16 11:02	8/15/16 9:48	608085030	LEAD	1 PPB	15 PPB
026-31A Classroom B-10 Drinking Fountain	8/6/16 11:04	8/15/16 9:48	608085031	LEAD	2 PPB	15 PPB
026-32A Classroom B-10 Sink Faucet	8/6/16 11:04	8/15/16 9:49	608085032	LEAD	2 PPB	15 PPB
026-33A Classroom B-11 Drinking Fountain	8/6/16 11:06	8/15/16 9:49	608085033	LEAD	3 PPB	15 PPB
026-34A Classroom B-11 Sink Faucet	8/6/16 11:06	8/15/16 9:49	608085034	LEAD	2 PPB	15 PPB
026-35A Classroom B-12 Drinking Fountain	8/6/16 11:08	8/15/16 9:49	608085035	LEAD	3 PPB	15 PPB
026-36A Classroom B-12 Sink Faucet	8/6/16 11:08	8/15/16 9:49	608085036	LEAD	1 PPB	15 PPB
026-37A Classroom B-13 Drinking Fountain	8/6/16 11:10	8/15/16 9:49	608085037	LEAD	3 PPB	15 PPB
026-38A Classroom B-13 Sink Faucet	8/6/16 11:10	8/15/16 9:49	608085038	LEAD	5 PPB	15 PPB
026-39A Classroom C-14 Drinking Fountain	8/6/16 11:16	8/15/16 9:50	608085039	LEAD	< 1 PPB	15 PPB
026-40A Classroom C-14 Sink Faucet	8/6/16 11:16	8/15/16 9:50	608085040	LEAD	2 PPB	15 PPB
026-41A Classroom C-15 Drinking Fountain	8/6/16 11:18	8/15/16 9:50	608085041	LEAD	3 PPB	15 PPB
026-42A Classroom C-15 Sink Faucet	8/6/16 11:18	8/15/16 9:50	608085042	LEAD	2 PPB	15 PPB
026-43A Classroom C-16 Drinking Fountain	8/6/16 11:20	8/15/16 9:50	608085043	LEAD	< 1 PPB	15 PPB
026-44A Classroom C-16 Sink Faucet	8/6/16 11:20	8/15/16 9:50	608085044	LEAD	2 PPB	15 PPB
026-45A Classroom C-17 Drinking Fountain	8/6/16 11:22	8/15/16 9:50	608085045	LEAD	3 PPB	15 PPB
026-46A Classroom C-17 Sink Faucet	8/6/16 11:22	8/15/16 9:50	608085046	LEAD	2 PPB	15 PPB
026-47A Classroom C-18 Drinking Fountain	8/6/16 11:24	8/15/16 9:50	608085047	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Lee Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Limit
026-48A Classroom C-18 Sink Faucet	8/6/16 11:24	8/15/16 9:50	608085048	LEAD	1 PPB	15 PPB
026-49A Classroom C-19 Drinking Fountain	8/6/16 11:26	8/15/16 9:50	608085049	LEAD	3 PPB	15 PPB
026-50A Classroom C-19 Sink Faucet	8/6/16 11:26	8/15/16 9:50	608085050	LEAD	2 PPB	15 PPB
026-51A Cafeteria Closet Ice Maker	8/6/16 10:11	8/15/16 9:50	608085051	LEAD	2 PPB	15 PPB
026-52A Nurse/Health Ice Maker	8/6/16 10:23	8/15/16 9:50	608085052	LEAD	1 PPB	15 PPB
026-53A Staff Lounge Ice Maker	8/6/16 10:31	8/15/16 9:50	608085053	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level