

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Liberty Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
027-01A	Kitchen Food Prep Sink Faucet	7/29/16 7:28	8/5/2016	1608152-01A	LEAD	4 PPB 15 PPB
027-02A	Kitchen Food Prep Sink Faucet	7/29/16 7:29	8/5/2016	1608152-02A	LEAD	5 PPB 15 PPB
027-03A	Room 20 Sink Faucet	7/29/16 7:38	8/5/2016	1608152-03A	LEAD	4 PPB 15 PPB
027-04A	Room 20 Drinking Fountain	7/29/16 7:38	8/5/2016	1608152-04A	LEAD	2 PPB 15 PPB
027-05A	Room 21 Sink Faucet	7/29/16 7:42	8/5/2016	1608152-05A	LEAD	1 PPB 15 PPB
027-06A	Room 21 Drinking Fountain	7/29/16 7:42	8/5/2016	1608152-06A	LEAD	<1.0 PPB 15 PPB
027-07A	Room 22 Sink Faucet	7/29/16 7:45	8/5/2016	1608152-07A	LEAD	4 PPB 15 PPB
027-08A	Room 22 Drinking Fountain	7/29/16 7:45	8/5/2016	1608152-08A	LEAD	<1.0 PPB 15 PPB
027-09A	Media Break Area Sink Faucet	7/29/16 7:52	8/5/2016	1608152-09A	LEAD	2 PPB 15 PPB
027-10A	Hall Drinking Fountain 1	7/29/16 7:54	8/5/2016	1608152-10A	LEAD	4 PPB 15 PPB
027-11A	Hall Drinking Fountain 2	7/29/16 7:55	8/5/2016	1608152-11A	LEAD	1 PPB 15 PPB
027-12A	Room 14 Sink Faucet	7/29/16 7:59	8/5/2016	1608152-12A	LEAD	1 PPB 15 PPB
027-13A	Room 14 Drinking Fountain	7/29/16 7:59	8/5/2016	1608152-13A	LEAD	<1.0 PPB 15 PPB
027-14A	Room 15 Sink Faucet	7/29/16 8:01	8/5/2016	1608152-14A	LEAD	3 PPB 15 PPB
027-15A	Room 15 Drinking Fountain	7/29/16 8:01	8/5/2016	1608152-15A	LEAD	1 PPB 15 PPB
027-16A	Room 16 Sink Faucet	7/29/16 8:03	8/5/2016	1608152-16A	LEAD	1 PPB 15 PPB
027-17A	Room 16 Drinking Fountain	7/29/16 8:03	8/5/2016	1608152-17A	LEAD	<1.0 PPB 15 PPB
027-18A	Room 17 Sink Faucet	7/29/16 8:06	8/5/2016	1608152-18A	LEAD	4 PPB 15 PPB
027-19A	Room 17 Drinking Fountain	7/29/16 8:06	8/5/2016	1608152-19A	LEAD	<1.0 PPB 15 PPB
027-20A	Room 18 Sink Faucet	7/29/16 8:09	8/5/2016	1608152-20A	LEAD	3 PPB 15 PPB
027-21A	Room 18 Drinking Fountain	7/29/16 8:09	8/5/2016	1608152-21A	LEAD	1 PPB 15 PPB
027-22A	Room 19 Sink Faucet	7/29/16 8:12	8/5/2016	1608152-22A	LEAD	3 PPB 15 PPB
027-23A	Room 19 Drinking Fountain	7/29/16 8:12	8/5/2016	1608152-23A	LEAD	1 PPB 15 PPB
027-24A	Room 12 Sink Faucet	7/29/16 8:19	8/5/2016	1608152-24A	LEAD	1 PPB 15 PPB
027-25A	Room 12 Drinking Fountain	7/29/16 8:19	8/5/2016	1608152-25A	LEAD	<1.0 PPB 15 PPB
027-26A	Room 11 Sink Faucet	7/29/16 8:22	8/5/2016	1608152-26A	LEAD	5 PPB 15 PPB
027-27A	Room 11 Drinking Fountain	7/29/16 8:22	8/5/2016	1608152-27A	LEAD	<1.0 PPB 15 PPB
027-28A	Computer Lab 7 Sink Faucet	7/29/16 8:25	8/5/2016	1608152-28A	LEAD	8 PPB 15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Liberty Elementary School

027-29A	Computer Lab 7 Drinking Fountain	7/29/16 8:25	8/5/2016	1608152-29A	LEAD	<1.0 PPB	15 PPB
027-30A	Room 6 Sink Faucet	7/29/16 8:28	8/5/2016	1608152-30A	LEAD	5 PPB	15 PPB
027-31A	Room 6 Drinking Fountain	7/29/16 8:28	8/5/2016	1608152-31A	LEAD	7 PPB	15 PPB
027-32A	Room 10 Sink Faucet	7/29/16 8:31	8/5/2016	1608152-32A	LEAD	4 PPB	15 PPB
027-33A	Room 10 Drinking Fountain	7/29/16 8:31	8/5/2016	1608152-33A	LEAD	<1.0 PPB	15 PPB
027-34A	Staff Lounge Sink Faucet	7/29/16 8:33	8/5/2016	1608152-34A	LEAD	9 PPB	15 PPB
027-35A	Room 1 Sink Faucet	7/29/16 8:40	8/5/2016	1608152-35A	LEAD	6 PPB	15 PPB
027-36A	Room 1 Drinking Fountain	7/29/16 8:40	8/5/2016	1608152-36A	LEAD	1 PPB	15 PPB
027-37A	Hall Drinking Fountain 3	7/29/16 8:46	8/5/2016	1608152-37A	LEAD	2 PPB	15 PPB
027-38A	Room 2 Sink Faucet	7/29/16 8:50	8/5/2016	1608152-38A	LEAD	3 PPB	15 PPB
027-39A	Room 2 Drinking Fountain	7/29/16 8:50	8/5/2016	1608152-39A	LEAD	<1.0 PPB	15 PPB
027-40A	Room 3 Sink Faucet	7/29/16 8:54	8/5/2016	1608152-40A	LEAD	5 PPB	15 PPB
027-41A	Room 3 Drinking Fountain	7/29/16 8:54	8/5/2016	1608152-41A	LEAD	4 PPB	15 PPB
027-42A	Room 5 Sink Faucet	7/29/16 8:57	8/5/2016	1608152-42A	LEAD	1 PPB	15 PPB
027-43A	Room 5 Drinking Fountain	7/29/16 8:57	8/5/2016	1608152-43A	LEAD	<1.0 PPB	15 PPB
027-44A	Room 4 Sink Faucet	7/29/16 9:00	8/5/2016	1608152-44A	LEAD	2 PPB	15 PPB
027-45A	Room 4 Drinking Fountain	7/29/16 9:00	8/5/2016	1608152-45A	LEAD	2 PPB	15 PPB
027-46A	Room 23 Sink Faucet	7/29/16 9:07	8/5/2016	1608152-46A	LEAD	1 PPB	15 PPB
027-47A	Hall Drinking Fountain 4	7/29/16 9:09	8/5/2016	1608152-47A	LEAD	<1.0 PPB	15 PPB
027-48A	Music Room Sink Faucet	7/29/16 9:10	8/5/2016	1608152-48A	LEAD	<1.0 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level