

Salem Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
036-01A Hallway Drinking Fountain 1	7/30/16 7:20	8/10/16 18:47	608012501	COPPER	0.4 PPM	1.3 PPM
036-02A Hallway Drinking Fountain 2	7/30/16 7:23	8/10/16 18:47	608012502	COPPER	0.2 PPM	1.3 PPM
036-03A Hallway Drinking Fountain 3	7/30/16 7:24	8/10/16 18:47	608012503	COPPER	0.3 PPM	1.3 PPM
036-04A Kitchen Water Fountain 1	7/30/16 7:27	8/10/16 18:47	608012504	COPPER	0.4 PPM	1.3 PPM
036-05A Kitchen Water Fountain 2	7/30/16 7:29	8/10/16 18:47	608012505	COPPER	0.4 PPM	1.3 PPM
036-06A Kitchen Counter Faucet	7/30/16 7:32	8/10/16 18:47	608012506	COPPER	0.4 PPM	1.3 PPM
036-07A Kitchen Ice Maker	7/30/16 7:34	8/10/16 18:47	608012507	COPPER	0.0 PPM	1.3 PPM
036-08A Kitchen Food Prep Sink Faucet 1	7/30/16 7:36	8/10/16 18:47	608012508	COPPER	0.1 PPM	1.3 PPM
036-09A Kitchen Food Prep Sink Faucet 2	7/30/16 7:38	8/10/16 18:47	608012509	COPPER	0.3 PPM	1.3 PPM
036-10A Kitchen Food Prep Sink Faucet 3	7/30/16 7:40	8/10/16 18:47	608012510	COPPER	0.2 PPM	1.3 PPM
036-11A Kitchen Food Prep Sink Faucet 4	7/30/16 7:42	8/10/16 18:47	608012511	COPPER	0.2 PPM	1.3 PPM
036-12A Kitchen Food Prep Sink Faucet 5	7/30/16 7:44	8/10/16 18:48	608012512	COPPER	0.1 PPM	1.3 PPM
036-13A Maintenance Office Sink Faucet	7/30/16 7:47	8/10/16 18:48	608012513	COPPER	0.2 PPM	1.3 PPM
036-14A Break Room Sink Faucet	7/30/16 7:49	8/10/16 18:48	608012514	COPPER	0.2 PPM	1.3 PPM
036-15A Student Store 132 Sink Faucet	7/30/16 7:53	8/10/16 18:48	608012515	COPPER	0.3 PPM	1.3 PPM
036-16A Student Store 132 Drinking Fountain	7/30/16 7:55	8/10/16 18:56	608012516	COPPER	0.5 PPM	1.3 PPM
036-17A Room 131 Sink Faucet	7/30/16 7:57	8/10/16 18:56	608012517	COPPER	0.2 PPM	1.3 PPM
036-18A Room 131 Drinking Fountain	7/30/16 7:59	8/10/16 18:56	608012518	COPPER	0.1 PPM	1.3 PPM
036-19A Room 129 Sink Faucet	7/30/16 8:02	8/10/16 18:56	608012519	COPPER	0.2 PPM	1.3 PPM
036-20A Room 129 Drinking Fountain	7/30/16 8:04	8/10/16 18:56	608012520	COPPER	0.5 PPM	1.3 PPM
036-21A Room 127 Sink Faucet	7/30/16 8:06	8/10/16 18:56	608012521	COPPER	0.2 PPM	1.3 PPM
036-22A Room 127 Drinking Fountain	7/30/16 8:08	8/10/16 18:56	608012522	COPPER	0.4 PPM	1.3 PPM
036-23A Room 128 Sink Faucet	7/30/16 8:11	8/10/16 18:56	608012523	COPPER	0.2 PPM	1.3 PPM
036-24A Room 128 Drinking Fountain	7/30/16 8:13	8/10/16 18:56	608012524	COPPER	0.1 PPM	1.3 PPM
036-25A Wood Shop 126 Drinking Fountain	7/30/16 8:17	8/10/16 18:56	608012525	COPPER	0.1 PPM	1.3 PPM
036-26A Mechanics 125 Drinking Fountain	7/30/16 8:20	8/10/16 18:56	608012526	COPPER	0.4 PPM	1.3 PPM
036-27A Hallway Drinking Fountain 4	7/30/16 8:23	8/10/16 18:56	608012527	COPPER	0.3 PPM	1.3 PPM
036-28A Hallway Drinking Fountain 5	7/30/16 8:25	8/10/16 18:56	608012528	COPPER	0.2 PPM	1.3 PPM
036-29A Agricultural 124 Drinking Fountain	7/30/16 8:30	8/10/16 18:56	608012529	COPPER	0.4 PPM	1.3 PPM
036-30A Girls Lockers Drinking Fountain	7/30/16 8:33	8/10/16 18:56	608012530	COPPER	0.2 PPM	1.3 PPM
036-31A Trainers Room Ice Maker	7/30/16 8:36	8/10/16 18:56	608012531	COPPER	< 0.005 PPM	1.3 PPM
036-32A Trainers Room Sink Faucet	7/30/16 8:38	8/10/16 18:56	608012532	COPPER	0.4 PPM	1.3 PPM
036-33A Weight Room Drinking Fountain	7/30/16 8:42	8/10/16 18:56	608012533	COPPER	0.5 PPM	1.3 PPM
036-34A Classroom 123 Sink Faucet	7/30/16 8:28	8/10/16 18:56	608012534	COPPER	0.5 PPM	1.3 PPM
036-35A Classroom 123 Drinking Fountain	7/30/16 8:30	8/10/16 18:56	608012535	COPPER	0.5 PPM	1.3 PPM
036-36A Hallway Drinking Fountain 6	7/30/16 8:23	8/10/16 18:57	608012536	COPPER	0.3 PPM	1.3 PPM
036-37A Hallway Drinking Fountain 7	7/30/16 8:35	8/10/16 18:57	608012537	COPPER	0.4 PPM	1.3 PPM
036-38A Home Ec. 109 Sink Faucet	7/30/16 8:40	8/10/16 18:57	608012538	COPPER	0.3 PPM	1.3 PPM
036-39A Home Ec. 109 Sink Faucet	7/30/16 8:42	8/10/16 18:57	608012539	COPPER	0.4 PPM	1.3 PPM
036-40A Home Ec. 109 Sink Faucet	7/30/16 8:44	8/10/16 18:57	608012540	COPPER	0.3 PPM	1.3 PPM
036-41A Home Ec. 109 Sink Faucet	7/30/16 8:46	8/10/16 18:57	608012541	COPPER	0.4 PPM	1.3 PPM
036-42A Home Ec. 109 Sink Faucet	7/30/16 8:48	8/10/16 18:57	608012542	COPPER	0.2 PPM	1.3 PPM
036-43A Home Ec. 109 Sink Faucet	7/30/16 8:50	8/10/16 18:57	608012543	COPPER	0.3 PPM	1.3 PPM
036-44A Room 105 Store Room Sink Faucet	7/30/16 8:53	8/10/16 18:57	608012544	COPPER	0.4 PPM	1.3 PPM
036-45A Room 105 Store Room Drinking Faucet	7/30/16 8:55	8/10/16 18:57	608012545	COPPER	0.4 PPM	1.3 PPM
036-46A Room 105 Sink Faucet	7/30/16 8:57	8/10/16 18:57	608012546	COPPER	0.3 PPM	1.3 PPM
036-47A Room 105 Sink Faucet	7/30/16 8:59	8/10/16 18:57	608012547	COPPER	0.2 PPM	1.3 PPM
036-48A Room 105 Sink Faucet	7/30/16 9:01	8/10/16 18:57	608012548	COPPER	0.2 PPM	1.3 PPM
036-49A Room 105 Sink Faucet	7/30/16 9:03	8/10/16 18:57	608012549	COPPER	0.2 PPM	1.3 PPM
036-50A Office Lounge Sink Faucet	7/30/16 9:09	8/10/16 18:57	608012550	COPPER	0.3 PPM	1.3 PPM
036-51A Office Lounge Drinking Faucet	7/30/16 9:11	8/10/16 18:57	608012551	COPPER	0.4 PPM	1.3 PPM
036-52A Health Office Sink Faucet	7/30/16 9:13	8/10/16 18:57	608012552	COPPER	0.6 PPM	1.3 PPM
036-53A Hallway Drinking Fountain 7	7/30/16 9:17	8/10/16 18:57	608012553	COPPER	0.3 PPM	1.3 PPM

Salem Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
036-54A Hallway Drinking Fountain 8	7/30/16 9:19	8/10/16 18:57	608012554	COPPER	0.4 PPM	1.3 PPM
036-55A Room 103 Sink Faucet	7/30/16 9:22	8/10/16 18:57	608012555	COPPER	0.4 PPM	1.3 PPM
036-56A Room 103 (Back) Sink Faucet	7/30/16 9:24	8/10/16 18:58	608012556	COPPER	0.4 PPM	1.3 PPM
036-57A Room 202 Sink Faucet	7/30/16 9:17	8/10/16 18:58	608012557	COPPER	0.3 PPM	1.3 PPM
036-58A Room 202 Drinking Fountain	7/30/16 9:19	8/10/16 18:58	608012558	COPPER	0.3 PPM	1.3 PPM
036-59A Classroom 214 Sink Faucet	7/30/16 9:21	8/10/16 18:58	608012559	COPPER	0.3 PPM	1.3 PPM
036-60A AV Breakroom Sink Faucet	7/30/16 9:24	8/10/16 18:58	608012560	COPPER	0.2 PPM	1.3 PPM
036-61A Hallway Drinking Fountain 8	7/30/16 9:27	8/10/16 18:58	608012561	COPPER	0.4 PPM	1.3 PPM
036-62A Classroom 228 Sink Faucet	7/30/16 9:30	8/10/16 18:58	608012562	COPPER	0.4 PPM	1.3 PPM
036-63A Classroom 228 Drinking Fountain	7/30/16 9:32	8/10/16 18:58	608012563	COPPER	0.5 PPM	1.3 PPM
036-64A Classroom 229 Sink Faucet	7/30/16 9:34	8/10/16 18:58	608012564	COPPER	0.1 PPM	1.3 PPM
036-65A Classroom 229 Drinking Fountain	7/30/16 9:36	8/10/16 18:58	608012565	COPPER	0.3 PPM	1.3 PPM
036-66A Hallway Drinking Fountain 9	7/30/16 9:40	8/10/16 18:58	608012566	COPPER	0.3 PPM	1.3 PPM
036-67A Hallway Drinking Fountain 10	7/30/16 9:42	8/10/16 18:58	608012567	COPPER	0.3 PPM	1.3 PPM
036-68A Hallway Drinking Fountain 11	7/30/16 9:44	8/10/16 18:58	608012568	COPPER	0.3 PPM	1.3 PPM
036-70A Room 242 Sink Faucet	7/30/16 9:52	8/10/16 18:58	608012569	COPPER	0.3 PPM	1.3 PPM
036-71A Hallway Drinking Fountain 12	7/30/16 9:47	8/10/16 18:58	608012570	COPPER	0.3 PPM	1.3 PPM
036-72A Hallway Drinking Fountain 13	7/30/16 9:49	8/10/16 18:58	608012571	COPPER	0.2 PPM	1.3 PPM
036-73A EGC Portable Sink Faucet	7/30/16 9:58	8/10/16 18:58	608012572	COPPER	0.1 PPM	1.3 PPM
036-74A Stadium Concession Sink Faucet	7/30/16 10:02	8/10/16 18:58	608012573	COPPER	0.2 PPM	1.3 PPM
036-75A 242 Drinking Fountain	7/30/16 9:54	8/10/16 18:58	608012574	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
036-76A Rm 242 Drinking Fountain	1/20/2017 6:28	1/23/2017	3132	COPPER	0.5 PPM	1.3 PPM
036-77A Theater Stage East End Sink Faucet	1/20/2017 6:25	1/23/2017	3133	COPPER	0.3 PPM	1.3 PPM
036-78A Theater Stage East End Drinking Fountain	1/20/2017 6:25	1/23/2017	3134	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
036-71B Hallway Drinking Fountain 12	7/30/16 9:48	8/26/16 11:34	608191701	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
036-71C Hallway Drinking Fountain 12	10/14/2016 6:36	10/18/2016	63254	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level