

Salem Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
036-01A Hallway Drinking Fountain 1	7/30/16 7:20	8/10/16 18:47	608012501	LEAD	< 1 PPB	15 PPB
036-02A Hallway Drinking Fountain 2	7/30/16 7:23	8/10/16 18:47	608012502	LEAD	3 PPB	15 PPB
036-03A Hallway Drinking Fountain 3	7/30/16 7:24	8/10/16 18:47	608012503	LEAD	3 PPB	15 PPB
036-04A Kitchen Water Fountain 1	7/30/16 7:27	8/10/16 18:47	608012504	LEAD	2 PPB	15 PPB
036-05A Kitchen Water Fountain 2	7/30/16 7:29	8/10/16 18:47	608012505	LEAD	7 PPB	15 PPB
036-06A Kitchen Counter Faucet	7/30/16 7:32	8/10/16 18:47	608012506	LEAD	6 PPB	15 PPB
036-07A Kitchen Ice Maker	7/30/16 7:34	8/10/16 18:47	608012507	LEAD	< 1 PPB	15 PPB
036-08A Kitchen Food Prep Sink Faucet 1	7/30/16 7:36	8/10/16 18:47	608012508	LEAD	2 PPB	15 PPB
036-09A Kitchen Food Prep Sink Faucet 2	7/30/16 7:38	8/10/16 18:47	608012509	LEAD	1 PPB	15 PPB
036-10A Kitchen Food Prep Sink Faucet 3	7/30/16 7:40	8/10/16 18:47	608012510	LEAD	7 PPB	15 PPB
036-11A Kitchen Food Prep Sink Faucet 4	7/30/16 7:42	8/10/16 18:47	608012511	LEAD	2 PPB	15 PPB
036-12A Kitchen Food Prep Sink Faucet 5	7/30/16 7:44	8/10/16 18:48	608012512	LEAD	6 PPB	15 PPB
036-13A Maintenance Office Sink Faucet	7/30/16 7:47	8/10/16 18:48	608012513	LEAD	2 PPB	15 PPB
036-14A Break Room Sink Faucet	7/30/16 7:49	8/10/16 18:48	608012514	LEAD	2 PPB	15 PPB
036-15A Student Store 132 Sink Faucet	7/30/16 7:53	8/10/16 18:48	608012515	LEAD	5 PPB	15 PPB
036-16A Student Store 132 Drinking Fountain	7/30/16 7:55	8/10/16 18:56	608012516	LEAD	3 PPB	15 PPB
036-17A Room 131 Sink Faucet	7/30/16 7:57	8/10/16 18:56	608012517	LEAD	2 PPB	15 PPB
036-18A Room 131 Drinking Fountain	7/30/16 7:59	8/10/16 18:56	608012518	LEAD	2 PPB	15 PPB
036-19A Room 129 Sink Faucet	7/30/16 8:02	8/10/16 18:56	608012519	LEAD	3 PPB	15 PPB
036-20A Room 129 Drinking Fountain	7/30/16 8:04	8/10/16 18:56	608012520	LEAD	2 PPB	15 PPB
036-21A Room 127 Sink Faucet	7/30/16 8:06	8/10/16 18:56	608012521	LEAD	2 PPB	15 PPB
036-22A Room 127 Drinking Fountain	7/30/16 8:08	8/10/16 18:56	608012522	LEAD	4 PPB	15 PPB
036-23A Room 128 Sink Faucet	7/30/16 8:11	8/10/16 18:56	608012523	LEAD	1 PPB	15 PPB
036-24A Room 128 Drinking Fountain	7/30/16 8:13	8/10/16 18:56	608012524	LEAD	3 PPB	15 PPB
036-25A Wood Shop 126 Drinking Fountain	7/30/16 8:17	8/10/16 18:56	608012525	LEAD	1 PPB	15 PPB
036-26A Mechanics 125 Drinking Fountain	7/30/16 8:20	8/10/16 18:56	608012526	LEAD	1 PPB	15 PPB
036-27A Hallway Drinking Fountain 4	7/30/16 8:23	8/10/16 18:56	608012527	LEAD	2 PPB	15 PPB
036-28A Hallway Drinking Fountain 5	7/30/16 8:25	8/10/16 18:56	608012528	LEAD	< 1 PPB	15 PPB
036-29A Agricultural 124 Drinking Fountain	7/30/16 8:30	8/10/16 18:56	608012529	LEAD	2 PPB	15 PPB
036-30A Girls Lockers Drinking Fountain	7/30/16 8:33	8/10/16 18:56	608012530	LEAD	< 1 PPB	15 PPB
036-31A Trainers Room Ice Maker	7/30/16 8:36	8/10/16 18:56	608012531	LEAD	< 1 PPB	15 PPB
036-32A Trainers Room Sink Faucet	7/30/16 8:38	8/10/16 18:56	608012532	LEAD	< 1 PPB	15 PPB
036-33A Weight Room Drinking Fountain	7/30/16 8:42	8/10/16 18:56	608012533	LEAD	< 1 PPB	15 PPB
036-34A Classroom 123 Sink Faucet	7/30/16 8:28	8/10/16 18:56	608012534	LEAD	1 PPB	15 PPB
036-35A Classroom 123 Drinking Fountain	7/30/16 8:30	8/10/16 18:56	608012535	LEAD	2 PPB	15 PPB
036-36A Hallway Drinking Fountain 6	7/30/16 8:23	8/10/16 18:57	608012536	LEAD	2 PPB	15 PPB
036-37A Hallway Drinking Fountain 7	7/30/16 8:35	8/10/16 18:57	608012537	LEAD	< 1 PPB	15 PPB
036-38A Home Ec. 109 Sink Faucet	7/30/16 8:40	8/10/16 18:57	608012538	LEAD	< 1 PPB	15 PPB
036-39A Home Ec. 109 Sink Faucet	7/30/16 8:42	8/10/16 18:57	608012539	LEAD	4 PPB	15 PPB
036-40A Home Ec. 109 Sink Faucet	7/30/16 8:44	8/10/16 18:57	608012540	LEAD	2 PPB	15 PPB
036-41A Home Ec. 109 Sink Faucet	7/30/16 8:46	8/10/16 18:57	608012541	LEAD	5 PPB	15 PPB
036-42A Home Ec. 109 Sink Faucet	7/30/16 8:48	8/10/16 18:57	608012542	LEAD	2 PPB	15 PPB
036-43A Home Ec. 109 Sink Faucet	7/30/16 8:50	8/10/16 18:57	608012543	LEAD	2 PPB	15 PPB
036-44A Room 105 Store Room Sink Faucet	7/30/16 8:53	8/10/16 18:57	608012544	LEAD	9 PPB	15 PPB
036-45A Room 105 Store Room Drinking Fountain	7/30/16 8:55	8/10/16 18:57	608012545	LEAD	3 PPB	15 PPB
036-46A Room 105 Sink Faucet	7/30/16 8:57	8/10/16 18:57	608012546	LEAD	< 1 PPB	15 PPB
036-47A Room 105 Sink Faucet	7/30/16 8:59	8/10/16 18:57	608012547	LEAD	< 1 PPB	15 PPB
036-48A Room 105 Sink Faucet	7/30/16 9:01	8/10/16 18:57	608012548	LEAD	< 1 PPB	15 PPB
036-49A Room 105 Sink Faucet	7/30/16 9:03	8/10/16 18:57	608012549	LEAD	< 1 PPB	15 PPB
036-50A Office Lounge Sink Faucet	7/30/16 9:09	8/10/16 18:57	608012550	LEAD	< 1 PPB	15 PPB
036-51A Office Lounge Drinking Faucet	7/30/16 9:11	8/10/16 18:57	608012551	LEAD	2 PPB	15 PPB
036-52A Health Office Sink Faucet	7/30/16 9:13	8/10/16 18:57	608012552	LEAD	< 1 PPB	15 PPB

Salem Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
036-53A Hallway Drinking Fountain 7	7/30/16 9:17	8/10/16 18:57	608012553	LEAD	< 1 PPB	15 PPB
036-54A Hallway Drinking Fountain 8	7/30/16 9:19	8/10/16 18:57	608012554	LEAD	< 1 PPB	15 PPB
036-55A Room 103 Sink Faucet	7/30/16 9:22	8/10/16 18:57	608012555	LEAD	1 PPB	15 PPB
036-56A Room 103 (Back) Sink Faucet	7/30/16 9:24	8/10/16 18:58	608012556	LEAD	< 1 PPB	15 PPB
036-57A Room 202 Sink Faucet	7/30/16 9:17	8/10/16 18:58	608012557	LEAD	5 PPB	15 PPB
036-58A Room 202 Drinking Fountain	7/30/16 9:19	8/10/16 18:58	608012558	LEAD	< 1 PPB	15 PPB
036-59A Classroom 214 Sink Faucet	7/30/16 9:21	8/10/16 18:58	608012559	LEAD	< 1 PPB	15 PPB
036-60A AV Breakroom Sink Faucet	7/30/16 9:24	8/10/16 18:58	608012560	LEAD	< 1 PPB	15 PPB
036-61A Hallway Drinking Fountain 8	7/30/16 9:27	8/10/16 18:58	608012561	LEAD	6 PPB	15 PPB
036-62A Classroom 228 Sink Faucet	7/30/16 9:30	8/10/16 18:58	608012562	LEAD	< 1 PPB	15 PPB
036-63A Classroom 228 Drinking Fountain	7/30/16 9:32	8/10/16 18:58	608012563	LEAD	3 PPB	15 PPB
036-64A Classroom 229 Sink Faucet	7/30/16 9:34	8/10/16 18:58	608012564	LEAD	< 1 PPB	15 PPB
036-65A Classroom 229 Drinking Fountain	7/30/16 9:36	8/10/16 18:58	608012565	LEAD	3 PPB	15 PPB
036-66A Hallway Drinking Fountain 9	7/30/16 9:40	8/10/16 18:58	608012566	LEAD	4 PPB	15 PPB
036-67A Hallway Drinking Fountain 10	7/30/16 9:42	8/10/16 18:58	608012567	LEAD	3 PPB	15 PPB
036-68A Hallway Drinking Fountain 11	7/30/16 9:44	8/10/16 18:58	608012568	LEAD	4 PPB	15 PPB
036-70A Room 242 Sink Faucet	7/30/16 9:52	8/10/16 18:58	608012569	LEAD	10 PPB	15 PPB
036-71A Hallway Drinking Fountain 12	7/30/16 9:47	8/10/16 18:58	608012570	LEAD	22 PPB	15 PPB
036-72A Hallway Drinking Fountain 13	7/30/16 9:49	8/10/16 18:58	608012571	LEAD	< 1 PPB	15 PPB
036-73A EGC Portable Sink Faucet	7/30/16 9:58	8/10/16 18:58	608012572	LEAD	1 PPB	15 PPB
036-74A Stadium Concession Sink Faucet	7/30/16 10:02	8/10/16 18:58	608012573	LEAD	9 PPB	15 PPB
036-75A 242 Drinking Fountain	7/30/16 9:54	8/10/16 18:58	608012574	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
036-76A Rm 242 Drinking Fountain	1/20/2017 6:28	1/23/2017	3132	LEAD	4 PPB	15 PPB
036-77A Theater Stage East End Sink Faucet	1/20/2017 6:25	1/23/2017	3133	LEAD	3 PPB	15 PPB
036-78A Theater Stage East End Drinking Fountain	1/20/2017 6:25	1/23/2017	3134	LEAD	12 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
McNary High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Tested For	Results	Action Level
038-53B Classroom 233 Sink Faucet	7/30/16 11:47	8/25/16 11:18	608231401	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
036-71B Hallway Drinking Fountain 12	7/30/16 9:48	8/26/16 11:34	608191701	LEAD	9 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
McKay High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
036-71C Hallway Drinking Fountain 12	10/14/2016 6:36	10/18/2016	63254	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level