

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McNary High School

| Sample Identification # and Location | Date & Time Collected | Date & Time Analyzed | Container ID | Tested For | Results | Action Level |
|--|-----------------------|----------------------|------------------|-------------|----------------|---------------|
| 038-01A Girls Locker Drinking Fountain (1) | 7/30/16 11:00 | 8/10/16 18:43 | 608012301 | LEAD | 2 PPB | 15 PPB |
| 038-02A Girls Locker Drinking Fountain (2) | 7/30/16 11:02 | 8/11/16 17:49 | 608012302 | LEAD | < 1 PPB | 15 PPB |
| 038-03A Weight Room Sink Faucet | 7/30/16 11:05 | 8/10/16 18:43 | 608012303 | LEAD | 6 PPB | 15 PPB |
| 038-04A Weight Room Drinking Fountain | 7/30/16 11:07 | 8/10/16 18:43 | 608012304 | LEAD | 2 PPB | 15 PPB |
| 038-07A Boys Locker Drinking Fountain (1) | 7/30/16 11:11 | 8/10/16 18:43 | 608012305 | LEAD | 8 PPB | 15 PPB |
| 038-08A Boys Locker Drinking Fountain (2) | 7/30/16 11:13 | 8/10/16 18:43 | 608012306 | LEAD | 5 PPB | 15 PPB |
| 038-09A Boys Locker Drinking Fountain (3) | 7/30/16 11:15 | 8/10/16 18:43 | 608012307 | LEAD | 5 PPB | 15 PPB |
| 038-10A Trainers Room Ice Maker | 7/30/16 11:18 | 8/10/16 18:43 | 608012308 | LEAD | < 1 PPB | 15 PPB |
| 038-11A Trainers Room Sink Faucet | 7/30/16 11:20 | 8/10/16 18:43 | 608012309 | LEAD | 1 PPB | 15 PPB |
| 038-12A Room 129 Sink Faucet (1) | 7/30/16 10:23 | 8/10/16 18:43 | 608012310 | LEAD | 3 PPB | 15 PPB |
| 038-13A Room 129 Sink Faucet (2) | 7/30/16 10:25 | 8/10/16 18:44 | 608012311 | LEAD | 6 PPB | 15 PPB |
| 038-14A Home Economics 158 Sink Faucet (1) | 7/30/16 10:30 | 8/10/16 18:44 | 608012312 | LEAD | 1 PPB | 15 PPB |
| 038-15A Home Economics 158 Sink Faucet (2) | 7/30/16 10:32 | 8/10/16 18:44 | 608012313 | LEAD | 1 PPB | 15 PPB |
| 038-16A Home Economics 158 Sink Faucet (3) | 7/30/16 10:34 | 8/10/16 18:44 | 608012314 | LEAD | 1 PPB | 15 PPB |
| 038-17A Home Economics 158 Sink Faucet (4) | 7/30/16 10:36 | 8/10/16 18:44 | 608012315 | LEAD | 2 PPB | 15 PPB |
| 038-18A Home Economics 158 Sink Faucet (5) | 7/30/16 10:38 | 8/10/16 18:44 | 608012316 | LEAD | < 1 PPB | 15 PPB |
| 038-19A Home Economics 158 Sink Faucet (6) | 7/30/16 10:40 | 8/10/16 18:44 | 608012317 | LEAD | 1 PPB | 15 PPB |
| 038-20A Home Economics 158 Sink Faucet (7) | 7/30/16 10:42 | 8/10/16 18:44 | 608012318 | LEAD | 7 PPB | 15 PPB |
| 038-21A Home Economics 158 Ice Maker | 7/30/16 10:44 | 8/10/16 18:44 | 608012319 | LEAD | < 1 PPB | 15 PPB |
| 038-22A Kitchen Food Prep Sink Faucet (1) | 7/30/16 10:47 | 8/10/16 18:44 | 608012320 | LEAD | < 1 PPB | 15 PPB |
| 038-23A Kitchen Food Prep Sink Faucet (2) | 7/30/16 10:49 | 8/10/16 18:44 | 608012321 | LEAD | 1 PPB | 15 PPB |
| 038-24A Kitchen Food Prep Sink Faucet (3) | 7/30/16 10:51 | 8/10/16 18:44 | 608012322 | LEAD | 1 PPB | 15 PPB |
| 038-25A Kitchen Ice Maker | 7/30/16 10:53 | 8/10/16 18:44 | 608012323 | LEAD | < 1 PPB | 15 PPB |
| 038-26A Cafeteria Drinking Fountain (1) | 7/30/16 10:55 | 8/10/16 18:44 | 608012324 | LEAD | 1 PPB | 15 PPB |
| 038-27A Cafeteria Drinking Fountain (2) | 7/30/16 10:57 | 8/10/16 18:44 | 608012325 | LEAD | 2 PPB | 15 PPB |
| 038-28A Cafeteria Grill Sink Faucet | 7/30/16 10:59 | 8/10/16 18:44 | 608012326 | LEAD | 2 PPB | 15 PPB |
| 038-29A Hallway Drinking Fountain 1 | 7/30/16 11:02 | 8/10/16 18:44 | 608012327 | LEAD | 8 PPB | 15 PPB |
| 038-30A Faculty Work Room Sink Faucet | 7/30/16 11:04 | 8/10/16 18:45 | 608012328 | LEAD | 4 PPB | 15 PPB |
| 038-31A Celtic Shop Sink Faucet | 7/30/16 10:49 | 8/10/16 18:45 | 608012329 | LEAD | 1 PPB | 15 PPB |
| 038-32A Make-up Sink Faucet (1) | 7/30/16 10:51 | 8/10/16 18:45 | 608012330 | LEAD | < 1 PPB | 15 PPB |
| 038-33A Make-up Sink Faucet (2) | 7/30/16 10:53 | 8/10/16 18:45 | 608012331 | LEAD | < 1 PPB | 15 PPB |
| 038-34A Library Break Room Sink Faucet | 7/30/16 10:55 | 8/10/16 18:45 | 608012332 | LEAD | 3 PPB | 15 PPB |
| 038-35A Hallway Drinking Fountain 2 | 7/30/16 10:58 | 8/10/16 18:45 | 608012333 | LEAD | 1 PPB | 15 PPB |
| 038-36A Hallway Drinking Fountain 3 | 7/30/16 11:05 | 8/10/16 18:45 | 608012334 | LEAD | 2 PPB | 15 PPB |
| 038-37A Hallway Drinking Fountain 4 | 7/30/16 11:07 | 8/10/16 18:45 | 608012335 | LEAD | 2 PPB | 15 PPB |
| 038-38A Hallway Drinking Fountain 5 | 7/30/16 11:09 | 8/10/16 18:45 | 608012336 | LEAD | 4 PPB | 15 PPB |
| 038-39A Hallway Drinking Fountain 6 | 7/30/16 11:11 | 8/10/16 18:45 | 608012337 | LEAD | 2 PPB | 15 PPB |
| 038-40A Room 114 Sink Faucet | 7/30/16 11:14 | 8/10/16 18:45 | 608012338 | LEAD | 5 PPB | 15 PPB |
| 038-41A Hallway Drinking Fountain 7 | 7/30/16 11:15 | 8/10/16 18:45 | 608012339 | LEAD | 3 PPB | 15 PPB |
| 038-42A Hallway Drinking Fountain 8 | 7/30/16 11:17 | 8/10/16 18:45 | 608012341 | LEAD | 2 PPB | 15 PPB |
| 038-43A Classroom 143 Sink Faucet | 7/30/16 11:20 | 8/10/16 18:45 | 608012342 | LEAD | 8 PPB | 15 PPB |
| 038-44A Classroom 143 Drinking Fountain | 7/30/16 11:22 | 8/10/16 18:45 | 608012343 | LEAD | 4 PPB | 15 PPB |
| 038-45A Classroom 145 Sink Faucet | 7/30/16 11:25 | 8/10/16 18:45 | 608012344 | LEAD | 3 PPB | 15 PPB |
| 038-46A Classroom 145 Drinking Fountain | 7/30/16 11:27 | 8/10/16 18:45 | 608012345 | LEAD | 4 PPB | 15 PPB |
| 038-47A Classroom 147 Sink Faucet | 7/30/16 11:30 | 8/10/16 18:45 | 608012346 | LEAD | 3 PPB | 15 PPB |
| 038-48A Classroom 147 Drinking Fountain | 7/30/16 11:32 | 8/10/16 18:45 | 608012347 | LEAD | 3 PPB | 15 PPB |
| 038-49A Hallway Drinking Fountain 9 | 7/30/16 11:36 | 8/10/16 18:45 | 608012348 | LEAD | 3 PPB | 15 PPB |
| 038-50A Hallway Drinking Fountain 10 | 7/30/16 11:38 | 8/10/16 18:46 | 608012349 | LEAD | 2 PPB | 15 PPB |
| 038-51A Classroom 231 Drinking Fountain | 7/30/16 11:41 | 8/10/16 18:46 | 608012350 | LEAD | 7 PPB | 15 PPB |
| 038-52A Classroom 231 Sink Faucet | 7/30/16 11:43 | 8/10/16 18:46 | 608012351 | LEAD | 7 PPB | 15 PPB |
| 038-53A Classroom 233 Sink Faucet | 7/30/16 11:46 | 8/10/16 18:46 | 608012352 | LEAD | 800 PPB | 15 PPB |
| 038-54A Classroom 216 Sink Faucet | 7/30/16 11:49 | 8/10/16 18:46 | 608012353 | LEAD | 2 PPB | 15 PPB |
| 038-55A Lounge Sink Faucet | 7/30/16 11:51 | 8/10/16 18:46 | 608012354 | LEAD | 3 PPB | 15 PPB |

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
McNary High School

| Sample Identification # and Location | Date & Time Collected | Date & Time Analyzed | Container ID | Tested For | Results | Action Level |
|---|-----------------------|----------------------|--------------|------------|---------|--------------|
| 038-57A Classroom 210 Sink Faucet | 7/30/16 11:55 | 8/10/16 18:46 | 608012355 | LEAD | 4 PPB | 15 PPB |
| 038-58A Hallway Drinking Fountain 9A | 7/30/16 11:57 | 8/10/16 18:46 | 608012356 | LEAD | 2 PPB | 15 PPB |
| 038-59A Hallway Drinking Fountain 10A | 7/30/16 11:58 | 8/10/16 18:46 | 608012357 | LEAD | 3 PPB | 15 PPB |
| 038-60A Hallway Drinking Fountain 11 | 7/30/16 12:01 | 8/10/16 18:46 | 608012358 | LEAD | 3 PPB | 15 PPB |
| 038-61A Hallway Drinking Fountain 12 | 7/30/16 12:03 | 8/10/16 18:46 | 608012359 | LEAD | 3 PPB | 15 PPB |
| 038-62A Room 254 Sink Faucet | 7/30/16 12:06 | 8/10/16 18:46 | 608012360 | LEAD | 6 PPB | 15 PPB |
| 038-63A Hallway Drinking Fountain 13 | 7/30/16 12:09 | 8/10/16 18:46 | 608012361 | LEAD | 10 PPB | 15 PPB |
| 038-64A Hallway Drinking Fountain 14 | 7/30/16 12:11 | 8/10/16 18:46 | 608012362 | LEAD | 9 PPB | 15 PPB |
| 038-65A Upper Gymnasium Drinking Fountain (1) | 7/30/16 12:14 | 8/10/16 18:46 | 608012363 | LEAD | 6 PPB | 15 PPB |
| 038-66A Upper Gymnasium Drinking Fountain (1) | 7/30/16 12:16 | 8/10/16 18:46 | 608012364 | LEAD | 4 PPB | 15 PPB |
| 038-67A Hallway Drinking Fountain 15 | 7/30/16 12:20 | 8/10/16 18:46 | 608012365 | LEAD | 3 PPB | 15 PPB |
| 038-68A Hallway Drinking Fountain 16 | 7/30/16 12:22 | 8/10/16 18:46 | 608012366 | LEAD | 3 PPB | 15 PPB |
| 038-69A Room 245 Sink Faucet | 7/30/16 12:25 | 8/10/16 18:46 | 608012367 | LEAD | 11 PPB | 15 PPB |
| 038-70A Hallway Drinking Fountain 15A | 7/30/16 11:00 | 8/10/16 18:46 | 608012368 | LEAD | 3 PPB | 15 PPB |
| 038-71A Hallway Drinking Fountain 16A | 7/30/16 11:02 | 8/10/16 18:47 | 608012369 | LEAD | 4 PPB | 15 PPB |
| 038-72A Stadium Concessions Sink Faucet (1) | 7/30/16 11:10 | 8/10/16 18:47 | 608012370 | LEAD | 2 PPB | 15 PPB |
| 038-73A Stadium Concessions Sink Faucet (2) | 7/30/16 11:12 | 8/10/16 18:47 | 608012371 | LEAD | 3 PPB | 15 PPB |
| 038-74A Stadium Concessions Sink Faucet (3) | 7/30/16 11:14 | 8/10/16 18:47 | 608012372 | LEAD | 7 PPB | 15 PPB |
| 038-75A Pedestal Drinking Fountain (Baseball Field) | 7/30/16 11:17 | 8/10/16 18:47 | 608012373 | LEAD | < 1 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level