

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-01A Room 10 Faculty Sink Faucet	8/6/16 8:00	8/14/2016	1608459-01A	LEAD	5 PPB	15 PPB
63-02A Hall Near Gymnasium Water Fountain 1	8/6/16 8:02	8/14/2016	1608459-02A	LEAD	14 PPB	15 PPB
63-03A Gymnasium by Double Doors Drinking Fountain 2	8/6/16 8:03	8/14/2016	1608459-03A	LEAD	3 PPB	15 PPB
63-04A Hall by Boiler Room Restroom Drinking Fountain 3	8/6/16 8:06	8/14/2016	1608459-04A	LEAD	21 PPB	15 PPB
63-05A Room 115 Sink Faucet	8/6/16 8:08	8/10/2016	1608459-05A	LEAD	2 PPB	15 PPB
63-06A Room 116 Sink Faucet	8/6/16 8:11	8/10/2016	1608459-06A	LEAD	5 PPB	15 PPB
63-07A Room 116 Drinking Fountain	8/6/16 8:11	8/14/2016	1608459-07A	LEAD	2 PPB	15 PPB
63-08A Room 117 Sink Faucet	8/6/16 8:13	8/14/2016	1608459-08A	LEAD	53 PPB	15 PPB
63-09A Room 117 Drinking Fountain	8/6/16 8:13	8/14/2016	1608459-09A	LEAD	2 PPB	15 PPB
63-10A Room 118 Sink Faucet	8/6/16 8:17	8/14/2016	1608459-10A	LEAD	48 PPB	15 PPB
63-11A Room 118 Drinking Fountain	8/6/16 8:17	8/14/2016	1608459-11A	LEAD	3 PPB	15 PPB
63-12A Room 119 Sink Faucet	8/6/16 8:19	8/14/2016	1608459-12A	LEAD	5 PPB	15 PPB
63-13A Room 119 Drinking Fountain	8/6/16 8:19	8/14/2016	1608459-13A	LEAD	1 PPB	15 PPB
63-14A Room 120 Sink Faucet	8/6/16 8:24	8/10/2016	1608459-14A	LEAD	16 PPB	15 PPB
63-15A Room 120 Drinking Fountain	8/6/16 8:24	8/14/2016	1608459-15A	LEAD	2 PPB	15 PPB
63-16A Room 121 Sink Faucet	8/6/16 8:22	8/10/2016	1608459-16A	LEAD	16 PPB	15 PPB
63-17A Room 122 Drinking Fountain	8/6/16 8:27	8/14/2016	1608459-17A	LEAD	5 PPB	15 PPB
63-18A Entry to Girls Restroom Drinking Fountain 4	8/6/16 8:29	8/14/2016	1608459-18A	LEAD	7 PPB	15 PPB
63-19A Health Room Sink Faucet	8/6/16 8:32	8/10/2016	1608459-19A	LEAD	5 PPB	15 PPB
63-20A Health Room Drinking Fountain	8/6/16 8:32	8/14/2016	1608459-20A	LEAD	2 PPB	15 PPB
63-21A Supply Hall (132) Sink Faucet	8/6/16 8:34	8/10/2016	1608459-21A	LEAD	9 PPB	15 PPB
63-22A AV Storage Room 100 Sink Faucet	8/6/16 8:36	8/14/2016	1608459-22A	LEAD	15 PPB	15 PPB
63-23A Room 101 Sink Faucet	8/6/16 8:43	8/14/2016	1608459-23A	LEAD	6 PPB	15 PPB
63-24A Room 101 Drinking Fountain	8/6/16 8:43	8/14/2016	1608459-24A	LEAD	2 PPB	15 PPB
63-25A Room 102 Sink Faucet	8/6/16 8:46	8/14/2016	1608459-25A	LEAD	33 PPB	15 PPB
63-26A Room 102 Drinking Fountain	8/6/16 8:46	8/14/2016	1608459-26A	LEAD	2 PPB	15 PPB
63-27A Room 103 Sink Faucet	8/6/16 8:48	8/10/2016	1608459-27A	LEAD	4 PPB	15 PPB
63-28A Room 103 Drinking Fountain	8/6/16 8:48	8/14/2016	1608459-28A	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Myers Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results		Action Level
63-29A	Hall to Restroom Drinking Fountain	8/6/16 8:54	8/14/2016	1608459-29A	LEAD	7	PPB	15 PPB
63-30A	Room 105 Sink Faucet	8/6/16 8:56	8/10/2016	1608459-30A	LEAD	27	PPB	15 PPB
63-31A	Room 105 Drinking Fountain	8/6/16 8:56	8/14/2016	1608459-31A	LEAD	2	PPB	15 PPB
63-32A	Room 104 Sink Faucet	8/6/16 8:59	8/10/2016	1608459-32A	LEAD	6	PPB	15 PPB
63-33A	Room 104 Drinking Fountain	8/6/16 8:59	8/14/2016	1608459-33A	LEAD	<1.0	PPB	15 PPB
63-34A	Room 106 Sink Faucet	8/6/16 9:02	8/10/2016	1608459-34A	LEAD	11	PPB	15 PPB
63-35A	Room 106 Drinking Fountain	8/6/16 9:02	8/14/2016	1608459-35A	LEAD	2	PPB	15 PPB
63-36A	Room 107 Sink Faucet	8/6/16 9:05	8/10/2016	1608459-36A	LEAD	3	PPB	15 PPB
63-37A	Room 107 Drinking Fountain	8/6/16 9:05	8/14/2016	1608459-37A	LEAD	1	PPB	15 PPB
63-38A	Room 110 Sink Faucet	8/6/16 9:09	8/10/2016	1608459-38A	LEAD	7	PPB	15 PPB
63-39A	Room 110 Drinking Fountain	8/6/16 9:09	8/14/2016	1608459-39A	LEAD	<1.0	PPB	15 PPB
63-40A	Room 108 Sink Faucet	8/6/16 9:13	8/10/2016	1608459-40A	LEAD	13	PPB	15 PPB
63-41A	Room 108 Drinking Fountain	8/6/16 9:13	8/14/2016	1608459-41A	LEAD	2	PPB	15 PPB
63-42A	Room 109 Sink Faucet	8/6/16 9:20	8/14/2016	1608459-42A	LEAD	9	PPB	15 PPB
63-43A	Room 109 Drinking Fountain	8/6/16 9:20	8/14/2016	1608459-43A	LEAD	2	PPB	15 PPB
63-44A	Room 112 Sink Faucet	8/6/16 9:24	8/14/2016	1608459-44A	LEAD	3	PPB	15 PPB
63-45A	Room 112 Drinking Fountain	8/6/16 9:24	8/14/2016	1608459-45A	LEAD	3	PPB	15 PPB
63-46A	Room 111 Sink Faucet	8/6/16 9:27	8/10/2016	1608459-46A	LEAD	4	PPB	15 PPB
63-47A	Room 111 Drinking Fountain	8/6/16 9:27	8/14/2016	1608459-47A	LEAD	<1.0	PPB	15 PPB
63-48A	Room 113 Sink Faucet	8/6/16 9:32	8/10/2016	1608459-48A	LEAD	6	PPB	15 PPB
63-49A	Room 113 Drinking Fountain	8/6/16 9:32	8/14/2016	1608459-49A	LEAD	12	PPB	15 PPB
63-50A	Portable Room 131 Drinking Fountain	8/6/16 9:42	8/14/2016	1608459-50A	LEAD	2	PPB	15 PPB
63-51A	Portable Room 131 Sink Faucet	8/6/16 9:42	8/14/2016	1608459-51A	LEAD	1	PPB	15 PPB
63-52A	Portable Room 132 Drinking Fountain	8/6/16 9:45	8/14/2016	1608459-52A	LEAD	<1.0	PPB	15 PPB
63-53A	Portable Room 132 Sink Faucet	8/6/16 9:45	8/14/2016	1608459-53A	LEAD	1	PPB	15 PPB
63-54A	Portable Room 133 Sink Faucet	8/6/16 9:50	8/10/2016	1608459-54A	LEAD	5	PPB	15 PPB
63-55A	Portable Room 133 Drinking Fountain	8/6/16 9:50	8/14/2016	1608459-55A	LEAD	4	PPB	15 PPB
63-56A	Portable Room 134 Sink Faucet	8/6/16 9:52	8/10/2016	1608459-56A	LEAD	6	PPB	15 PPB

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-57A Portable Room 134 Drinking Fountain	8/6/16 9:52	8/10/2016	1608459-57A	LEAD	<1.0 PPB	15 PPB
63-58A Food Service Galley Dish Sink Faucet	8/6/16 9:58	8/14/2016	1608459-58A	LEAD	5 PPB	15 PPB
63-59A Drinking Fountain Across from Room 116 5	8/6/16 9:36	8/14/2016	1608459-59A	LEAD	18 PPB	15 PPB
63-60A Room 113 2nd Sink Faucet (Without Drinking Fountain)	8/6/16 9:34	8/14/2016	1608459-60A	LEAD	13 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Myers Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results		Action Level
63-08C	Room 117 Sink Faucet	1/6/17 5:43	1/9/2017	782	LEAD	38	PPB	15 PPB
63-10C	Room 118 Sink Faucet	1/6/17 5:45	1/9/2017	783	LEAD	50	PPB	15 PPB
63-14C	Room 120 Sink Faucet	1/6/17 5:47	1/9/2017	784	LEAD	8	PPB	15 PPB
63-16C	Room 121 Sink Faucet	1/6/17 5:49	1/9/2017	785	LEAD	9	PPB	15 PPB
63-22C	AV Storage Room 100 Sink Faucet	1/6/17 5:54	1/9/2017	786	LEAD	4	PPB	15 PPB
63-25C	Room 102 Sink Faucet	1/6/17 5:59	1/9/2017	787	LEAD	5	PPB	15 PPB
63-30C	Room 105 Sink Faucet	1/6/17 6:01	1/9/2017	788	LEAD	11	PPB	15 PPB
63-59C	Drinking Fountain Across from Room 116 (5)	1/6/17 5:56	1/9/2017	789	LEAD	23	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 Flushed (B) Sample Data
 Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-04B Hall by Boiler Room Restroom Drinking Fountain 3	8/6/16 8:07	8/26/2016	1608460-04A	LEAD	9 PPB	15 PPB
63-08B Room 117 Sink Faucet	8/6/16 8:14	8/26/2016	1608460-08A	LEAD	3 PPB	15 PPB
63-10B Room 118 Sink Faucet	8/6/16 8:18	8/26/2016	1608460-10A	LEAD	2 PPB	15 PPB
63-14B Room 120 Sink Faucet	8/6/16 8:25	8/26/2016	1608460-14A	LEAD	4 PPB	15 PPB
63-16B Room 121 Sink Faucet	8/6/16 8:23	8/26/2016	1608460-16A	LEAD	1 PPB	15 PPB
63-22B AV Storage Room 100 Sink Faucet	8/6/16 8:37	8/26/2016	1608460-22A	LEAD	3 PPB	15 PPB
63-25B Room 102 Sink Faucet	8/6/16 8:47	8/26/2016	1608460-25A	LEAD	4 PPB	15 PPB
63-30B Room 105 Sink Faucet	8/6/16 8:57	8/26/2016	1608460-30A	LEAD	1 PPB	15 PPB
63-59B Drinking Fountain Across from Room 116 5	8/6/16 9:37	8/26/2016	1608460-59A	LEAD	8 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (D) Sample Data
Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-08D Room 117 Sink Faucet	1/6/2017 5:44	2/1/2017	4398	LEAD	3 PPB	15 PPB
63-10D Room 118 Sink Faucet	1/6/2017 5:46	2/1/2017	4399	LEAD	3 PPB	15 PPB
63-59D Drinking Fountain Across from Room 116 (5)	1/6/2017 5:57	2/1/2017	4400	LEAD	14 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (E) Sample Data
 Myers Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
63-08E Room 117 Sink Faucet	4/6/2017 6:16	4/11/2017	18114	LEAD	27 PPB	15 PPB
63-10E Room 118 Sink Faucet	4/6/2017 6:19	4/11/2017	18115	LEAD	73 PPB	15 PPB
63-59E Drinking Fountain Across from Rm 116 (5)	4/6/2017 6:22	4/11/2017	18116	LEAD	13 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level