

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-01A Weight Room Refrigerated Drinking Fountain	7/30/16 8:02	8/4/2016	1608154-01A	COPPER	0.6 PPM	1.3 PPM
042-02A Gymnasium B Drinking Fountain	7/30/16 8:00	8/5/2016	1608154-02A	COPPER	1.2 PPM	1.3 PPM
042-03A Hall Drinking Fountain 1	7/30/16 8:06	8/4/2016	1608154-03A	COPPER	0.7 PPM	1.3 PPM
042-04A Gymnasium Concession Sink Faucet	7/30/16 8:08	8/4/2016	1608154-04A	COPPER	0.4 PPM	1.3 PPM
042-05A Gymnasium Concession Sink Faucet	7/30/16 8:10	8/4/2016	1608154-05A	COPPER	0.3 PPM	1.3 PPM
042-07A Main Gymnasium Drinking Fountain	7/30/16 8:14	8/4/2016	1608154-06A	COPPER	0.3 PPM	1.3 PPM
042-08A Main Gymnasium Drinking Fountain	7/30/16 8:16	8/4/2016	1608154-07A	COPPER	0.5 PPM	1.3 PPM
042-09A Wrestling Room 2 Drinking Fountain	7/30/16 8:16	8/4/2016	1608154-08A	COPPER	0.1 PPM	1.3 PPM
042-10A Training Room Sink Faucet	7/30/16 8:27	8/4/2016	1608154-09A	COPPER	0.2 PPM	1.3 PPM
042-11A Training Room Ice Maker	7/30/16 8:28	8/4/2016	1608154-10A	COPPER	0.0 PPM	1.3 PPM
042-12A Portable P7 Refrigerated Drinking Fountain	7/30/16 8:32	8/5/2016	1608154-11A	COPPER	1.6 PPM	1.3 PPM
042-13A Stadium Concession Sink Faucet	7/30/16 8:36	8/4/2016	1608154-12A	COPPER	0.4 PPM	1.3 PPM
042-14A Stadium Concession Sink Faucet	7/30/16 8:37	8/4/2016	1608154-13A	COPPER	0.1 PPM	1.3 PPM
042-15A Stadium Concession Ice Maker	7/30/16 8:39	8/4/2016	1608154-14A	COPPER	0.0 PPM	1.3 PPM
042-16A Hall Drinking Fountain 2	7/30/16 8:54	8/4/2016	1608154-15A	COPPER	0.5 PPM	1.3 PPM
042-17A Kitchen Ice Maker	7/30/16 8:58	8/4/2016	1608154-16A	COPPER	0.0 PPM	1.3 PPM
042-18A Kitchen Food Prep Sink Faucet (1)	7/30/16 9:00	8/4/2016	1608154-17A	COPPER	0.2 PPM	1.3 PPM
042-19A Kitchen Food Prep Sink Faucet (2)	7/30/16 8:58	8/4/2016	1608154-18A	COPPER	0.2 PPM	1.3 PPM
042-20A Kitchen Food Prep Sink Faucet (3)	7/30/16 9:01	8/4/2016	1608154-19A	COPPER	0.1 PPM	1.3 PPM
042-21A Guidance Center Break Area Sink Faucet	7/30/16 9:09	8/4/2016	1608154-20A	COPPER	0.4 PPM	1.3 PPM
042-22A Room 101 Sink Faucet	7/30/16 9:11	8/4/2016	1608154-21A	COPPER	0.2 PPM	1.3 PPM
042-24A Home Economics Sink Faucet (1)	7/30/16 9:19	8/4/2016	1608154-22A	COPPER	0.4 PPM	1.3 PPM
042-25A Home Economics Sink Faucet (2)	7/30/16 9:18	8/4/2016	1608154-23A	COPPER	0.5 PPM	1.3 PPM
042-26A Home Economics Sink Faucet (3)	7/30/16 9:11	8/4/2016	1608154-24A	COPPER	0.2 PPM	1.3 PPM
042-27A Home Economics Sink Faucet (4)	7/30/16 9:21	8/4/2016	1608154-25A	COPPER	0.2 PPM	1.3 PPM
042-28A Home Economics Sink Faucet (5)	7/30/16 9:22	8/4/2016	1608154-26A	COPPER	0.2 PPM	1.3 PPM
042-29A Home Economics Sink Faucet (6)	7/30/16 9:24	8/4/2016	1608154-27A	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
North Salem High School

042-30A	Home Economics Sink Faucet (7)	7/30/16 9:23	8/4/2016	1608154-28A	COPPER	0.2 PPM	1.3 PPM
042-31A	Home Economics Sink Faucet (8)	7/30/16 9:25	8/4/2016	1608154-29A	COPPER	0.3 PPM	1.3 PPM
042-32A	Home Economics Ice Maker	7/30/16 9:19	8/4/2016	1608154-30A	COPPER	0.0 PPM	1.3 PPM
042-33A	Hall Drinking Fountain 3	7/30/16 9:31	8/4/2016	1608154-31A	COPPER	0.2 PPM	1.3 PPM
042-34A	Hall Drinking Fountain 4	7/30/16 9:31	8/4/2016	1608154-32A	COPPER	0.3 PPM	1.3 PPM
042-35A	Hall Drinking Fountain 5	7/30/16 9:31	8/4/2016	1608154-33A	COPPER	0.2 PPM	1.3 PPM
042-36A	Hall Drinking Fountain 6	7/30/16 9:39	8/5/2016	1608154-34A	COPPER	0.9 PPM	1.3 PPM
042-37A	Library Refrigerated Drinking Fountain (1)	7/30/16 9:42	8/4/2016	1608154-35A	COPPER	0.6 PPM	1.3 PPM
042-38A	Library Refrigerated Drinking Fountain (2)	7/30/16 9:43	8/4/2016	1608154-36A	COPPER	0.6 PPM	1.3 PPM
042-39A	Room 134 Sink Faucet	7/30/16 9:48	8/4/2016	1608154-37A	COPPER	0.3 PPM	1.3 PPM
042-40A	Hall Drinking Fountain 7	7/30/16 9:51	8/4/2016	1608154-38A	COPPER	0.6 PPM	1.3 PPM
042-41A	Hall Drinking Fountain 8	7/30/16 9:52	8/4/2016	1608154-39A	COPPER	0.4 PPM	1.3 PPM
042-42A	Hall Drinking Fountain 9	7/30/16 9:54	8/4/2016	1608154-40A	COPPER	0.4 PPM	1.3 PPM
042-43A	Hall Drinking Fountain 10	7/30/16 10:03	8/5/2016	1608154-41A	COPPER	0.9 PPM	1.3 PPM
042-44A	Hall Drinking Fountain 11	7/30/16 10:04	8/5/2016	1608154-42A	COPPER	1.0 PPM	1.3 PPM
042-45A	Orchestra 118 Sink Faucet	7/30/16 10:08	8/4/2016	1608154-43A	COPPER	0.1 PPM	1.3 PPM
042-46A	Band 120 Sink Faucet	7/30/16 10:10	8/4/2016	1608154-44A	COPPER	0.4 PPM	1.3 PPM
042-47A	Room 224 Sink Faucet	7/30/16 10:22	8/4/2016	1608154-45A	COPPER	0.5 PPM	1.3 PPM
042-48A	Room 230 Sink Faucet	7/30/16 10:23	8/4/2016	1608154-46A	COPPER	0.5 PPM	1.3 PPM
042-49A	Room 223 Sink Faucet	7/30/16 10:25	8/4/2016	1608154-47A	COPPER	0.7 PPM	1.3 PPM
042-50A	Room 223 Sink Faucet	7/30/16 10:25	8/4/2016	1608154-48A	COPPER	0.7 PPM	1.3 PPM
042-51A	Room 222 Sink Faucet	7/30/16 10:29	8/4/2016	1608154-49A	COPPER	0.6 PPM	1.3 PPM
042-52A	Room 222 Sink Faucet	7/30/16 10:29	8/4/2016	1608154-50A	COPPER	0.7 PPM	1.3 PPM
042-53A	Hall Drinking Fountain 13	7/30/16 10:30	8/5/2016	1608154-51A	COPPER	1.0 PPM	1.3 PPM
042-54A	Hall Drinking Fountain 14	7/30/16 10:34	8/4/2016	1608154-52A	COPPER	0.9 PPM	1.3 PPM
042-55A	Hall Drinking Fountain 15	7/30/16 10:33	8/4/2016	1608154-53A	COPPER	0.9 PPM	1.3 PPM
042-56A	Hall Drinking Fountain 16	7/30/16 10:35	8/4/2016	1608154-54A	COPPER	0.7 PPM	1.3 PPM
042-57A	Hall Drinking Fountain 17	7/30/16 10:38	8/4/2016	1608154-55A	COPPER	0.9 PPM	1.3 PPM
042-58A	Hall Drinking Fountain 18	7/30/16 10:42	8/4/2016	1608154-56A	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
North Salem High School

042-59A	Hall Drinking Fountain 19	7/30/16 10:42	8/4/2016	1608154-57A	COPPER	0.5 PPM	1.3 PPM
042-60A	Hall Drinking Fountain 20	7/30/16 10:42	8/4/2016	1608154-58A	COPPER	0.5 PPM	1.3 PPM
042-61A	Room 206 Sink Faucet	7/30/16 10:44	8/4/2016	1608154-59A	COPPER	0.2 PPM	1.3 PPM
042-62A	Room 206 Drinking Fountain	7/30/16 10:44	8/4/2016	1608154-60A	COPPER	0.2 PPM	1.3 PPM
042-63A	Infant Room Food Prep Sink Faucet	7/30/16 11:05	8/5/2016	1608154-61A	COPPER	0.3 PPM	1.3 PPM
042-64A	Staff Food Prep Sink Faucet	7/30/16 11:07	8/5/2016	1608154-62A	COPPER	0.3 PPM	1.3 PPM
042-65A	Room 413 Sink Faucet	7/30/16 11:11	8/5/2016	1608154-63A	COPPER	0.4 PPM	1.3 PPM
042-66A	Hall Drinking Fountain 21	7/30/16 11:09	8/5/2016	1608154-64A	COPPER	0.5 PPM	1.3 PPM
042-67A	Room 414 Sink Faucet	7/30/16 11:05	8/5/2016	1608154-65A	COPPER	0.4 PPM	1.3 PPM
042-68A	Room 414 Sink Faucet	7/30/16 11:05	8/5/2016	1608154-66A	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-06A Gymnasium Concession Ice Maker	9/23/2016 5:20	9/26/2016	58301	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-10B Training Room Sink Faucet	7/30/16 8:28	8/24/2016	1608155-09A	COPPER	0.2 PPM	1.3 PPM
042-12B Portable P7 Refrigerated Drinking Fountain	7/30/16 8:47	8/24/2016	1608155-10A	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-12C Portable P7 Refrigerated Drinking Fountain	1/20/2017 5:54	1/23/2017	3139	COPPER	0.5 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-15C Stadium Concession Ice Maker	3/16/2017 6:40	3/17/2017	13884	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level