

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-01A Weight Room Refrigerated Drinking Fountain	7/30/16 8:02	8/4/2016	1608154-01A	LEAD	<1.0 PPB	15 PPB
042-02A Gymnasium B Drinking Fountain	7/30/16 8:00	8/5/2016	1608154-02A	LEAD	<1.0 PPB	15 PPB
042-03A Hall Drinking Fountain 1	7/30/16 8:06	8/4/2016	1608154-03A	LEAD	<1.0 PPB	15 PPB
042-04A Gymnasium Concession Sink Faucet	7/30/16 8:08	8/4/2016	1608154-04A	LEAD	3 PPB	15 PPB
042-05A Gymnasium Concession Sink Faucet	7/30/16 8:10	8/4/2016	1608154-05A	LEAD	1 PPB	15 PPB
042-07A Main Gymnasium Drinking Fountain	7/30/16 8:14	8/4/2016	1608154-06A	LEAD	<1.0 PPB	15 PPB
042-08A Main Gymnasium Drinking Fountain	7/30/16 8:16	8/4/2016	1608154-07A	LEAD	<1.0 PPB	15 PPB
042-09A Wrestling Room 2 Drinking Fountain	7/30/16 8:16	8/4/2016	1608154-08A	LEAD	<1.0 PPB	15 PPB
042-10A Training Room Sink Faucet	7/30/16 8:27	8/4/2016	1608154-09A	LEAD	15 PPB	15 PPB
042-11A Training Room Ice Maker	7/30/16 8:28	8/4/2016	1608154-10A	LEAD	<1.0 PPB	15 PPB
042-12A Portable P7 Refrigerated Drinking Fountain	7/30/16 8:32	8/5/2016	1608154-11A	LEAD	2 PPB	15 PPB
042-13A Stadium Concession Sink Faucet	7/30/16 8:36	8/4/2016	1608154-12A	LEAD	4 PPB	15 PPB
042-14A Stadium Concession Sink Faucet	7/30/16 8:37	8/4/2016	1608154-13A	LEAD	<1.0 PPB	15 PPB
042-15A Stadium Concession Ice Maker	7/30/16 8:39	8/4/2016	1608154-14A	LEAD	110 PPB	15 PPB
042-16A Hall Drinking Fountain 2	7/30/16 8:54	8/4/2016	1608154-15A	LEAD	1 PPB	15 PPB
042-17A Kitchen Ice Maker	7/30/16 8:58	8/4/2016	1608154-16A	LEAD	<1.0 PPB	15 PPB
042-18A Kitchen Food Prep Sink Faucet (1)	7/30/16 9:00	8/4/2016	1608154-17A	LEAD	2 PPB	15 PPB
042-19A Kitchen Food Prep Sink Faucet (2)	7/30/16 8:58	8/4/2016	1608154-18A	LEAD	3 PPB	15 PPB
042-20A Kitchen Food Prep Sink Faucet (3)	7/30/16 9:01	8/4/2016	1608154-19A	LEAD	3 PPB	15 PPB
042-21A Guidance Center Break Area Sink Faucet	7/30/16 9:09	8/4/2016	1608154-20A	LEAD	<1.0 PPB	15 PPB
042-22A Room 101 Sink Faucet	7/30/16 9:11	8/4/2016	1608154-21A	LEAD	4 PPB	15 PPB
042-24A Home Economics Sink Faucet (1)	7/30/16 9:19	8/4/2016	1608154-22A	LEAD	<1.0 PPB	15 PPB
042-25A Home Economics Sink Faucet (2)	7/30/16 9:18	8/4/2016	1608154-23A	LEAD	<1.0 PPB	15 PPB
042-26A Home Economics Sink Faucet (3)	7/30/16 9:11	8/4/2016	1608154-24A	LEAD	<1.0 PPB	15 PPB
042-27A Home Economics Sink Faucet (4)	7/30/16 9:21	8/4/2016	1608154-25A	LEAD	<1.0 PPB	15 PPB
042-28A Home Economics Sink Faucet (5)	7/30/16 9:22	8/4/2016	1608154-26A	LEAD	2 PPB	15 PPB
042-29A Home Economics Sink Faucet (6)	7/30/16 9:24	8/4/2016	1608154-27A	LEAD	1 PPB	15 PPB
042-30A Home Economics Sink Faucet (7)	7/30/16 9:23	8/4/2016	1608154-28A	LEAD	1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
North Salem High School

042-31A	Home Economics Sink Faucet (8)	7/30/16 9:25	8/4/2016	1608154-29A	LEAD	4	PPB	15 PPB
042-32A	Home Economics Ice Maker	7/30/16 9:19	8/4/2016	1608154-30A	LEAD	<1.0	PPB	15 PPB
042-33A	Hall Drinking Fountain 3	7/30/16 9:31	8/4/2016	1608154-31A	LEAD	2	PPB	15 PPB
042-34A	Hall Drinking Fountain 4	7/30/16 9:31	8/4/2016	1608154-32A	LEAD	<1.0	PPB	15 PPB
042-35A	Hall Drinking Fountain 5	7/30/16 9:31	8/4/2016	1608154-33A	LEAD	2	PPB	15 PPB
042-36A	Hall Drinking Fountain 6	7/30/16 9:39	8/5/2016	1608154-34A	LEAD	1	PPB	15 PPB
042-37A	Library Refrigerated Drinking Fountain (1)	7/30/16 9:42	8/4/2016	1608154-35A	LEAD	<1.0	PPB	15 PPB
042-38A	Library Refrigerated Drinking Fountain (2)	7/30/16 9:43	8/4/2016	1608154-36A	LEAD	<1.0	PPB	15 PPB
042-39A	Room 134 Sink Faucet	7/30/16 9:48	8/4/2016	1608154-37A	LEAD	2	PPB	15 PPB
042-40A	Hall Drinking Fountain 7	7/30/16 9:51	8/4/2016	1608154-38A	LEAD	1	PPB	15 PPB
042-41A	Hall Drinking Fountain 8	7/30/16 9:52	8/4/2016	1608154-39A	LEAD	<1.0	PPB	15 PPB
042-42A	Hall Drinking Fountain 9	7/30/16 9:54	8/4/2016	1608154-40A	LEAD	<1.0	PPB	15 PPB
042-43A	Hall Drinking Fountain 10	7/30/16 10:03	8/5/2016	1608154-41A	LEAD	<1.0	PPB	15 PPB
042-44A	Hall Drinking Fountain 11	7/30/16 10:04	8/5/2016	1608154-42A	LEAD	<1.0	PPB	15 PPB
042-45A	Orchestra 118 Sink Faucet	7/30/16 10:08	8/4/2016	1608154-43A	LEAD	<1.0	PPB	15 PPB
042-46A	Band 120 Sink Faucet	7/30/16 10:10	8/4/2016	1608154-44A	LEAD	<1.0	PPB	15 PPB
042-47A	Room 224 Sink Faucet	7/30/16 10:22	8/4/2016	1608154-45A	LEAD	3	PPB	15 PPB
042-48A	Room 230 Sink Faucet	7/30/16 10:23	8/4/2016	1608154-46A	LEAD	<1.0	PPB	15 PPB
042-49A	Room 223 Sink Faucet	7/30/16 10:25	8/4/2016	1608154-47A	LEAD	4	PPB	15 PPB
042-50A	Room 223 Sink Faucet	7/30/16 10:25	8/4/2016	1608154-48A	LEAD	2	PPB	15 PPB
042-51A	Room 222 Sink Faucet	7/30/16 10:29	8/4/2016	1608154-49A	LEAD	4	PPB	15 PPB
042-52A	Room 222 Sink Faucet	7/30/16 10:29	8/4/2016	1608154-50A	LEAD	4	PPB	15 PPB
042-53A	Hall Drinking Fountain 13	7/30/16 10:30	8/5/2016	1608154-51A	LEAD	<1.0	PPB	15 PPB
042-54A	Hall Drinking Fountain 14	7/30/16 10:34	8/4/2016	1608154-52A	LEAD	2	PPB	15 PPB
042-55A	Hall Drinking Fountain 15	7/30/16 10:33	8/4/2016	1608154-53A	LEAD	1	PPB	15 PPB
042-56A	Hall Drinking Fountain 16	7/30/16 10:35	8/4/2016	1608154-54A	LEAD	2	PPB	15 PPB
042-57A	Hall Drinking Fountain 17	7/30/16 10:38	8/4/2016	1608154-55A	LEAD	<1.0	PPB	15 PPB
042-58A	Hall Drinking Fountain 18	7/30/16 10:42	8/4/2016	1608154-56A	LEAD	<1.0	PPB	15 PPB
042-59A	Hall Drinking Fountain 19	7/30/16 10:42	8/4/2016	1608154-57A	LEAD	2	PPB	15 PPB
042-60A	Hall Drinking Fountain 20	7/30/16 10:42	8/4/2016	1608154-58A	LEAD	2	PPB	15 PPB

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 North Salem High School

042-61A	Room 206 Sink Faucet	7/30/16 10:44	8/4/2016	1608154-59A	LEAD	13	PPB	15	PPB
042-62A	Room 206 Drinking Fountain	7/30/16 10:44	8/4/2016	1608154-60A	LEAD	10	PPB	15	PPB
042-63A	Infant Room Food Prep Sink Faucet	7/30/16 11:05	8/5/2016	1608154-61A	LEAD	<1.0	PPB	15	PPB
042-64A	Staff Food Prep Sink Faucet	7/30/16 11:07	8/5/2016	1608154-62A	LEAD	4	PPB	15	PPB
042-65A	Room 413 Sink Faucet	7/30/16 11:11	8/5/2016	1608154-63A	LEAD	3	PPB	15	PPB
042-66A	Hall Drinking Fountain 21	7/30/16 11:09	8/5/2016	1608154-64A	LEAD	<1.0	PPB	15	PPB
042-67A	Room 414 Sink Faucet	7/30/16 11:05	8/5/2016	1608154-65A	LEAD	3	PPB	15	PPB
042-68A	Room 414 Sink Faucet	7/30/16 11:05	8/5/2016	1608154-66A	LEAD	2	PPB	15	PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-06A Gymnasium Concession Ice Maker	9/23/2016 5:20	9/26/2016	58301	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-10B Training Room Sink Faucet	7/30/16 8:28	8/24/2016	1608155-09A	LEAD	1 PPB	15 PPB
042-12B Portable P7 Refrigerated Drinking Fountain	7/30/16 8:47	8/24/2016	1608155-10A	LEAD	<1.0 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-12C Portable P7 Refrigerated Drinking Fountain	1/20/2017 5:54	1/23/2017	3139	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
North Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
042-15C Stadium Concession Ice Maker	3/16/2017 6:40	3/17/2017	13884	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level