

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Paulus/Repo/Tech

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
77-01A West End Hallway Drinking Fountain	8/6/2016 7:25	8/23/2016	49986	LEAD	11 PPB	15 PPB
77-02A Room 108 Kitchenette Sink Faucet	8/6/2016 7:27	8/23/2016	49987	LEAD	<1 PPB	15 PPB
77-03A Hallway Drinking Fountain	8/6/2016 7:29	8/23/2016	49988	LEAD	<1 PPB	15 PPB
77-04A 2nd Floor Halway Drinking Fountain	8/6/2016 7:31	8/23/2016	49989	LEAD	2 PPB	15 PPB
77-05A Room 210 Kitchenette Sink Faucet	8/6/2016 7:34	8/23/2016	49990	LEAD	2 PPB	15 PPB
77-06A 2nd Floor Lunch Room Sink Faucet	8/6/2016 7:36	8/23/2016	49991	LEAD	4 PPB	15 PPB
77-07A 2nd Floor West Hall Drinking Fountain	8/6/2016 7:39	8/23/2016	49992	LEAD	33 PPB	15 PPB
77-08A Main Office Sink Faucet	8/6/2016 8:01	8/23/2016	49993	LEAD	<1 PPB	15 PPB
77-09A Print Shop Sink Faucet	8/6/2016 8:03	8/23/2016	49994	LEAD	<1 PPB	15 PPB
77-10A Breakroom Hall Drinking Fountain	8/6/2016 8:05	8/23/2016	49995	LEAD	<1 PPB	15 PPB
77-11A Breakroom Sink Faucet	8/6/2016 8:07	8/23/2016	49996	LEAD	<1 PPB	15 PPB
77-12A Main Office Sink Faucet	8/6/2016 7:50	8/23/2016	49997	LEAD	4 PPB	15 PPB
77-13A Breakroom Sink Faucet	8/6/2016 7:53	8/23/2016	49998	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Paulus/Repo/Tech

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
77-07B 2nd Floor West Hall Drinking Fountain	8/6/2016 7:40	9/6/2016	53429	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Paulus

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
077-07C 2nd Floor West Hall Drinking Fountain	1/20/2017 5:41	1/23/2017	3130	LEAD	12 PPB	15 PPB
077-14C Paulus Office 101 Sink Faucet in Closet	1/20/2017 5:44	1/23/2017	3131	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level