

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Richmond Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
45-01A 1st Floor Hall (West) Drinking Fountain (Left) #1	7/27/2016 8:45	8/5/2016	44493	LEAD	2 PPB	15 PPB
45-02A 1st Floor Hall (West) Drinking Fountain(Right) #2	7/27/2016 8:47	8/5/2016	44494	LEAD	2 PPB	15 PPB
45-03A Room 10 Sink Faucet	7/27/2016 8:49	8/5/2016	44495	LEAD	2 PPB	15 PPB
45-04A Room 11 Sink Faucet	7/27/2016 8:51	8/5/2016	44496	LEAD	167 PPB	15 PPB
45-05A room 11 Drinking Fountain	7/27/2016 8:51	8/5/2016	44497	LEAD	16 PPB	15 PPB
45-06A Room 9 Sink Faucet	7/27/2016 8:53	8/5/2016	44498	LEAD	3 PPB	15 PPB
45-07A Room 9 Drinking Fountain	7/27/2016 8:53	8/5/2016	44499	LEAD	2 PPB	15 PPB
45-08A Room 12 Sink Faucet	7/27/2016 8:55	8/5/2016	44500	LEAD	21 PPB	15 PPB
45-09A Room 12 Drinking Fountain	7/27/2016 8:55	8/5/2016	44501	LEAD	2 PPB	15 PPB
45-10A Main Office Sink Faucet	7/27/2016 8:57	8/5/2016	44502	LEAD	2 PPB	15 PPB
45-11A Conference Room Sink Faucet	7/27/2016 8:59	8/5/2016	44503	LEAD	3 PPB	15 PPB
45-12A Room 8 Sink Faucet	7/27/2016 9:03	8/5/2016	44504	LEAD	2 PPB	15 PPB
45-13A Room 8 Drinking Fountain	7/27/2016 9:03	8/5/2016	44505	LEAD	3 PPB	15 PPB
45-14A Room 7 Sink Faucet	7/27/2016 9:05	8/5/2016	44506	LEAD	14 PPB	15 PPB
45-15A Room 7 Drinking Fountain	7/27/2016 9:05	8/5/2016	44507	LEAD	2 PPB	15 PPB
45-16A North Hallway Drinking Fountain #3	7/27/2016 9:07	8/11/2016	44508	LEAD	3 PPB	15 PPB
45-17A Room 6 Sink Faucet	7/27/2016 9:09	8/11/2016	44509	LEAD	4 PPB	15 PPB
45-18A Room 6 Drinking Fountian	7/27/2016 9:09	8/11/2016	44510	LEAD	2 PPB	15 PPB
45-19A room 5 Sink Faucet	7/27/2016 9:11	8/11/2016	44511	LEAD	7 PPB	15 PPB
45-20A Kitchen Sink Faucet (North)	7/27/2016 9:13	8/11/2016	44512	LEAD	6 PPB	15 PPB
45-21A Kitchen Sink Faucet (East Wall)	7/27/2016 9:15	8/11/2016	44513	LEAD	3 PPB	15 PPB
45-22A Main Hall Drinking Fountain #4	7/27/2016 9:18	8/11/2016	44514	LEAD	3 PPB	15 PPB
45-23A Room 4 Sink Faucet	7/27/2016 9:20	8/11/2016	44515	LEAD	2 PPB	15 PPB
45-24A Room 4 Drinking Fountain	7/27/2016 9:20	8/11/2016	44516	LEAD	4 PPB	15 PPB
45-25A Room 3 Sink Faucet	7/27/2016 9:22	8/11/2016	44517	LEAD	5 PPB	15 PPB
45-26A Room 1 Sink Faucet	7/27/2016 9:25	8/11/2016	44518	LEAD	4 PPB	15 PPB
45-27A Room 1 Drinking Fountain	7/27/2016 9:25	8/11/2016	44519	LEAD	5 PPB	15 PPB
45-28A Room 15 Sink Faucet	7/27/2016 9:29	8/11/2016	44520	LEAD	<1 PPB	15 PPB
45-29A Room 15 Drinking Fountain	7/27/2016 9:29	8/11/2016	44521	LEAD	1 PPB	15 PPB
45-30A Room 14 Sink Faucet	7/27/2016 9:31	8/11/2016	44522	LEAD	76 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Richmond Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
45-31A Room 14 Drinking Fountain	7/27/2016 9:31	8/11/2016	44523	LEAD	21 PPB	15 PPB
45-32A Staff Lounge Sink Faucet	7/27/2016 9:33	8/11/2016	44524	LEAD	36 PPB	15 PPB
45-33A Staff Lounge Drinking Fountain	7/27/2016 9:33	8/11/2016	44525	LEAD	2 PPB	15 PPB
45-34A Room 13 Sink Faucet	7/27/2016 9:35	8/11/2016	44526	LEAD	1 PPB	15 PPB
45-35A Room 13 Drinking Fountain	7/27/2016 9:35	8/11/2016	44527	LEAD	3 PPB	15 PPB
45-36A 2nd Floor Hall Drinking Fountain #5	7/27/2016 9:37	8/11/2016	44528	LEAD	2 PPB	15 PPB
45-37A Room 16 Sink Faucet	7/27/2016 9:39	8/11/2016	44529	LEAD	2 PPB	15 PPB
45-38A Room 16 Drinking Fountain	7/27/2016 9:39	8/11/2016	44530	LEAD	1 PPB	15 PPB
45-39A Room 20 Sink Faucet	7/27/2016 9:44	8/11/2016	44531	LEAD	11 PPB	15 PPB
45-40A Room 20 Drinking Fountain	7/27/2016 9:44	8/11/2016	44532	LEAD	5 PPB	15 PPB
45-41A Room 19 Sink Faucet	7/27/2016 9:46	8/11/2016	44533	LEAD	24 PPB	15 PPB
45-42A Room 19 Drinking Fountain	7/27/2016 9:46	8/11/2016	44534	LEAD	11 PPB	15 PPB
45-43A Book room Sink Faucet	7/27/2016 9:48	8/11/2016	44535	LEAD	<1 PPB	15 PPB
45-44A Room 17 Sink Faucet	7/27/2016 9:50	8/11/2016	44536	LEAD	<1 PPB	15 PPB
45-45A Room 17 Drinking Fountain	7/27/2016 9:50	8/11/2016	44537	LEAD	3 PPB	15 PPB
45-46A Room 21 Sink Faucet	7/27/2016 9:52	8/11/2016	44538	LEAD	15 PPB	15 PPB
45-47A Room 21 Drinking Fountain	7/27/2016 9:52	8/11/2016	44539	LEAD	3 PPB	15 PPB
45-48A 3rd floor hall Drinking Fountain #6	7/27/2016 9:54	8/12/2016	44540	LEAD	<1 PPB	15 PPB
45-49A Library Workroom Sink Faucet	7/27/2016 10:00	8/11/2016	44541	LEAD	3 PPB	15 PPB
45-50A Library Drinking Fountain (Left)	7/27/2016 10:02	8/11/2016	44542	LEAD	<1 PPB	15 PPB
45-51A Library Drinking Fountain (Right)	7/27/2016 10:03	8/11/2016	44543	LEAD	<1 PPB	15 PPB
45-52A Gymnasium Drinking Fountain	7/27/2016 10:20	8/11/2016	44544	LEAD	3 PPB	15 PPB
45-53A Portable Room 23 Sink Faucet	7/27/2016 10:24	8/11/2016	44545	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Richmond Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
45-04B Room 11 Sink Faucet	7/27/2016 8:52	9/6/2016	53415	LEAD	8 PPB	15 PPB
45-05B Room 11 Drinking Fountain	7/27/2016 8:52	9/6/2016	53416	LEAD	9 PPB	15 PPB
45-08B Room 12 Sink Faucet	7/27/2016 8:56	9/6/2016	53417	LEAD	3 PPB	15 PPB
45-30B Room 14 Sink Faucet	7/27/2016 9:32	9/6/2016	53418	LEAD	11 PPB	15 PPB
45-31B Room 14 Drinking Fountain	7/27/2016 9:32	9/6/2016	53419	LEAD	10 PPB	15 PPB
45-32B Staff Lounge Sink Faucet	7/27/2016 9:34	9/6/2016	53420	LEAD	1 PPB	15 PPB
45-41B Room 19 Sink Faucet	7/27/2016 9:47	9/6/2016	53421	LEAD	3 PPB	15 PPB
45-46B Room 21 Sink Faucet	7/27/2016 9:53	9/6/2016	53422	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Richmond Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
045-04C Room 11 Sink Faucet	9/23/2016 5:33	9/26/2016	58315	LEAD	158 PPB	15 PPB
045-05C Room 11 Drinking Fountain	9/23/2016 5:33	9/26/2016	58316	LEAD	6 PPB	15 PPB
045-08C Room 12 Sink Faucet	9/23/2016 5:36	9/26/2016	58317	LEAD	69 PPB	15 PPB
045-30C Room 14 Sink Faucet	9/23/2016 5:39	9/26/2016	58318	LEAD	76 PPB	15 PPB
045-31C Room 14 Drinking Fountain	9/23/2016 5:39	9/26/2016	58319	LEAD	12 PPB	15 PPB
045-32C Staff Lounge Sink Faucet	9/23/2016 5:42	9/26/2016	58320	LEAD	15 PPB	15 PPB
045-41C Room 19 Sink Faucet	9/23/2016 5:45	9/26/2016	58321	LEAD	9 PPB	15 PPB
045-46C Room 21 Sink Faucet	9/23/2016 5:47	9/26/2016	58322	LEAD	6 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (E) Sample Data  
 Richmond Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
045-04E Room 11 Sink Faucet	4/6/2017 6:47	4/11/2017	18164	LEAD	234 PPB	15 PPB
045-08E Room 12 Sink Faucet	4/6/2017 6:49	4/11/2017	18165	LEAD	17 PPB	15 PPB
045-30E Room 14 Sink Faucet	4/6/2017 6:52	4/11/2017	18166	LEAD	83 PPB	15 PPB
045-32E Staff Lounge Sink Faucet	4/6/2017 6:55	4/11/2017	18167	LEAD	45 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**