

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Roberts High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
46-01A Room 126 Sink Faucet	8/5/2016 10:33	8/23/2016	49999	LEAD	2 PPB	15 PPB
46-02A Room 132 Sink Faucet	8/5/2016 10:36	8/23/2016	50000	LEAD	3 PPB	15 PPB
46-03A Room 133/134 Sink Faucet (Kitchen)	8/5/2016 10:39	8/23/2016	50001	LEAD	5 PPB	15 PPB
46-04A Room 133/134 Sink Faucet (Classroom)	8/5/2016 10:39	8/23/2016	50002	LEAD	2 PPB	15 PPB
46-05A Gym Drinking Fountain (Left)	8/5/2016 10:41	8/23/2016	50003	LEAD	<1 PPB	15 PPB
46-06A Gym Drinking Fountain (Right)	8/5/2016 10:43	8/23/2016	50004	LEAD	<1 PPB	15 PPB
46-07A Staff Room Drinking Fountain	8/5/2016 10:50	8/23/2016	50005	LEAD	<1 PPB	15 PPB
46-08A Staff Room Sink Faucet	8/5/2016 10:51	8/23/2016	50006	LEAD	3 PPB	15 PPB
46-09A Room 202 Sink Faucet	8/5/2016 10:54	8/23/2016	50007	LEAD	2 PPB	15 PPB
46-10A Room 202 Drinking Fountain	8/5/2016 10:54	8/23/2016	50008	LEAD	3 PPB	15 PPB
46-11A Room 205 Sink Faucet	8/5/2016 10:57	8/23/2016	50009	LEAD	2 PPB	15 PPB
46-12A Room 205 Drinking Fountain	8/5/2016 10:57	8/23/2016	50010	LEAD	1 PPB	15 PPB
46-13A Double-Wide Kitchen Sink Faucet	8/5/2016 11:01	8/23/2016	50011	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level