

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Salem Heights Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Collected	Container ID	Tested For	Results	Action Level
047-01A	Staff Lounge Refrigerator Ice Maker	7/29/16 8:50 AM	8/5/2016	1608142-01A	COPPER	0.6 PPM	1.3 PPM
047-02A	Staff Lounge Sink Faucet	7/29/16 8:52 AM	8/5/2016	1608142-02A	COPPER	0.7 PPM	1.3 PPM
047-03A	Hall Drinking Fountain 1	7/29/16 9:00 AM	8/5/2016	1608142-03A	COPPER	0.4 PPM	1.3 PPM
047-04A	Classroom 6 Sink Faucet	7/29/16 10:02 AM	8/5/2016	1608142-04A	COPPER	0.6 PPM	1.3 PPM
047-05A	Classroom 6 Drinking Fountain	7/29/16 10:02 AM	8/5/2016	1608142-05A	COPPER	0.5 PPM	1.3 PPM
047-06A	Classroom 5 Sink Faucet	7/29/16 10:06 AM	8/5/2016	1608142-06A	COPPER	0.7 PPM	1.3 PPM
047-07A	Classroom 5 Drinking Fountain	7/29/16 10:06 AM	8/5/2016	1608142-07A	COPPER	0.6 PPM	1.3 PPM
047-08A	Classroom 4 Sink Faucet	7/29/16 10:17 AM	8/5/2016	1608142-08A	COPPER	0.9 PPM	1.3 PPM
047-09A	Classroom 4 Drinking Fountain	7/29/16 10:17 AM	8/5/2016	1608142-09A	COPPER	0.9 PPM	1.3 PPM
047-10A	Classroom 3 Sink Faucet	7/29/16 10:25 AM	8/5/2016	1608142-10A	COPPER	0.5 PPM	1.3 PPM
047-11A	Classroom 3 Drinking Fountain	7/29/16 10:25 AM	8/5/2016	1608142-11A	COPPER	0.5 PPM	1.3 PPM
047-12A	Hall Drinking Fountain 2	7/29/16 10:28 AM	8/5/2016	1608142-12A	COPPER	0.9 PPM	1.3 PPM
047-13A	Classroom 2 Sink Faucet	7/29/16 10:30 AM	8/5/2016	1608142-13A	COPPER	0.9 PPM	1.3 PPM
047-14A	Classroom 2 Drinking Fountain	7/29/16 10:30 AM	8/5/2016	1608142-14A	COPPER	0.6 PPM	1.3 PPM
047-15A	Classroom 1 Sink Faucet	7/29/16 10:35 AM	8/5/2016	1608142-15A	COPPER	0.7 PPM	1.3 PPM
047-16A	Classroom 1 Drinking Fountain	7/29/16 10:35 AM	8/6/2016	1608142-16A	COPPER	1.0 PPM	1.3 PPM
047-17A	Kitchen Food Prep Sink Faucet	7/29/16 10:10 AM	8/5/2016	1608142-17A	COPPER	0.5 PPM	1.3 PPM
047-18A	Cafeteria Drinking Fountain	7/29/16 10:12 AM	8/5/2016	1608142-18A	COPPER	0.7 PPM	1.3 PPM
047-19A	Office Sink Faucet	7/29/16 10:55 AM	8/5/2016	1608142-19A	COPPER	0.4 PPM	1.3 PPM
047-20A	Classroom 12 Sink Faucet	7/29/16 10:50 AM	8/5/2016	1608142-20A	COPPER	0.7 PPM	1.3 PPM
047-21A	Classroom 12 Drinking Fountain	7/29/16 9:50 AM	8/5/2016	1608142-21A	COPPER	0.9 PPM	1.3 PPM
047-22A	Classroom 11 Sink Faucet	7/29/16 9:45 AM	8/5/2016	1608142-22A	COPPER	0.7 PPM	1.3 PPM
047-23A	Classroom 11 Drinking Fountain	7/29/16 9:45 AM	8/5/2016	1608142-23A	COPPER	0.8 PPM	1.3 PPM
047-24A	Hall Drinking Fountain 3	7/29/16 9:10 AM	8/6/2016	1608142-24A	COPPER	1.1 PPM	1.3 PPM
047-25A	Hall Drinking Fountain 4	7/29/16 9:10 AM	8/6/2016	1608142-25A	COPPER	1.1 PPM	1.3 PPM
047-26A	Faculty WorkClassroom Sink Faucet	7/29/16 9:07 AM	8/5/2016	1608142-26A	COPPER	0.7 PPM	1.3 PPM
047-27A	Hall Drinking Fountain 5	7/29/16 9:13 AM	8/5/2016	1608142-27A	COPPER	0.8 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Salem Heights Elementary School

047-28A	Classroom 13 Sink Faucet	7/29/16 9:17 AM	8/5/2016	1608142-28A	COPPER	0.7	PPM	1.3 PPM
047-29A	Classroom 13 Drinking Fountain	7/29/16 9:17 AM	8/5/2016	1608142-29A	COPPER	0.6	PPM	1.3 PPM
047-30A	Classroom 14 Sink Faucet	7/29/16 9:19 AM	8/5/2016	1608142-30A	COPPER	0.7	PPM	1.3 PPM
047-31A	Classroom 14 Drinking Fountain	7/29/16 9:19 AM	8/5/2016	1608142-31A	COPPER	0.9	PPM	1.3 PPM
047-32A	Music 18 Sink Faucet	7/29/16 9:26 AM	8/5/2016	1608142-32A	COPPER	0.6	PPM	1.3 PPM
047-33A	Music 18 Drinking Fountain	7/29/16 9:26 AM	8/5/2016	1608142-33A	COPPER	0.6	PPM	1.3 PPM
047-34A	Classroom 18 Sink Faucet	7/29/16 9:23 AM	8/5/2016	1608142-34A	COPPER	0.7	PPM	1.3 PPM
047-35A	Classroom 18 Drinking Fountain	7/29/16 9:23 AM	8/5/2016	1608142-35A	COPPER	0.8	PPM	1.3 PPM
047-36A	Classroom 16 Sink Faucet	7/29/16 9:30 AM	8/5/2016	1608142-36A	COPPER	0.7	PPM	1.3 PPM
047-37A	Classroom 16 Drinking Fountain	7/29/16 9:30 AM	8/5/2016	1608142-37A	COPPER	0.8	PPM	1.3 PPM
047-38A	Classroom 17 Sink Faucet	7/29/16 9:38 AM	8/5/2016	1608142-38A	COPPER	0.8	PPM	1.3 PPM
047-39A	Classroom 17 Drinking Fountain	7/29/16 9:38 AM	8/5/2016	1608142-39A	COPPER	0.8	PPM	1.3 PPM
047-40A	Classroom 20 Sink Faucet	7/29/16 9:41 AM	8/5/2016	1608142-40A	COPPER	0.7	PPM	1.3 PPM
047-41A	Classroom 20 Drinking Fountain	7/29/16 9:41 AM	8/5/2016	1608142-41A	COPPER	0.7	PPM	1.3 PPM
047-42A	Classroom 23 Sink Faucet	7/29/16 12:19 PM	8/5/2016	1608142-42A	COPPER	0.1	PPM	1.3 PPM
047-43A	Classroom 24 Sink Faucet	7/29/16 12:21 PM	8/5/2016	1608142-43A	COPPER	0.3	PPM	1.3 PPM
047-45A	Classroom 19 Sink Faucet	7/29/16 9:34 AM	8/5/2016	1608142-44A	COPPER	0.8	PPM	1.3 PPM
047-46A	Classroom 19 Drinking Fountain	7/29/16 9:34 AM	8/5/2016	1608142-45A	COPPER	0.6	PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Copper Water Sampling Results
 Flushed (B) Sample Data
 Salem Heights Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
047-28B Classroom 13 Sink Faucet	7/29/16 9:18 AM	8/31/2016	1608143-27A	COPPER	0.8 PPM	1.3 PPM
EPA Action Level for Copper in Schools is 1.3 PPM						
SKPS Action Level for Copper is 1.3 PPM						
Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level						