

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Salem Heights Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Collected	Container ID	Tested For	Results	Action Level
047-01A	Staff Lounge Refrigerator Ice Maker	7/29/16 8:50 AM	8/5/2016	1608142-01A	LEAD	<1.0 PPB	15 PPB
047-02A	Staff Lounge Sink Faucet	7/29/16 8:52 AM	8/5/2016	1608142-02A	LEAD	<1.0 PPB	15 PPB
047-03A	Hall Drinking Fountain 1	7/29/16 9:00 AM	8/5/2016	1608142-03A	LEAD	5 PPB	15 PPB
047-04A	Classroom 6 Sink Faucet	7/29/16 10:02 AM	8/5/2016	1608142-04A	LEAD	<1.0 PPB	15 PPB
047-05A	Classroom 6 Drinking Fountain	7/29/16 10:02 AM	8/5/2016	1608142-05A	LEAD	5 PPB	15 PPB
047-06A	Classroom 5 Sink Faucet	7/29/16 10:06 AM	8/5/2016	1608142-06A	LEAD	1 PPB	15 PPB
047-07A	Classroom 5 Drinking Fountain	7/29/16 10:06 AM	8/5/2016	1608142-07A	LEAD	4 PPB	15 PPB
047-08A	Classroom 4 Sink Faucet	7/29/16 10:17 AM	8/5/2016	1608142-08A	LEAD	<1.0 PPB	15 PPB
047-09A	Classroom 4 Drinking Fountain	7/29/16 10:17 AM	8/5/2016	1608142-09A	LEAD	1 PPB	15 PPB
047-10A	Classroom 3 Sink Faucet	7/29/16 10:25 AM	8/5/2016	1608142-10A	LEAD	<1.0 PPB	15 PPB
047-11A	Classroom 3 Drinking Fountain	7/29/16 10:25 AM	8/5/2016	1608142-11A	LEAD	4 PPB	15 PPB
047-12A	Hall Drinking Fountain 2	7/29/16 10:28 AM	8/5/2016	1608142-12A	LEAD	<1.0 PPB	15 PPB
047-13A	Classroom 2 Sink Faucet	7/29/16 10:30 AM	8/5/2016	1608142-13A	LEAD	2 PPB	15 PPB
047-14A	Classroom 2 Drinking Fountain	7/29/16 10:30 AM	8/5/2016	1608142-14A	LEAD	<1.0 PPB	15 PPB
047-15A	Classroom 1 Sink Faucet	7/29/16 10:35 AM	8/5/2016	1608142-15A	LEAD	<1.0 PPB	15 PPB
047-16A	Classroom 1 Drinking Fountain	7/29/16 10:35 AM	8/6/2016	1608142-16A	LEAD	2 PPB	15 PPB
047-17A	Kitchen Food Prep Sink Faucet	7/29/16 10:10 AM	8/5/2016	1608142-17A	LEAD	2 PPB	15 PPB
047-18A	Cafeteria Drinking Fountain	7/29/16 10:12 AM	8/5/2016	1608142-18A	LEAD	13 PPB	15 PPB
047-19A	Office Sink Faucet	7/29/16 10:55 AM	8/5/2016	1608142-19A	LEAD	6 PPB	15 PPB
047-20A	Classroom 12 Sink Faucet	7/29/16 10:50 AM	8/5/2016	1608142-20A	LEAD	<1.0 PPB	15 PPB
047-21A	Classroom 12 Drinking Fountain	7/29/16 9:50 AM	8/5/2016	1608142-21A	LEAD	4 PPB	15 PPB
047-22A	Classroom 11 Sink Faucet	7/29/16 9:45 AM	8/5/2016	1608142-22A	LEAD	<1.0 PPB	15 PPB
047-23A	Classroom 11 Drinking Fountain	7/29/16 9:45 AM	8/5/2016	1608142-23A	LEAD	3 PPB	15 PPB
047-24A	Hall Drinking Fountain 3	7/29/16 9:10 AM	8/6/2016	1608142-24A	LEAD	3 PPB	15 PPB
047-25A	Hall Drinking Fountain 4	7/29/16 9:10 AM	8/6/2016	1608142-25A	LEAD	2 PPB	15 PPB
047-26A	Faculty WorkClassroom Sink Faucet	7/29/16 9:07 AM	8/5/2016	1608142-26A	LEAD	1 PPB	15 PPB
047-27A	Hall Drinking Fountain 5	7/29/16 9:13 AM	8/5/2016	1608142-27A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Salem Heights Elementary School

047-28A	Classroom 13 Sink Faucet	7/29/16 9:17 AM	8/5/2016	1608142-28A	LEAD	16	PPB	15 PPB
047-29A	Classroom 13 Drinking Fountain	7/29/16 9:17 AM	8/5/2016	1608142-29A	LEAD	5	PPB	15 PPB
047-30A	Classroom 14 Sink Faucet	7/29/16 9:19 AM	8/5/2016	1608142-30A	LEAD	1	PPB	15 PPB
047-31A	Classroom 14 Drinking Fountain	7/29/16 9:19 AM	8/5/2016	1608142-31A	LEAD	4	PPB	15 PPB
047-32A	Music 18 Sink Faucet	7/29/16 9:26 AM	8/5/2016	1608142-32A	LEAD	<1.0	PPB	15 PPB
047-33A	Music 18 Drinking Fountain	7/29/16 9:26 AM	8/5/2016	1608142-33A	LEAD	4	PPB	15 PPB
047-34A	Classroom 18 Sink Faucet	7/29/16 9:23 AM	8/5/2016	1608142-34A	LEAD	<1.0	PPB	15 PPB
047-35A	Classroom 18 Drinking Fountain	7/29/16 9:23 AM	8/5/2016	1608142-35A	LEAD	5	PPB	15 PPB
047-36A	Classroom 16 Sink Faucet	7/29/16 9:30 AM	8/5/2016	1608142-36A	LEAD	<1.0	PPB	15 PPB
047-37A	Classroom 16 Drinking Fountain	7/29/16 9:30 AM	8/5/2016	1608142-37A	LEAD	3	PPB	15 PPB
047-38A	Classroom 17 Sink Faucet	7/29/16 9:38 AM	8/5/2016	1608142-38A	LEAD	<1.0	PPB	15 PPB
047-39A	Classroom 17 Drinking Fountain	7/29/16 9:38 AM	8/5/2016	1608142-39A	LEAD	3	PPB	15 PPB
047-40A	Classroom 20 Sink Faucet	7/29/16 9:41 AM	8/5/2016	1608142-40A	LEAD	<1.0	PPB	15 PPB
047-41A	Classroom 20 Drinking Fountain	7/29/16 9:41 AM	8/5/2016	1608142-41A	LEAD	3	PPB	15 PPB
047-42A	Classroom 23 Sink Faucet	7/29/16 12:19 PM	8/5/2016	1608142-42A	LEAD	3	PPB	15 PPB
047-43A	Classroom 24 Sink Faucet	7/29/16 12:21 PM	8/5/2016	1608142-43A	LEAD	3	PPB	15 PPB
047-45A	Classroom 19 Sink Faucet	7/29/16 9:34 AM	8/5/2016	1608142-44A	LEAD	2	PPB	15 PPB
047-46A	Classroom 19 Drinking Fountain	7/29/16 9:34 AM	8/5/2016	1608142-45A	LEAD	<1.0	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 Flushed (B) Sample Data  
 Salem Heights Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
047-28B Classroom 13 Sink Faucet	7/29/16 9:18 AM	8/31/2016	1608143-27A	LEAD	2 PPB	15 PPB
EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
<b>Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level</b>						

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Salem Heights Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Collected	Container ID	Tested For	Results		Action Level
047-47A	Basement Room 21 Drinking Fountain	9/1/2017 8:14	9/5/2017	50667	LEAD	11	PPB	15 PPB
047-48A	Basement Storage Sink Faucet	9/1/2017 8:13	9/5/2017	50668	LEAD	1	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level