

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Schirle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
48-01A Cafeteria Drinking Fountain	8/13/2016 9:50	8/23/2016	50062	COPPER	0.3 PPM	1.3 PPM
48-02A Kitchen Sink Faucet #1	8/13/2016 9:53	8/23/2016	50063	COPPER	0.1 PPM	1.3 PPM
48-03A Kitchen Sink Faucet #2	8/13/2016 9:53	8/23/2016	50064	COPPER	0.3 PPM	1.3 PPM
48-04A Hallway Drinking Fountain #1	8/13/2016 5:56	8/23/2016	50065	COPPER	0.6 PPM	1.3 PPM
48-05A Staff Room Sink Faucet	8/13/2016 9:58	8/23/2016	50066	COPPER	0.2 PPM	1.3 PPM
48-06A Gymnasium Drinking Fountain	8/13/2016 10:00	8/23/2016	50067	COPPER	0.5 PPM	1.3 PPM
48-07A Breakfast Room Sink Faucet	8/13/2016 10:03	8/23/2016	50068	COPPER	0.4 PPM	1.3 PPM
48-08A Breakfast Room Sink Faucet	8/13/2016 10:03	8/23/2016	50069	COPPER	0.3 PPM	1.3 PPM
48-09A LRC Room Sink Faucet	8/13/2016 10:06	8/23/2016	50070	COPPER	0.2 PPM	1.3 PPM
48-10A Hallway Drinking Fountain #2	8/13/2016 10:08	8/23/2016	50071	COPPER	0.5 PPM	1.3 PPM
48-11A E6 Sink Faucet	8/13/2016 10:12	8/23/2016	50072	COPPER	0.2 PPM	1.3 PPM
48-12A E6 Drinking Fountain	8/13/2016 10:12	8/23/2016	50073	COPPER	0.4 PPM	1.3 PPM
48-13A E5 Sink Faucet	8/13/2016 10:14	8/23/2016	50074	COPPER	0.2 PPM	1.3 PPM
48-14A E5 Drinking Fountain	8/13/2016 10:14	8/23/2016	50075	COPPER	0.5 PPM	1.3 PPM
48-15A E4 Sink Faucet	8/13/2016 10:16	8/23/2016	50076	COPPER	0.2 PPM	1.3 PPM
48-16A E4 Drinking Fountain	8/13/2016 10:16	8/23/2016	50077	COPPER	0.4 PPM	1.3 PPM
48-17A E3 Sink Faucet	8/13/2016 10:18	8/23/2016	50078	COPPER	0.3 PPM	1.3 PPM
48-18A E3 Drinking Fountain	8/13/2016 10:18	8/23/2016	50079	COPPER	0.4 PPM	1.3 PPM
48-19A E2 Sink Faucet	8/13/2016 10:20	8/23/2016	50080	COPPER	0.3 PPM	1.3 PPM
48-20A E2 Drinking Fountain	8/13/2016 10:20	8/23/2016	50081	COPPER	0.5 PPM	1.3 PPM
48-21A E1 Sink Faucet	8/13/2016 10:22	8/23/2016	50082	COPPER	0.3 PPM	1.3 PPM
48-22A E1 Drinking Fountain	8/13/2016 10:22	8/23/2016	50083	COPPER	0.5 PPM	1.3 PPM
48-23A Office Sink Faucet #1	8/13/2016 10:28	8/23/2016	50084	COPPER	0.4 PPM	1.3 PPM
48-24A Office Drinking Fountain	8/13/2016 10:28	8/23/2016	50085	COPPER	0.6 PPM	1.3 PPM
48-25A Office Sink Faucet #2	8/13/2016 10:30	8/23/2016	50086	COPPER	0.4 PPM	1.3 PPM
48-26A Hallway Drinking Fountain #3	8/13/2016 10:32	8/23/2016	50087	COPPER	0.4 PPM	1.3 PPM
48-27A Hallway Sink Faucet	8/13/2016 10:35	8/23/2016	50088	COPPER	0.4 PPM	1.3 PPM
48-28A B1 Sink Faucet	8/13/2016 10:40	8/23/2016	50089	COPPER	0.4 PPM	1.3 PPM
48-29A B1 Drinking Fountain	8/13/2016 10:40	8/23/2016	50090	COPPER	0.6 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Schirle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
48-30A B2 Sink Faucet	8/13/2016 10:42	8/23/2016	50091	COPPER	0.3 PPM	1.3 PPM
48-31A B2 Drinking Fountain	8/13/2016 10:42	8/23/2016	50092	COPPER	0.5 PPM	1.3 PPM
48-32A B3 Sink Faucet	8/13/2016 10:44	8/23/2016	50093	COPPER	0.3 PPM	1.3 PPM
48-33A B3 Drinking Fountain	8/13/2016 10:44	8/23/2016	50094	COPPER	0.5 PPM	1.3 PPM
48-34A Hallway Drinking Fountain #4	8/13/2016 10:46	8/23/2016	50095	COPPER	0.5 PPM	1.3 PPM
48-35A B4 Sink Faucet	8/13/2016 10:48	8/23/2016	50096	COPPER	0.3 PPM	1.3 PPM
48-36A B4 Drinking Fountain	8/13/2016 10:48	8/23/2016	50097	COPPER	0.3 PPM	1.3 PPM
48-37A B5 Sink Faucet	8/13/2016 10:50	8/23/2016	50098	COPPER	0.2 PPM	1.3 PPM
48-38A B5 Drinking Fountain	8/13/2016 10:50	8/23/2016	50099	COPPER	0.3 PPM	1.3 PPM
48-39A B6 Sink Faucet	8/13/2016 10:52	8/23/2016	50100	COPPER	0.2 PPM	1.3 PPM
48-40A B6 Drinking Fountain	8/13/2016 10:52	8/23/2016	50101	COPPER	0.5 PPM	1.3 PPM
48-41A C1 Sink Faucet	8/13/2016 10:55	8/23/2016	50102	COPPER	0.3 PPM	1.3 PPM
48-42A C1 Drinking Fountain	8/13/2016 10:55	8/23/2016	50103	COPPER	0.5 PPM	1.3 PPM
48-43A C2 Sink Faucet	8/13/2016 10:57	8/23/2016	50104	COPPER	0.2 PPM	1.3 PPM
48-44A C2 Drinking Fountain	8/13/2016 10:57	8/23/2016	50105	COPPER	0.3 PPM	1.3 PPM
48-45A C3 Sink Faucet	8/13/2016 10:59	8/23/2016	50106	COPPER	0.2 PPM	1.3 PPM
48-46A C3 Drinking Fountain	8/13/2016 10:59	8/23/2016	50107	COPPER	0.4 PPM	1.3 PPM
48-47A Hallway Drinking Fountain #5	8/13/2016 11:01	8/23/2016	50108	COPPER	0.3 PPM	1.3 PPM
48-48A C4 Sink Faucet	8/13/2016 11:03	8/23/2016	50109	COPPER	0.2 PPM	1.3 PPM
48-49A C4 Drinking Fountain	8/13/2016 11:03	8/23/2016	50110	COPPER	0.3 PPM	1.3 PPM
48-50A C5 Sink Faucet	8/13/2016 11:05	8/23/2016	50111	COPPER	0.2 PPM	1.3 PPM
48-51A C5 Drinking Fountain	8/13/2016 11:05	8/23/2016	50112	COPPER	0.3 PPM	1.3 PPM
48-52A C6 Sink Faucet	8/13/2016 11:07	8/23/2016	50113	COPPER	0.3 PPM	1.3 PPM
48-53A C6 Drinking Fountain	8/13/2016 11:07	8/23/2016	50114	COPPER	0.4 PPM	1.3 PPM
48-54A Life Skills Drinking Fountain	8/13/2016 11:15	8/24/2016	50115	COPPER	2.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Schirle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
48-54B Life Skills Drinking Fountain	8/13/2016 11:30	9/6/2016	52937	COPPER	3.8 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Schirle Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
048-54C Life Skills Drinking Fountain	1/6/2017 6:40	1/9/2017	793	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level