

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-01A Kitchen Sink Faucet	7/28/16 15:03	8/3/2016	1608009-01A	COPPER	0.1 PPM	1.3 PPM
049-02A Cafeteria Sink Faucet	7/28/16 15:04	8/3/2016	1608009-02A	COPPER	0.0 PPM	1.3 PPM
049-03A Cafeteria Drinking Fountain	7/28/16 15:04	8/3/2016	1608009-03A	COPPER	0.0 PPM	1.3 PPM
049-04A Break Room Sink Faucet	7/28/16 15:00	8/3/2016	1608009-04A	COPPER	0.5 PPM	1.3 PPM
049-05A MRS Power Room Sink Faucet	7/28/16 15:10	8/3/2016	1608009-05A	COPPER	0.1 PPM	1.3 PPM
049-06A MRS Power Room Sink Faucet	7/28/16 15:10	8/3/2016	1608009-06A	COPPER	0.0 PPM	1.3 PPM
049-07A Music Room Sink Faucet	7/28/16 15:46	8/3/2016	1608009-07A	COPPER	0.0 PPM	1.3 PPM
049-08A Music Room Drinking Fountain	7/28/16 15:46	8/3/2016	1608009-08A	COPPER	0.1 PPM	1.3 PPM
049-09A Music Room Sink Faucet	7/28/16 15:48	8/2/2016	1608009-09A	COPPER	0.0 PPM	1.3 PPM
049-10A Room A7 Sink Faucet	7/28/16 15:06	8/2/2016	1608009-10A	COPPER	0.1 PPM	1.3 PPM
049-11A Hall Drinking Fountain 1	7/28/16 15:16	8/3/2016	1608009-11A	COPPER	0.0 PPM	1.3 PPM
049-12A Room A1 Sink Faucet	7/28/16 15:12	8/2/2016	1608009-12A	COPPER	0.0 PPM	1.3 PPM
049-13A Room A1 Drinking Fountain	7/28/16 15:12	8/3/2016	1608009-13A	COPPER	0.0 PPM	1.3 PPM
049-14A Room A2 Sink Faucet	7/28/16 15:13	8/3/2016	1608009-14A	COPPER	0.0 PPM	1.3 PPM
049-15A Room A2 Drinking Fountain	7/28/16 15:13	8/3/2016	1608009-15A	COPPER	0.0 PPM	1.3 PPM
049-16A Room A3 Sink Faucet	7/28/16 15:18	8/2/2016	1608009-16A	COPPER	0.0 PPM	1.3 PPM
049-17A Room A3 Drinking Fountain	7/28/16 15:18	8/3/2016	1608009-17A	COPPER	0.0 PPM	1.3 PPM
049-18A Room A4 Sink Faucet	7/28/16 15:19	8/2/2016	1608009-18A	COPPER	0.0 PPM	1.3 PPM
049-19A Room A4 Drinking Fountain	7/28/16 15:19	8/3/2016	1608009-19A	COPPER	0.0 PPM	1.3 PPM
049-20A Room A5 Sink Faucet	7/28/16 15:22	8/3/2016	1608009-20A	COPPER	0.0 PPM	1.3 PPM
049-21A Room A5 Drinking Fountain	7/28/16 15:22	8/3/2016	1608009-21A	COPPER	0.0 PPM	1.3 PPM
049-22A Room A5 Sink Faucet	7/28/16 16:04	8/3/2016	1608009-22A	COPPER	0.0 PPM	1.3 PPM
049-23A Room A6 Sink Faucet	7/28/16 15:30	8/3/2016	1608009-23A	COPPER	0.0 PPM	1.3 PPM
049-24A Room A6 Sink Faucet	7/28/16 15:31	8/2/2016	1608009-24A	COPPER	0.0 PPM	1.3 PPM
049-25A Room A6 Drinking Fountain	7/28/16 15:31	8/3/2016	1608009-25A	COPPER	0.0 PPM	1.3 PPM
049-26A Hall Drinking Fountain 2	7/28/16 15:26	8/3/2016	1608009-26A	COPPER	<0.005 PPM	1.3 PPM
049-27A Main Office Sink Faucet	7/28/16 15:38	8/2/2016	1608009-27A	COPPER	0.1 PPM	1.3 PPM
049-28A Craft Room Sink Faucet	7/28/16 15:40	8/3/2016	1608009-28A	COPPER	0.0 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Scott Elementary School

049-29A	Media Room Drinking Fountain	7/28/16 15:42	8/3/2016	1608009-29A	COPPER	0.0	PPM	1.3 PPM
049-30A	Hall Drinking Fountain 3	7/28/16 15:20	8/3/2016	1608009-30A	COPPER	0.0	PPM	1.3 PPM
049-31A	Room B1 Sink Faucet	7/28/16 15:22	8/2/2016	1608009-31A	COPPER	0.0	PPM	1.3 PPM
049-32A	Room B1 Drinking Fountain	7/28/16 15:22	8/3/2016	1608009-32A	COPPER	0.0	PPM	1.3 PPM
049-33A	Room B2 Sink Faucet	7/28/16 15:24	8/2/2016	1608009-33A	COPPER	0.1	PPM	1.3 PPM
049-34A	Room B2 Drinking Fountain	7/28/16 15:24	8/3/2016	1608009-34A	COPPER	0.0	PPM	1.3 PPM
049-35A	Room B3 Sink Faucet	7/28/16 15:28	8/3/2016	1608009-35A	COPPER	0.0	PPM	1.3 PPM
049-36A	Room B3 Drinking Fountain	7/28/16 15:28	8/3/2016	1608009-36A	COPPER	0.0	PPM	1.3 PPM
049-37A	Room B4 Sink Faucet	7/28/16 15:30	8/3/2016	1608009-37A	COPPER	0.0	PPM	1.3 PPM
049-38A	Room B4 Drinking Fountain	7/28/16 15:30	8/3/2016	1608009-38A	COPPER	0.0	PPM	1.3 PPM
049-39A	Room B5 Sink Faucet	7/28/16 15:48	8/3/2016	1608009-39A	COPPER	0.0	PPM	1.3 PPM
049-40A	Room B5 Drinking Fountain	7/28/16 15:48	8/3/2016	1608009-40A	COPPER	0.0	PPM	1.3 PPM
049-41A	Room B6 Sink Faucet	7/28/16 15:34	8/4/2016	1608009-41A	COPPER	0.0	PPM	1.3 PPM
049-42A	Room B6 Drinking Fountain	7/28/16 15:34	8/4/2016	1608009-42A	COPPER	0.0	PPM	1.3 PPM
049-43A	Hall Drinking Fountain 4	7/28/16 16:48	8/4/2016	1608009-43A	COPPER	0.0	PPM	1.3 PPM
049-44A	Room C1 Sink Faucet	7/28/16 15:38	8/4/2016	1608009-44A	COPPER	0.0	PPM	1.3 PPM
049-45A	Room C1 Drinking Fountain	7/28/16 15:38	8/4/2016	1608009-45A	COPPER	0.0	PPM	1.3 PPM
049-46A	Room C2 Sink Faucet	7/28/16 15:40	8/2/2016	1608009-46A	COPPER	0.0	PPM	1.3 PPM
049-47A	Room C2 Drinking Fountain	7/28/16 15:40	8/4/2016	1608009-47A	COPPER	0.0	PPM	1.3 PPM
049-48A	Room C3 Sink Faucet	7/28/16 15:44	8/4/2016	1608009-48A	COPPER	0.0	PPM	1.3 PPM
049-49A	Room C3 Drinking Fountain	7/28/16 15:44	8/4/2016	1608009-49A	COPPER	0.0	PPM	1.3 PPM
049-50A	Room C4 Sink Faucet	7/28/16 15:46	8/2/2016	1608009-50A	COPPER	0.0	PPM	1.3 PPM
049-51A	Room C4 Drinking Fountain	7/28/16 15:46	8/4/2016	1608009-51A	COPPER	0.0	PPM	1.3 PPM
049-52A	Room C5 Sink Faucet	7/28/16 15:41	8/2/2016	1608009-52A	COPPER	0.0	PPM	1.3 PPM
049-53A	Room C5 Drinking Fountain	7/28/16 15:41	8/4/2016	1608009-53A	COPPER	0.0	PPM	1.3 PPM
049-54A	Room C6 Sink Faucet	7/28/16 15:46	8/4/2016	1608009-54A	COPPER	0.0	PPM	1.3 PPM
049-55A	Room C6 Drinking Fountain	7/28/16 15:46	8/4/2016	1608009-55A	COPPER	0.0	PPM	1.3 PPM
049-56A	Room N2 Drinking Fountain	7/28/16 16:22	8/5/2016	1608009-56A	COPPER	1.0	PPM	1.3 PPM
049-57A	Room N6 Sink Faucet	7/28/16 16:25	8/2/2016	1608009-57A	COPPER	0.0	PPM	1.3 PPM
049-58A	Room N6 Drinking Fountain	7/28/16 16:25	8/4/2016	1608009-58A	COPPER	0.0	PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Scott Elementary School

049-59A	Room N7 Sink Faucet	7/28/16 16:29	8/4/2016	1608009-59A	COPPER	0.0	PPM	1.3 PPM
049-60A	Room N7 Drinking Fountain	7/28/16 16:29	8/4/2016	1608009-60A	COPPER	0.0	PPM	1.3 PPM
049-61A	Room N8 Sink Faucet	7/28/16 16:34	8/4/2016	1608009-61A	COPPER	0.0	PPM	1.3 PPM
049-62A	Room N8 Drinking Fountain	7/28/16 16:34	8/4/2016	1608009-62A	COPPER	0.0	PPM	1.3 PPM
049-63A	Room N9 Sink Faucet	7/28/16 16:36	8/4/2016	1608009-63A	COPPER	0.0	PPM	1.3 PPM
049-64A	Room N9 Drinking Fountain	7/28/16 16:36	8/4/2016	1608009-64A	COPPER	0.0	PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-01B Kitchen Sink Faucet	7/28/16 15:04	8/24/2016	1608010-01A	COPPER	0.0 PPM	1.3 PPM
049-04B Break Room Sink Faucet	7/28/16 15:01	8/24/2016	1608010-04A	COPPER	0.1 PPM	1.3 PPM
049-05B MRS Power Room Sink Faucet	7/28/16 15:11	8/24/2016	1608010-05A	COPPER	0.0 PPM	1.3 PPM
049-10B Room A7 Sink Faucet	7/28/16 15:07	8/24/2016	1608010-10A	COPPER	0.0 PPM	1.3 PPM
049-29B Media Room Drinking Fountain	7/28/16 15:43	8/24/2016	1608010-29A	COPPER	<0.005 PPM	1.3 PPM
049-30B Hall Drinking Fountain 3	7/28/16 15:21	8/24/2016	1608010-30A	COPPER	0.0 PPM	1.3 PPM
049-43B Hall Drinking Fountain 4	7/28/16 16:49	8/24/2016	1608010-43A	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (D) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-43D Hall Drinking Fountain 4	11/18/2016 5:47	2/1/2017	4392	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (E) Sample Data
Scott Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
049-43E Hall Drinking Fountain 4	4/6/2017 8:13	4/11/2017	18162	LEAD	21 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level