

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Scott Elementary School

| Sample Identification # and Location | | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | | Action Level |
|--------------------------------------|------------------------------|-------------------|---------------|--------------|------------|---------|-----|--------------|
| 049-01A | Kitchen Sink Faucet | 7/28/16 15:03 | 8/3/2016 | 1608009-01A | LEAD | 20 | PPB | 15 PPB |
| 049-02A | Cafeteria Sink Faucet | 7/28/16 15:04 | 8/3/2016 | 1608009-02A | LEAD | 10 | PPB | 15 PPB |
| 049-03A | Cafeteria Drinking Fountain | 7/28/16 15:04 | 8/3/2016 | 1608009-03A | LEAD | 4 | PPB | 15 PPB |
| 049-04A | Break Room Sink Faucet | 7/28/16 15:00 | 8/3/2016 | 1608009-04A | LEAD | 150 | PPB | 15 PPB |
| 049-05A | MRS Power Room Sink Faucet | 7/28/16 15:10 | 8/3/2016 | 1608009-05A | LEAD | 120 | PPB | 15 PPB |
| 049-06A | MRS Power Room Sink Faucet | 7/28/16 15:10 | 8/3/2016 | 1608009-06A | LEAD | 6 | PPB | 15 PPB |
| 049-07A | Music Room Sink Faucet | 7/28/16 15:46 | 8/3/2016 | 1608009-07A | LEAD | 2 | PPB | 15 PPB |
| 049-08A | Music Room Drinking Fountain | 7/28/16 15:46 | 8/3/2016 | 1608009-08A | LEAD | 8 | PPB | 15 PPB |
| 049-09A | Music Room Sink Faucet | 7/28/16 15:48 | 8/2/2016 | 1608009-09A | LEAD | 3 | PPB | 15 PPB |
| 049-10A | Room A7 Sink Faucet | 7/28/16 15:06 | 8/2/2016 | 1608009-10A | LEAD | 17 | PPB | 15 PPB |
| 049-11A | Hall Drinking Fountain 1 | 7/28/16 15:16 | 8/3/2016 | 1608009-11A | LEAD | 4 | PPB | 15 PPB |
| 049-12A | Room A1 Sink Faucet | 7/28/16 15:12 | 8/2/2016 | 1608009-12A | LEAD | 5 | PPB | 15 PPB |
| 049-13A | Room A1 Drinking Fountain | 7/28/16 15:12 | 8/3/2016 | 1608009-13A | LEAD | 3 | PPB | 15 PPB |
| 049-14A | Room A2 Sink Faucet | 7/28/16 15:13 | 8/3/2016 | 1608009-14A | LEAD | 4 | PPB | 15 PPB |
| 049-15A | Room A2 Drinking Fountain | 7/28/16 15:13 | 8/3/2016 | 1608009-15A | LEAD | 3 | PPB | 15 PPB |
| 049-16A | Room A3 Sink Faucet | 7/28/16 15:18 | 8/2/2016 | 1608009-16A | LEAD | 10 | PPB | 15 PPB |
| 049-17A | Room A3 Drinking Fountain | 7/28/16 15:18 | 8/3/2016 | 1608009-17A | LEAD | 6 | PPB | 15 PPB |
| 049-18A | Room A4 Sink Faucet | 7/28/16 15:19 | 8/2/2016 | 1608009-18A | LEAD | 5 | PPB | 15 PPB |
| 049-19A | Room A4 Drinking Fountain | 7/28/16 15:19 | 8/3/2016 | 1608009-19A | LEAD | 3 | PPB | 15 PPB |
| 049-20A | Room A5 Sink Faucet | 7/28/16 15:22 | 8/3/2016 | 1608009-20A | LEAD | 4 | PPB | 15 PPB |
| 049-21A | Room A5 Drinking Fountain | 7/28/16 15:22 | 8/3/2016 | 1608009-21A | LEAD | 3 | PPB | 15 PPB |
| 049-22A | Room A5 Sink Faucet | 7/28/16 16:04 | 8/3/2016 | 1608009-22A | LEAD | 4 | PPB | 15 PPB |
| 049-23A | Room A6 Sink Faucet | 7/28/16 15:30 | 8/3/2016 | 1608009-23A | LEAD | 3 | PPB | 15 PPB |
| 049-24A | Room A6 Sink Faucet | 7/28/16 15:31 | 8/2/2016 | 1608009-24A | LEAD | 3 | PPB | 15 PPB |
| 049-25A | Room A6 Drinking Fountain | 7/28/16 15:31 | 8/3/2016 | 1608009-25A | LEAD | 2 | PPB | 15 PPB |
| 049-26A | Hall Drinking Fountain 2 | 7/28/16 15:26 | 8/3/2016 | 1608009-26A | LEAD | 2 | PPB | 15 PPB |
| 049-27A | Main Office Sink Faucet | 7/28/16 15:38 | 8/2/2016 | 1608009-27A | LEAD | 6 | PPB | 15 PPB |
| 049-28A | Craft Room Sink Faucet | 7/28/16 15:40 | 8/3/2016 | 1608009-28A | LEAD | 3 | PPB | 15 PPB |

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Scott Elementary School

| | | | | | | | | |
|---------|------------------------------|---------------|----------|-------------|------|------|-----|--------|
| 049-29A | Media Room Drinking Fountain | 7/28/16 15:42 | 8/3/2016 | 1608009-29A | LEAD | 16 | PPB | 15 PPB |
| 049-30A | Hall Drinking Fountain 3 | 7/28/16 15:20 | 8/3/2016 | 1608009-30A | LEAD | 21 | PPB | 15 PPB |
| 049-31A | Room B1 Sink Faucet | 7/28/16 15:22 | 8/2/2016 | 1608009-31A | LEAD | 4 | PPB | 15 PPB |
| 049-32A | Room B1 Drinking Fountain | 7/28/16 15:22 | 8/3/2016 | 1608009-32A | LEAD | 2 | PPB | 15 PPB |
| 049-33A | Room B2 Sink Faucet | 7/28/16 15:24 | 8/2/2016 | 1608009-33A | LEAD | 7 | PPB | 15 PPB |
| 049-34A | Room B2 Drinking Fountain | 7/28/16 15:24 | 8/3/2016 | 1608009-34A | LEAD | 8 | PPB | 15 PPB |
| 049-35A | Room B3 Sink Faucet | 7/28/16 15:28 | 8/3/2016 | 1608009-35A | LEAD | 1 | PPB | 15 PPB |
| 049-36A | Room B3 Drinking Fountain | 7/28/16 15:28 | 8/3/2016 | 1608009-36A | LEAD | 3 | PPB | 15 PPB |
| 049-37A | Room B4 Sink Faucet | 7/28/16 15:30 | 8/3/2016 | 1608009-37A | LEAD | 1 | PPB | 15 PPB |
| 049-38A | Room B4 Drinking Fountain | 7/28/16 15:30 | 8/3/2016 | 1608009-38A | LEAD | 2 | PPB | 15 PPB |
| 049-39A | Room B5 Sink Faucet | 7/28/16 15:48 | 8/3/2016 | 1608009-39A | LEAD | 1 | PPB | 15 PPB |
| 049-40A | Room B5 Drinking Fountain | 7/28/16 15:48 | 8/3/2016 | 1608009-40A | LEAD | 1 | PPB | 15 PPB |
| 049-41A | Room B6 Sink Faucet | 7/28/16 15:34 | 8/4/2016 | 1608009-41A | LEAD | 3 | PPB | 15 PPB |
| 049-42A | Room B6 Drinking Fountain | 7/28/16 15:34 | 8/4/2016 | 1608009-42A | LEAD | 3 | PPB | 15 PPB |
| 049-43A | Hall Drinking Fountain 4 | 7/28/16 16:48 | 8/4/2016 | 1608009-43A | LEAD | 35 | PPB | 15 PPB |
| 049-44A | Room C1 Sink Faucet | 7/28/16 15:38 | 8/4/2016 | 1608009-44A | LEAD | 3 | PPB | 15 PPB |
| 049-45A | Room C1 Drinking Fountain | 7/28/16 15:38 | 8/4/2016 | 1608009-45A | LEAD | 2 | PPB | 15 PPB |
| 049-46A | Room C2 Sink Faucet | 7/28/16 15:40 | 8/2/2016 | 1608009-46A | LEAD | 4 | PPB | 15 PPB |
| 049-47A | Room C2 Drinking Fountain | 7/28/16 15:40 | 8/4/2016 | 1608009-47A | LEAD | 5 | PPB | 15 PPB |
| 049-48A | Room C3 Sink Faucet | 7/28/16 15:44 | 8/4/2016 | 1608009-48A | LEAD | 3 | PPB | 15 PPB |
| 049-49A | Room C3 Drinking Fountain | 7/28/16 15:44 | 8/4/2016 | 1608009-49A | LEAD | 1 | PPB | 15 PPB |
| 049-50A | Room C4 Sink Faucet | 7/28/16 15:46 | 8/2/2016 | 1608009-50A | LEAD | 2 | PPB | 15 PPB |
| 049-51A | Room C4 Drinking Fountain | 7/28/16 15:46 | 8/4/2016 | 1608009-51A | LEAD | 3 | PPB | 15 PPB |
| 049-52A | Room C5 Sink Faucet | 7/28/16 15:41 | 8/2/2016 | 1608009-52A | LEAD | 3 | PPB | 15 PPB |
| 049-53A | Room C5 Drinking Fountain | 7/28/16 15:41 | 8/4/2016 | 1608009-53A | LEAD | 3 | PPB | 15 PPB |
| 049-54A | Room C6 Sink Faucet | 7/28/16 15:46 | 8/4/2016 | 1608009-54A | LEAD | 4 | PPB | 15 PPB |
| 049-55A | Room C6 Drinking Fountain | 7/28/16 15:46 | 8/4/2016 | 1608009-55A | LEAD | 7 | PPB | 15 PPB |
| 049-56A | Room N2 Drinking Fountain | 7/28/16 16:22 | 8/5/2016 | 1608009-56A | LEAD | <1.0 | PPB | 15 PPB |
| 049-57A | Room N6 Sink Faucet | 7/28/16 16:25 | 8/2/2016 | 1608009-57A | LEAD | 6 | PPB | 15 PPB |
| 049-58A | Room N6 Drinking Fountain | 7/28/16 16:25 | 8/4/2016 | 1608009-58A | LEAD | 4 | PPB | 15 PPB |

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Scott Elementary School

| | | | | | | | | |
|---------|---------------------------|---------------|----------|-------------|------|------|-----|--------|
| 049-59A | Room N7 Sink Faucet | 7/28/16 16:29 | 8/4/2016 | 1608009-59A | LEAD | 5 | PPB | 15 PPB |
| 049-60A | Room N7 Drinking Fountain | 7/28/16 16:29 | 8/4/2016 | 1608009-60A | LEAD | 4 | PPB | 15 PPB |
| 049-61A | Room N8 Sink Faucet | 7/28/16 16:34 | 8/4/2016 | 1608009-61A | LEAD | <1.0 | PPB | 15 PPB |
| 049-62A | Room N8 Drinking Fountain | 7/28/16 16:34 | 8/4/2016 | 1608009-62A | LEAD | <1.0 | PPB | 15 PPB |
| 049-63A | Room N9 Sink Faucet | 7/28/16 16:36 | 8/4/2016 | 1608009-63A | LEAD | <1.0 | PPB | 15 PPB |
| 049-64A | Room N9 Drinking Fountain | 7/28/16 16:36 | 8/4/2016 | 1608009-64A | LEAD | <1.0 | PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Copper is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Scott Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 049-01B Kitchen Sink Faucet | 7/28/16 15:04 | 8/24/2016 | 1608010-01A | LEAD | 6 PPB | 15 PPB |
| 049-04B Break Room Sink Faucet | 7/28/16 15:01 | 8/24/2016 | 1608010-04A | LEAD | 40 PPB | 15 PPB |
| 049-05B MRS Power Room Sink Faucet | 7/28/16 15:11 | 8/24/2016 | 1608010-05A | LEAD | 47 PPB | 15 PPB |
| 049-10B Room A7 Sink Faucet | 7/28/16 15:07 | 8/24/2016 | 1608010-10A | LEAD | 6 PPB | 15 PPB |
| 049-29B Media Room Drinking Fountain | 7/28/16 15:43 | 8/24/2016 | 1608010-29A | LEAD | 6 PPB | 15 PPB |
| 049-30B Hall Drinking Fountain 3 | 7/28/16 15:21 | 8/24/2016 | 1608010-30A | LEAD | 29 PPB | 15 PPB |
| 049-43B Hall Drinking Fountain 4 | 7/28/16 16:49 | 8/24/2016 | 1608010-43A | LEAD | 23 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (D) Sample Data
Scott Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 049-43D Hall Drinking Fountain 4 | 11/18/2016 5:47 | 2/1/2017 | 4392 | LEAD | 16 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (E) Sample Data
Scott Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 049-43E Hall Drinking Fountain 4 | 4/6/2017 8:13 | 4/11/2017 | 18162 | COPPER | 0.0 PPM | 1.3 PPM |

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level